

INFINIGY®

FROM ZERO TO INFINIGY
the solutions are endless

1033 WATERVLIET SHAKER RD, ALBANY, NY 12205

February 16, 2021

Jason Blinkhorn
Project Manager
401-787-6007
jblinkhorn@qualtekwireless.com
16 Esquire Rd, N Billerica MA 01862

RE:	PE Close Out Letter	
	AT&T Site Name:	Scotland-Huntington Road
	AT&T Site ID:	CTL01242
	FA Site Number:	10050915
	Site Address:	165 Huntington Road Scotland, CT 06264

To Whom It May Concern,

Infinigy has conducted a post construction review of the above-mentioned site. Infinigy has prepared the drawings for the above-mentioned site and as such, we have conducted a final review of the proposed installation for the sole purpose to verify that the installation was completed in accordance with the site plans.

Based on our review of the Signed and Sealed Engineering Drawings for this site completed by Infinigy (Revision 2, Dated 10/28/19), and contractor-provided As-Built Drawings & closeout photos, the following items deviate from the original site plans:

- Existing Power Plant and Battery Rack replaced with new Power Plant and Batteries
- (2) Fiber Cables installed
- Proposed and existing DC/Fiber Squids mounted to main mast above tower top.

The above deviations do not negatively affect the integrity of the project and therefore, it is the opinion of Infinigy that the site was built in general conformance with the site plans as prepared by Infinigy.

Please free to contact me at (518) 690-0790 if you have any questions or require additional information.

Sincerely,
Chris Warren, P.E.
Infinigy Engineering

New York Georgia California New Jersey Colorado Florida New Hampshire

INFINIGY®