

Filed by:

G. Scott Shepherd, Sr. Property Specialist - SBA Communications 134 Flanders Rd., Suite 125, Westborough, MA 01581 508.251.0720 x 3807 - GShepherd@sbasite.com

December 10, 2021

Melanie A. Bachman **Executive Director** Connecticut Siting Council Ten Franklin Square New Britain, CT 06051

RE: Notice of Exempt Modification 225 Grist Mill Rd., Simsbury, CT

> Latitude: 41.866708 Longitude: -72.815772

T-Mobile Site #: CTHA531A\_Hardening

Dear Ms. Bachman:

T-Mobile currently maintains nine (9) antennas at the 131-foot level of the existing 150-foot Monopole Tower at 225 Grist Mill Rd., CT. The tower is owned by SBA Towers II, LLC. The property is owned by Ensign-Bickford Realty Corporation. T-Mobile now intends to add one (1) Generac RD025 Diesel generator and 4' x 10' concrete pad, within a 76' x 75' fenced compound lease area. The proposed generator and concrete pad will sit fully within the leased area of the compound and will not require additional space for the supplementary tank.

#### Ground

## **Install New:**

- (1) Generac RD0 25kw Diesel generator
- (1) 4' x 10' concrete pad
- (1) 2" RGS conduit for Ethernet cable for generator & Alarms from exist. Equip. cabinet to prop.
- (1) 2" RGS conduit for emergency power from prop. generator to prop. ATS
- (1) 1-1/2" RGS conduit for generator heater & Battery from exist. PPC to prop. generator
- (1) 2" RGS conduit for emergency power from proposed ATS to existing PPC
- Generac 200A, 120/240v automatic transfer switch mounted to proposed H-Frame



# Remaining:

- T-Mobile Emerson Nextend Compact 2416 fiber cabinet
- Ericsson B160 Cabinet
- Ericsson 6160 Cabinet
- RBS6201 ODE equip. cabinet
- Existing equip/ cabinet
- Existing PPC
- T-Mobiles cables routed along existing Ice Bridge
- Existing GPS antenna mounted to existing Ice Bridge
- T-Mobile conduit

# Reason for Request / Change in Generator Size and Fuel

In an effort to further enhance network reliability, T-Mobile is proposing to install a diesel-based backup generator, the Generac RD025 25kw Diesel Generator. T-Mobile is currently in the middle of a National Hardening Project.

The proposed diesel generator measures  $84.2'' \times 35'' \times 91.7''$  (w/fuel tank:  $103.4'' \times 35'' \times 91.7''$ ). It will sit fully within the leased area of the compound and will not require additional space for the supplementary tank.

Generac's RD025 25kw Diesel Generator carries up to 98 hours of run time with 100% load, 125 hours of run time with a 75% load and 161 hours of run time with a 50% load. It can operate in temperatures of 122 degrees Fahrenheit.

# **Monitoring, Prevention and Containment Measures**

It will be filled by a licensed fuel filling company. The Generac's RD025 25kw Diesel Generator is fuel efficient, rodent and corrosion resistant, and has a sound attenuated aluminum enclosure with a Rated Load Sound Output at 23ft. of -65dB. It further supports advanced, remote monitoring for diagnostics and control and is installed with a tank alarm system. The Sound Output from the Generac RD025kw meets/exceeds the allowable noise emissions levels for the Town of Simsbury, Hartford County, CT which is as follows:

# Maximum Continuous Noise Levels (measured in dBA):

No Person in a residential zone shall emit noise beyond the boundaries of his/her premises in excess of the noise levels stated herein and applicable to adjacent residential, commercial or industrial zones:

# Receptor's Zone: Maximum Level:

- Industrial...62 dBA
- Commercial...55 dBA
- Residential/Day...55 dBA
- Residential/Night...45 dBA



The proposed modification will remain within the existing  $76' \times 75'$  fenced compound. The new generator and tank will be surrounded by the existing security fence and double leaf gate and will be placed on a plinth secured to a proposed  $4' \times 10'$  concrete pad.

# Additional safety specifications:

- Automatic Voltage Regulation with Over and Under Protection
- Overspeed Shutdown
- High Tempature Shutdown
- Meets ANSI/IEEE C62.41, SA CSA 22.2, SAE J1349, NFPA 37, 70 99

# Revised Construction Drawings and Full Spec Sheets referencing the above are attached herewith.

The revised ground configuration continues to meet all requirements for a Notice of Exempt Modifications. The request remains technically, legally, environmentally, and economically feasible and meets public safety concerns per Connecticut General Statute Section 16-50aa.

There is no environmental impact associated with the revised ground configuration, including, but not limited to, visibility, wetlands and water resources, air quality or noise.

# T-Mobile's revised ground configuration:

- Will not have any significant adverse visual impact on the surrounding areas
- Does not affect or alter the existing site with regard to wetlands, water resources or air quality
- The generator would only be used in cases of emergency and would provide backup time of approximately 60 hours in time of need.

The proposed work is not thought to have any substantial adverse environmental impact. Public Need for the additional coverage outweighs any minor environmental effects that would result from the construction, operation, and maintenance of the proposed collocation.

# A Map of the Site Showing Nearest Wetlands, depicted in feet, is attached herewith.

Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies §16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. §16.50j-72(b)(2). In accordance with R.C.S.A. § 16.50j-73, a copy of this letter is being sent to the Town of Simsbury's First Selectman, Wendy Mackstuitis, Henry Miga, Building Official, as well as to the property owner. (Separate notice is not being sent to tower owner, as it belongs to SBA.)

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. §16.50j-72(b)(2).

- 1. The proposed modifications will not result in an increase in the height of the existing structure.
- 2. The proposed modification will not require the extension of the site boundary.
- 3. The proposed modifications will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.



- 4. The operation of the replacement antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard.
- 5. The proposed modification will not cause a change or alteration in the physical or environmental characteristics of the site.
- 6. The existing structure and its foundation can support the proposed loading.

For the foregoing reasons, T-Mobile respectfully submits that the proposed modifications to the above-referenced telecommunication facility constitute an exempt modifications under R.C.S.A. § 16-50j-72(b)(2).

# Sincerely,

G. Scott Shepherd
Sr. Property Specialist
SBA COMMUNICATIONS CORPORATION
134 Flanders Rd., Suite 125
Westborough, MA 01581
508.251.0720 x3807 + T
508.366.2610 + F
508.868.6000 + C
GShepherd@sbasite.com

# Attachments

cc: Wendy Mackstuitis, First Selectman / with attachments
Town of Simsbury, 933 Hopmeadow St., Simsbury, CT 06070
Henry Miga, Building Official / with attachments
Town of Simsbury, 933 Hopmeadow St., Simsbury, CT 06070
Ensign-Bickford Realty Corporation / with attachments
999 17<sup>th</sup> St., Suite 901, Denver, CO 80202 {SBA remit to address on file}


# **Exhibit List**

Exhibit 1	Check Copy	х
Exhibit 2	FedEx Labels	x
Exhibit 3	Property Card	x
Exhibit 4	Property Map	x
Exhibit 5	Zoning Documents	CSC Docket No. 203 (11/7/01)
Exhibit 6	Construction Drawings	Chappell 10/29/21
Exhibit 7	Generator Specifications	x
Exhibit 8	Wetlands Map	х

# EXHIBIT 1 Copy of Check for filing fee.

# EXHIBIT 2

FedEx Labels



# After printing this label:

- 1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
- 2. Fold the printed page along the horizontal line.
- 3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning**: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com.FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery,misdelivery,or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim.Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental,consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss.Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

Page 1 of 2 **Detailed Tracking** 



#### TRACK ANOTHER SHIPMENT

775458401229



ESTIMATED DELIVERY DATE

12/13/21 before 11:30 am ?





# **ADD NICKNAME**

# Estimated delivery date: Monday, 12/13/2021 before 11:30 am

The delivery date may be updated when FedEx receives the package.



Travel History Shipment Facts Travel History TIME ZONE Local Scan Time Friday, December 10, 2021 11:58 AM Shipment information sent to FedEx Shipment Facts TRACKING NUMBER SERVICE WEIGHT 775458401229 FedEx Priority Overnight 2 lbs / 0.91 kgs **TOTAL PIECES TOTAL SHIPMENT WEIGHT TERMS** 2 lbs / 0.91 kgs Shipper SHIPPER REFERENCE **PACKAGING** SPECIAL HANDLING SECTION 10-56-92009-6089 FedEx Pak Deliver Weekday

STANDARD TRANSIT

11/29/99 ?

ANTICIPATED SHIP DATE

12/10/21 ③



# After printing this label:

- 1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
- 2. Fold the printed page along the horizontal line.
- 3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning**: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com.FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery,misdelivery,or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim.Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental,consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss.Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

Page 1 of 2 **Detailed Tracking** 



## TRACK ANOTHER SHIPMENT

775458430409









# Estimated delivery date: Monday, 12/13/2021 before 11:30 am

The delivery date may be updated when FedEx receives the package.



#### LABEL CREATED

Shipment information sent to FedEx

## **GET STATUS UPDATES**

#### FROM

SBA COMMUNICATIONS CORPORATION

Rick Woods

134 Flanders Rd Suite 125 WESTBOROUGH, MA US 01581 508-614-0389

# TO

Wendy Mackstuitis Town of Simsbury

First Selectman 933 Hopmeadow St SIMSBURY, CT US 06070 508-251-0720

MANAGE DELIVERY ✓

Travel History Shipment Facts **Travel History** TIME ZONE Local Scan Time Friday, December 10, 11:59 AM Shipment information sent to FedEx Shipment Facts TRACKING NUMBER SERVICE WEIGHT 775458430409 FedEx Priority Overnight 0.5 lbs / 0.23 kgs **TOTAL PIECES** TOTAL SHIPMENT WEIGHT **TERMS** 0.5 lbs / 0.23 kgs Shipper



# After printing this label:

- 1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
- 2. Fold the printed page along the horizontal line.
- 3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning**: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com.FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery,misdelivery,or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim.Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental,consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss.Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

Page 1 of 2 **Detailed Tracking** 



#### TRACK ANOTHER SHIPMENT

775458443225







**ADD NICKNAME** 

# Estimated delivery date: Monday, 12/13/2021 before 11:30 am

Shipping label has been created. The status will be updated when shipment begins to travel.



#### LABEL CREATED

Shipment information sent to FedEx

## **GET STATUS UPDATES**

#### FROM

SBA COMMUNICATIONS CORPORATION

Rick Woods

134 Flanders Rd Suite 125 WESTBOROUGH, MA US 01581 508-614-0389


# то

Henry Miga Town of Simsbury

**Building Official** 933 Hopmeadow St SIMSBURY, CT US 06070 508-251-0720

MANAGE DELIVERY ✓

Travel History Shipment Facts **Travel History** TIME ZONE Local Scan Time Friday, December 10, 12:00 PM Shipment information sent to FedEx Shipment Facts TRACKING NUMBER SERVICE WEIGHT 775458443225 FedEx Priority Overnight 0.5 lbs / 0.23 kgs **TOTAL PIECES** TOTAL SHIPMENT WEIGHT **TERMS** 0.5 lbs / 0.23 kgs Shipper



# After printing this label:

- 1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
- 2. Fold the printed page along the horizontal line.
- 3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning**: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com.FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery,misdelivery,or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim.Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental,consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss.Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

Page 1 of 2 **Detailed Tracking** 



#### TRACK ANOTHER SHIPMENT

775458479720









# Estimated delivery date: Monday, 12/13/2021 before 11:30 am

The delivery date may be updated when FedEx receives the package.



#### LABEL CREATED

Shipment information sent to FedEx

## **GET STATUS UPDATES**

#### FROM

SBA COMMUNICATIONS CORPORATION

Rick Woods

134 Flanders Rd Suite 125 WESTBOROUGH, MA US 01581 508-614-0389

# TO

Ensign-Bickford Realty Corp


999 17th St Suite 901 DENVER, CO US 80202 508-251-0720

MANAGE DELIVERY ✓

Travel History Shipment Facts **Travel History** TIME ZONE Local Scan Time Friday, December 10, 12:02 PM Shipment information sent to FedEx Shipment Facts TRACKING NUMBER SERVICE WEIGHT 775458479720 FedEx Priority Overnight 0.5 lbs / 0.23 kgs **TOTAL PIECES** TOTAL SHIPMENT WEIGHT **TERMS** 0.5 lbs / 0.23 kgs Shipper

# **EXHIBIT 3**

# Property Card



Map Block Lot

F11 103 005

Building #

Unique Identifier

30569027

# **Property Information**

<b>Property Location</b>	225 GRIST MILL ROAD
Mailing Address	P O BOX 711
Mailing Address	SIMSBURY CT 06070
Land Use	Commercial Vacant Land
Zoning Code	I-2
Neighborhood	0239

Owner	ENSIGN-BICKFORD REALTY CORPORATION
Co-Owner	
Book / Page	0294/0600
Land Class	Commercial
Census Tract	
Acreage	0.23

# **Valuation Summary**

(Assessed value = 70% of Appraised Value)

Item	Appraised	Assessed
Buildings	0	0
Outbuildings	120000	84000
Land	490188	343130
Total	610188	427130

# **Utility Information**

Electric	No
Gas	No
Sewer	No
Public Water	No
Well	No



# No Photo Available

# **Primary Construction Details**

Year Built	
Building Desc.	
Building Style	
Stories	
Exterior Walls	
Exterior Walls 2	
Interior Walls	
Interior Walls 2	
Interior Floors 1	
Interior Floors 2	

Heating Fuel	
Heating Type	
AC Type	
Bedrooms	
Full Bathrooms	
Half Bathrooms	
Extra Fixtures	
Total Rooms	
Bath Style	
Kitchen Style	
Occupancy	

Livable Area (ft)	
Building Use	
Building Condition	
Frame Type	
Building Grade	
Fireplaces	
Wood Stoves	
Attic Access	
Roof Style	
Roof Cover	

Bsmt Area	
Fin Bsmt Area	
Fin Bsmt Quality	
Bsmt Access	
Bsmt Gar	
Bsmt Sump Pump	

# Town of Simsbury, CT

**ENSIGN-BICKFORD REALTY CORPORATION** 

**Property Listing Report** 

Map Block Lot

F11 103 005

Building #

Unique Identifier

30569027

Detached Outbuildings				
Type	Description	Area (sq ft)	Condition	Year Built
Tower	Cell Tower	1	Average	0
			_	
Attached Extra Features	<u>s</u>			
Туре	Description	Area (sq ft)	Condition	Year Built
Sales History				
Owner of Record		Book/ Page	Sale Date	Sale Price


0294\_0600

11/25/1985

0

# EXHIBIT 4 Property Map

# Google Maps Grist Mill Rd



Map data ©2021 500 ft ■

# Google Maps 41°52'00.2"N 72°48'56.8"W



Imagery ©2021 CNES / Airbus, Maxar Technologies, U.S. Geological Survey, USDA Farm Service Agency, Map data ©2021

# EXHIBIT 5 Zoning Documents

SITE NAME:	Simsbury 2	SITE ID:	CT1002	2-A	
Transaction:	Mariner Tower				Jill
	ZONING/PERMITTING COMPL	ETION F	ORM		
Address: 22	25 Grist Mill Road				
Landlord/Parcel	ID:				
Jurisdiction:	Connecticut Siting Council	Zoning	District: _		
Zoning Approval	Type: CSC Approval			Case #: _	
Approval Date:			Tower Buil	d Date: _	
Conditions of Ap	proval:		Yes	<u>No</u>	N/A
Removal E	Bond			$\boxtimes$	
Site Plan S	Submittal			$\boxtimes \Box$	
Fall Zone				$\boxtimes$	
Periodic In	nspections			$\boxtimes$	
Periodic R	Reporting			$\boxtimes$	
Approval F	Renewal			$\boxtimes$	
Additional	Conditions			⊠	
Cell towers curren	ntly fall under complete jurisdiction of Connecticut Siti Public need issued under Docket 203 on 11/7/01. No	ng Council	(CSC). Ce	ertificate of Er	vironmental
via letter reference	ing Docket number 203. Any modifications/collocation	ns must go	through C	SC Review.	
	: Carriann Mulcahy (CSC)				
Phone: 86	60-827-2940 Fax:				_
	prcement:Fax:				
Phone:					
Submitted by:	Satches Costes Date Zoning Compliance	e:	4/19/1	27	
	TO BE COMPLETED BY CO	ORPORA	TE		
		<u>Ye</u>	s <u>No</u>	N/A	PE
Zoning Approva	l Attached (required)	×	ı 🗆		
Ordinance Attac	ched (required)		] ⊠		
Building Permit	Attached (required) 108897				Date Recd 6/14/02
Certificate of O	ccupancy or Compliance (CO) attached (require	ed) 🗵	<b>3</b> 0		12/31/02
Zoning Manage	er Approval: Diane E. Borchardt, AICP			_ Date _	119/2007



# CONNECTICUT SITING COUNCIL



ABOUT US PROGRAMS AND SERVICES PUBLICATIONS FORMS CONTACT U

CSC Search:



Advanced Search

- >> COUNCIL MEMBERSHIP
- >> DIRECTIONS
- >> AUDIO LINK
- >> PUBLIC PARTICIPATION
- >> APPLICATION GUIDES
- >> PROCEEDINGS PROCESS
- TELECOMMUNICATION DATABASE
- STATUS
- PENDING PROCEEDINGS
- SELECTRIC TRANSMISSION UPGRADE PROJECTS

# Connecticut Siting Council Ten Franklin Square New Britain, CT 06051

Daniel F. Caruso, Chairman

S. Derek Phelps, Executive Director

Phone: (860) 827-2935 Fax: (860) 827-2950

> E-mail Address: siting.council @ct.gov

#### NOTICE TO USERS

The Connecticut Siting
Council posts filed
documents to this site as a
public service. The Council
disclaims any llability for the
content of submissions made
by parties, intervenors,
public officials, and the
general public. Further, while
the Council seeks to be
complete in its postings, the
Council urges users of this
site to confirm with the
submitter the completeness
of the postings made. The

**DOCKET NO. 203** - New England Site Management application for a Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a cellular telecommunications facility located on Grist Mill Road, known as the Powder Forest, Simsbury, Connecticut.

Siting

Novembe 8 1

7, 2001

Connectic

# **Decision and Order**

Pursuant to the foregoing Findings of Fact and Opinion, the Connecticut Sitin Council (Council) finds that the effects associated with the construction, operation, and maintenance of a telecommunications facility at the proposed site in Simsbury, Connecticut, including effects on the natural environment; ecological integrity and balance; public health and safety; scenic, historic, an recreational values; forests and parks; air and water purity; and fish and wildlife are not disproportionate either alone or cumulatively with other effec when compared to need, are not in conflict with the policies of the State concerning such effects, and are not sufficient reason to deny the application and therefore directs that a Certificate of Environmental Compatibility and Public Need, as provided by General Statutes § 16-50k, be issued to New England Site Management for the construction, maintenance and operation o cellular telecommunications facility at the proposed site located on Grist Mill Road, known as the Powder Forest, Simsbury, Connecticut.

The facility shall be constructed, operated, and maintained substantially as specified in the Council's record in this matter, and subject to the following conditions:

- 1. The tower shall be constructed as a monopole, no taller than necessary to provide the proposed telecommunications services, sufficient to accommodat the antennas of the Town of Simsbury, Cingular, Nextel, AT&T and other entities, both public and private, but such tower shall not exceed a height of 130 feet above ground level unless sufficient carriers commit to placement of antennas on the tower and no space on the tower exists below 130 feet, while if approved by the Council through a petition pursuant to Sections 16-50j-38 through 16-50j-40 of the Regulations of Connecticut State Agencies, shall authorize the construction or extension of the tower to a maximum height of 150 feet above ground level (AGL).
- 2. The Certificate Holder shall prepare a D&M Plan for this site in compliance with Sections 16-50j-75 through 16-50j-77 of the Regulations of Connecticut State Agencies. The D&M Plan shall be submitted to and approved by the Council prior to the commencement of facility construction and shall include: final site plan(s) for site development to include the location and specification for the tower foundation, placement of carrier antennas, tower height,

posting of any document does not constitute or imply endorsement by the Connecticut Siting Council. Finally, the Connecticut Siting Council assumes no responsibility for the use of documents posted on this site.

For further information about the proper use of material posted on this site, please see the State of Connecticut disclaimer.

#### E-ALERTS

Receive CSC news updates by e-mail. >>> Subscribe now or update your e-Alerts

>> LOGIN

provisions for tower extension, equipment buildings, security fence, access road, and utility line; construction plans for site clearing, tree trimming, wate drainage, and erosion and sedimentation controls consistent with the Connecticut Guidelines for Soil Erosion and Sediment Control, as amended; landscaping and provisions to protect the existing vegetative buffer that wou extend around the facility compound; a tower finish that may include paintin and provisions for the prevention and containment of spills and/or other discharge into surface water and groundwater bodies.

- 3. The Certificate Holder shall, prior to the commencement of operation, provide the Council worst-case modeling of electromagnetic radio frequency power density of all proposed entities' antennas at the closest point of uncontrolled access to the tower base, consistent with Federal Communicatic Commission, Office of Engineering and Technology, Bulletin No. 65, August 1997. The Certificate Holder shall provide a recalculated report of electromagnetic radio frequency power density if and when circumstances in operation cause a change in power density above the levels calculated and provided pursuant to this Decision and Order.
- 4. Upon the establishment of any new State or Federal radio frequency standards applicable to frequencies of this facility, the facility granted herein shall be brought into compliance with such standards.
- 5. The Certificate Holder shall permit public or private entities to share space the proposed tower for fair consideration, or shall provide any requesting ent with specific legal, technical, environmental, or economic reasons precluding such tower sharing.
- 6. If the facility does not initially provide, or permanently ceases to provide cellular services following completion of construction, this Decision and Order shall be void, and the Certificate Holder shall dismantle the tower and removall associated equipment or reapply for any continued or new use to the Coubefore any such use is made.
- 7. Any antenna that becomes obsolete and ceases to function shall be remov within 60 days after such antennas become obsolete and ceases to function.
- 8. Unless otherwise approved by the Council, this Decision and Order shall be void if all construction authorized herein is not completed within three years the effective date of this Decision and Order or within three years after all appeals to this Decision and Order have been resolved.

Pursuant to General Statutes § 16-50p, we hereby direct that a copy of the Findings of Fact, Opinion, and Decision and Order be served on each person listed below, and notice of issuance shall be published in <a href="#">The Hartford Coura</a>

By this Decision and Order, the Council disposes of the legal rights, duties, a privileges of each party named or admitted to the proceeding in accordance with Section 16-50j-17 of the Regulations of Connecticut State Agencies.

The parties and intervenors to this proceeding are:

New England Site Management, LLC (NESM)

Wayne Kemp New England Site Management LLP

1050 Buckley Highway Union, CT 06076

Andrew Lord Murtha Cullina, LLP City Place 1, 185 Asylum Stree Hartford, CT 06103-3469

Douglas Roberts, AIA URS Corporation AES 795 Brook Street, Building 5 Rocky Hill, CT 06067

Town of Simsbury Robert M. DeCrescenzo, Esq. Updike, Kelly & Spellacy, P.C.

P.O. Box 231277 One State Street

Hartford, CT 06123-1277

Crown Atlantic Company Kenneth C. Baldwin

Robinson & Cole 280 Trumbull Street Hartford, CT 06103-3597

SNET Mobility, LLC, d/b/a Peter W. van Wilgen Cingular Wireless (Cingular) SNET Mobility, LLC

500 Enterprise Drive

Rocky Hill, CT 06067-3900

AT&T Wireless Services, LLC Christopher B. Fisher, Esq.

Cuddy & Feder & Worby LLP

90 Maple Avenue

White Plains, NY 10601-5196

Nextel Communications of the Christopher B. Fisher, Esq. Mid-Atlantic, Inc. d/b/a Nextel Cuddy & Feder & Worby LLP

Communications 90 Maple Avenue

White Plains, NY 10601-5196

Content Last Modified on 8/12/2002 9:34:01 AM

Home | CT.gov Home | Send Feedback

State of Connecticut Disclaimer and Privacy Policy Copyright © 2002 - 2007 State of Connecticut



own of Simsburu

SIMBBURY, CONNECTICUT 06070

Office of Community Planning and Development

August 13, 2002

Mr. S. Derek Phelps Executive Director Connecticut Siting Council 10 Franklin Square New Britain, Connecticut 06051

Re: New England Site Management, LLC: Development and Management Plan

Dear Mr. Pheips:

I write on behalf of the Town of Simsbury in support of New England Site Management LLC's ("NESM") request for revisions to the Development and Management Plan ("D&M Plan") for an approved telecommunications tower and ancillary facilities in the Powder Forest Business Park.

I have reviewed NESM's plans to move a portion of the access road for the facility approximately 100 feet north of the original alignment. This configuration is necessary to accommodate future plans for a large parcel of the Powder Forest Business Park. I also reviewed a soil report prepared by Mr. Henry Mosller which indicated that there are no wetlands within 75 feet of the revised road alignment. Based on my review of these documents, the Town of Simsbury has no objection to NESM's request to revise the D&M Plan.

Thank you for considering these comments. If you have any questions or require additional information, please contact me.

Sincerely.

William S. Voelker, AICI

Director of Community Planning and Development

Mr. Wayne Kemp

Mr. Ken Lindeland

Mr. Robert Stevens

Andrew W. Lord, Esq.

Mr. Thomas E. Vincent, First Select nan

Telephone (860) 658-3245 Factorile (860) 658-3217

n staret m/music/simbury

830 - 430 Tausday through Frida

# **EXHIBIT 6**

**Constrcution Drawings** 

225 GRIST MILL ROAD SIMSBURY, CT 06070 HARTFORD COUNTY

SITE NO.: CTHA531A

SITE TYPE: 150'± MONOPOLE

PROJECT TYPE: NATIONAL HARDENING PROJECT

SHEET INDEX

DESCRIPTION

TITLE SHEET

GENERAL NOTES

I GENERATOR DETAILS

COMPOUND & EQUIPMENT PLANS

GENERATOR SPECIFICATIONS 1

GENERATOR SPECIFICATIONS 2

ELECTRIC & GROUNDING DETAILS

SHEET NO.

GN-1

A-2

# SBA SIMSBURY MONOPOLE

# DATE: DATE:

**TOWER OWNER:** DATE: DATE:

**OPERATIONS:** 

ZONING/SITE ACQ .:

# TECHNICIAN SITE SAFETY NOTES

DATE:

DATE:

**LOCATION** SPECIAL RESTRICTIONS SECTOR A: ACCESS BY CERTIFIED CLIMBER SECTOR B: ACCESS BY CERTIFIED CLIMBER SECTOR C: ACCESS BY CERTIFIED CLIMBER SECTOR D: ACCESS BY CERTIFIED CLIMBER GPS/LMU: UNRESTRICTED

RADIO CABINETS: UNRESTRICTED PPC DISCONNECT: UNRESTRICTED MAIN CIRCUIT D/C: UNRESTRICTED NIU/T DEMARC: UNRESTRICTED OTHER/SPECIAL: NONE

GENERAL NOTES

**APPROVALS** 

**CONSTRUCTION:** 

**RF ENGINEERING:** 

**PROJECT MANAGER:** 

- THE CONTRACTOR SHALL GIVE ALL NOTICES AND COMPLY WITH ALI LAWS. ORDINANCES. RULES, REGULATIONS AND LAWFUL ORDERS OF ANY PUBLIC AUTHORITY, MUNICIPAL AND UTILITY COMPANY SPECIFICATIONS, AND LOCAL AND STATE JURISDICTIONAL CODES BEARING ON THE PERFORMANCE OF THE WORK. THE WORK PERFORMED ON THE PROJECT AND THE MATERIALS INSTALLED SHALL BE IN STRICT ACCORDANCE WITH ALL APPLICABLE CODES, REGULATIONS, AND ORDINANCES.
- THE ARCHITECT/ENGINEER HAVE MADE EVERY EFFORT TO SET FORTH IN THE CONSTRUCTION AND CONTRACT DOCUMENTS THE COMPLETE SCOPE OF WORK. THE CONTRACTOR BIDDING THE JOB IS NEVERTHELESS CAUTIONED THAT MINOR OMISSIONS OR ERRORS IN THE DRAWINGS AND OR SPECIFICATIONS SHALL NOT EXCUSE SAID CONTRACTOR FROM COMPLETING THE PROJECT AND IMPROVEMENTS IN ACCORDANCE WITH THE INTENT OF THESE DOCUMENTS.
- THE CONTRACTOR OR BIDDER SHALL BEAR THE RESPONSIBILITY OF NOTIFYING (IN WRITING) THE OMNIPOINT REPRESENTATIVE OF ANY CONFLICTS, ERRORS, OR OMISSIONS PRIOR TO THE SUBMISSION OF CONTRACTOR'S PROPOSAL OR PERFORMANCE OF WORK. IN THE EVENT OF DISCREPANCIES THE CONTRACTOR SHALL PRICE THE MORE COSTLY OR EXTENSIVE WORK, UNLESS DIRECTED IN WRITING OTHERWISE.
- THE SCOPE OF WORK SHALL INCLUDE FURNISHING ALL MATERIALS, EQUIPMENT, LABOR AND ALL OTHER MATERIALS AND LABOR DEEMED NECESSARY TO COMPLETE THE WORK/PROJECT AS DESCRIBED
- THE CONTRACTOR SHALL VISIT THE JOB SITE PRIOR TO THE SUBMISSION OF BIDS OR PERFORMING WORK TO FAMILIARIZE HIMSELF WITH THE FIELD CONDITIONS AND TO VERIFY THAT THE PROJECT CAN BE CONSTRUCTED IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.
- THE CONTRACTOR SHALL OBTAIN AUTHORIZATION TO PROCEED WITH CONSTRUCTION PRIOR TO STARTING WORK ON ANY ITEM NOT CLEARLY DEFINED BY THE CONSTRUCTION DRAWINGS/CONTRACT DOCUMENTS.
- THE CONTRACTOR SHALL INSTALL ALL EQUIPMENT AND MATERIALS ACCORDING TO THE MANUFACTURER'S/VENDOR'S SPECIFICATIONS UNLESS NOTED OTHERWISE OR WHERE LOCAL CODES OR ORDINANCES TAKE PRECEDENCE.
- THE CONTRACTOR SHALL PROVIDE A FULL SET OF CONSTRUCTION DOCUMENTS AT THE SITE UPDATED WITH THE LATEST REVISIONS AND ADDENDUMS OR CLARIFICATIONS AVAILABLE FOR THE USE BY ALL PERSONNEL INVOLVED WITH THE PROJECT.
- THE CONTRACTOR SHALL SUPERVISE AND DIRECT THE PROJECT DESCRIBED HEREIN. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR ALL CONSTRUCTION MEANS, METHODS. TECHNIQUES, SEQUENCES AND PROCEDURES AND FOR COORDINATING ALL PORTIONS OF THE WORK UNDER THE CONTRACT.
- THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL NECESSARY CONSTRUCTION CONTROL SURVEYS, ESTABLISHING AND MAINTAINING ALL LINES AND GRADES REQUIRED TO CONSTRUCT ALL IMPROVEMENTS AS SHOWN HEREIN.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL PERMITS AND INSPECTIONS WHICH MAY BE REQUIRED FOR THE WORK BY THE ARCHITECT/ENGINEER, THE STATE, COUNTY OR LOCAL GOVERNMENT AUTHORITY.
- THE CONTRACTOR SHALL MAKE NECESSARY PROVISIONS TO PROTECT EXISTING IMPROVEMENTS, EASEMENTS, PAVING, CURBING, ETC. DURING CONSTRUCTION. UPON COMPLETION OF WORK, THE CONTRACTOR

- CONSTRUCTION ON OR ABOUT THE PROPERTY.
- 13. THE CONTRACTOR SHALL KEEP THE GENERAL WORK AREA CLEAN AND HAZARD FREE DURING CONSTRUCTION AND DISPOSE OF ALL DIRT. DEBRIS, RUBBISH AND REMOVE EQUIPMENT NOT SPECIFIED AS REMAINING ON THE PROPERTY. PREMISES SHALL BE LEFT IN CLEAN CONDITION AND FREE FROM PAINT SPOTS, DUST, OR SMUDGES OF
- 14. THE CONTRACTOR SHALL COMPLY WITH ALL OSHA REQUIREMENTS AS THEY APPLY TO THIS PROJECT.
- 15. THE CONTRACTOR SHALL NOTIFY THE PROJECT OWNER'S REPRESENTATIVE WHERE A CONFLICT OCCURS ON ANY OF THE CONTRACT DOCUMENTS. THE CONTRACTOR IS NOT TO ORDER MATERIAL OR CONSTRUCT ANY PORTION OF THE WORK THAT IS IN CONFLICT UNTIL CONFLICT IS RESOLVED BY THE LESSEE/LICENSEE
- 16. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, ELEVATIONS, PROPERTY LINES, ETC. ON THE JOB.
- 17. ALL UNDERGROUND UTILITY INFORMATION WAS DETERMINED FROM SURFACE INVESTIGATIONS AND EXISTING PLANS OF RECORD. THE CONTRACTOR SHALL LOCATE ALL UNDERGROUND UTILITIES IN THE FIELD PRIOR TO ANY SITE WORK.

AT LEAST 72 HOURS PRIOR TO DIGGING, THE CONTRACTOR IS **REQUIRED TO CALL DIG SAFE AT 811** 



# VICINITY MAP SCALE: 1" = 1000' - 0"

# **DIRECTIONS**

TURN LEFT ONTO S WASHINGTON ST. TURN RIGHT ONTO MA-123 E. TURN LEFT TO MERGE ONTO I-495 NORTH TOWARD MANSFIELD/MARLBORO. MERGE ONTO I-495 NORTH. TAKE EXIT 58 TO MERGE ONTO I-90 W VIA THE RAMP ON THE LEFT TOWARD ALBANY/SPRINGFIELD (PORTIONS TOLL). MERGE ONTO I-84 W VIA EXIT 9 TOWARD NEW YORK CITY/HARTFORD/US-20 (PORTIONS TOLL) (CROSSING INTO CONNECTICUT). MERGE ONTO I-291 W VIA EXIT 61 TOWARD WINDSOR. TAKE THE CT-218 EXIT, EXIT 1, TOWARD BLOOMFIELD. TURN LEFT ONTO CT-218. TURN RIGHT ONTO TYLER ST. TURN LEFT ONTO PARK AVE/CT-178. CONTINUE TO FOLLOW CT-178. TURN RIGHT ONTO SIMSBURY RD/CT-185. CONTINUE TO FOLLOW CT-185. TURN RIGHT ONTO HOPMEADOW ST/US-202 E/CT-10. TURN LEFT ONTO WEST ST/CT-167. TURN LEFT ONTO GRIST MILL RD. SITE WILL BE ON THE LEFT.

# PROJECT SUMMARY

DISCREPANCIES AT THE CONTRACTOR'S EXPENSE.

SCOPE OF WORK

REMOVE:

NO.

0

NONE

SITE NOTES

SITE NUMBER: CTHA531A SITE NAME: SBA SIMSBURY MONOPOLE SBA SITE NUMBER: CT10022-A SIMSBURY 2, CT SBA SITE NAME: SITE ADDRESS: 225 GRIST MILL ROAD SIMSBURY, CT 06070 PROPERTY OWNER: ENSIGN-BICKFORD REALTY CORP PO BOX 711 SIMSBURY, CT 06070 TOWER OWNER: SBA TOWERS II, LLC 8501 CONGRESS AVENUE BOCA RATON, FL 33487 PHONE: 561-226-9523 COUNTY: **HARTFORD** 

• 1 GENERATOR

THIS IS AN UNMANNED AND RESTRICTED ACCESS TELECOMMUNICATION FACILITY, AND IS

FOR THE PURPOSE OF PROVIDING PUBLIC CELLULAR SERVICE.

POTABLE WATER OR SANITARY SERVICE IS NOT REQUIRED.

BUILDING CODE: 2018 CONNECTICUT STATE BUILDING CODE

ELECTRICAL CODE: 2017 NATIONAL ELECTRICAL CODE

NO OUTDOOR STORAGE OR ANY SOLID WASTE RECEPTACLES REQUIRED.

ADA COMPLIANCE NOT REQUIRED

STRUCTURES AND ANTÉNNAS.

**ZONING DISTRICT:** 

ARCHITECT:

NOT FOR HUMAN HABITATION. IT WILL BE USED FOR THE TRANSMISSION OF RADIO SIGNAL

CONTRACTOR SHALL VERIFY ALL PLANS, EXISTING DIMENSIONS, AND CONDITIONS ON JOB

SITE. CONTRACTOR SHALL IMMEDIATELY NOTIFY THE ARCHITECT/ENGINEER IN WRITING OF ANY DISCREPANCIES BEFORE PROCEEDING WITH THE WORK. FAILURE TO NOTIFY THE

ARCHITECT/ENGINEER PLACE THE RESPONSIBILITY ON THE CONTRACTOR TO CORRECT THE

STRUCTURAL CODE: TIA/EIA-222-G STRUCTURAL STANDARDS FOR ANTENNA SUPPORTING

NEW CONSTRUCTION WILL CONFORM TO ALL APPLICABLE CODES AND ORDINANCES.

• 2 20A-1P BREAKERS

• 1 AUTOMATIC TRANSFER SWITCH

STRUCTURE TYPE: **MONOPOLE** STRUCTURE HEIGHT: 150'± APPLICANT: T-MOBILE NORTHEAST LLC 15 COMMERCE WAY, SUITE B

> CHAPPELL ENGINEERING ASSOCIATES, LLC. 201 BOSTON POST ROAD WEST. SUITE 101

NORTON, MA 02766

COMMERCIAL (I-2)

MARLBOROUGH, MA 01752 STRUCTURAL ENGINEER: CHAPPELL ENGINEERING ASSOCIATES, LLC.

201 BOSTON POST ROAD WEST, SUITE 101 MARLBOROUGH, MA 01752

SITE CONTROL POINT: LATITUDE: N.41.86671° N41°52'0.16" LONGITUDE W.-72.81577° W72°48'56.77"

# DO NOT SCALE DRAWINGS

CONTRACTOR SHALL VERIFY ALL PLANS AND EXISTING DIMENSIONS AND CONDITIONS ON THE JOB SITE AND SHALL IMMEDIATELY NOTIFY THE PROJECT OWNER'S REPRESENTATIVE IN WRITING OF DISCREPANCIES BEFORE PROCEEDING WITH THE WORK OR BE RESPONSIBLE FOR SAME.

SPECIAL ZONING NOTE

BASED ON INFORMATION PROVIDED BY T-MOBILE REGULATORY COMPLIANCE PROFESSIONALS AND LEGAL COUNSEL, THIS TELECOMMUNICATIONS EQUIPMENT DEPLOYMENT IS CONSIDERED AN ELIGIBLE FACILITY UNDER THE MIDDLE CLASS TAX RELIEF AND JOB CREATION ACT OF 2012, 47 USC 1455(A), SECTION 6409(A), AND IS SUBJECT TO AN **ELIGIBLE FACILITY REQUEST**, EXPEDITED REVIEW, AND LIMITED/PARTIAL ZONING PRE-EMPTION FOR LOCAL DISCRETIONARY PERMITS (VARIANCE, SPECIAL PERMIT, SITE PLAN REVIEW, OR ADMINISTRATIVE REVIEW).

# T-MOBILE NORTHEAST LLC


15 COMMERCE WAY, SUITE B NORTON, MA 02766 (508) 286-2700



SBA COMMUNICATIONS CORP. 134 FLANDERS ROAD, SUITE 125 WESTBOROUGH, MA 01581 (508) 251-0720



R.K. EXECUTIVE CENTRE 201 BOSTON POST ROAD WEST, SUITE 101 MARLBOROUGH, MA 01752 (508) 481-7400 www.chappellengineering.com



CHECKED BY:

APPROVED BY:

	SUBMITTALS				
REV.	DATE	DESCRIPTION	BY		
0	10/29/21	ISSUED FOR REVIEW	JRV		

# SITE NUMBER: CTHA531A

SITE ADDRESS: 225 GRIST MILL ROAD SIMSBURY, CT 06070

SHEET TITLE

TITLE SHEET

SHEET NUMBER

| - 1

# **GENERAL NOTES:**

ATTENTION OF CONTRACTOR.

1. FOR THE PURPOSE OF CONSTRUCTION DRAWINGS, THE FOLLOWING DEFINITIONS SHALL APPLY: CONTRACTOR — T-MOBILE SUBCONTRACTOR — GENERAL CONTRACTOR (CONSTRUCTION) OWNER — T-MOBILE

OEM - ORIGINAL EQUIPMENT MANUFACTURER

- 2. PRIOR TO THE SUBMISSION OF BIDS, THE BIDDING SUBCONTRACTOR SHALL VISIT THE CELL SITE TO FAMILIARIZE WITH THE EXISTING CONDITIONS AND TO CONFIRM THAT THE WORK CAN BE ACCOMPLISHED AS SHOWN ON THE CONSTRUCTION DRAWINGS. ANY DISCREPANCY FOUND SHALL BE BROUGHT TO THE
- 3. ALL MATERIALS FURNISHED AND INSTALLED SHALL BE IN STRICT ACCORDANCE WITH ALL APPLICABLE CODES, REGULATIONS, AND ORDINANCES. SUBCONTRACTOR SHALL ISSUE ALL APPROPRIATE NOTICES AND COMPLY WITH ALL LAWS, ORDINANCES, RULES, REGULATIONS, AND LAWFUL ORDERS OF ANY PUBLIC AUTHORITY REGARDING THE PERFORMANCE OF THE WORK.
- 4. ALL WORK CARRIED OUT SHALL COMPLY WITH ALL APPLICABLE MUNICIPAL AND UTILITY COMPANY SPECIFICATIONS AND LOCAL, STATE AND FEDERAL JURISDICTIONAL CODES, ORDINANCES AND APPLICABLE REGULATIONS.
- 5. DRAWINGS PROVIDED HERE ARE NOT TO BE SCALED AND ARE INTENDED TO SHOW OUTLINE ONLY.
- 6. UNLESS NOTED OTHERWISE, THE WORK SHALL INCLUDE FURNISHING MATERIALS, EQUIPMENT, APPURTENANCES, AND LABOR NECESSARY TO COMPLETE ALL INSTALLATIONS AS INDICATED ON THE DRAWINGS.
- 7. THE SUBCONTRACTOR SHALL INSTALL ALL EQUIPMENT AND MATERIALS IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS UNLESS SPECIFICALLY STATED OTHERWISE.
- 8. IF THE SPECIFIED EQUIPMENT CANNOT BE INSTALLED AS SHOWN ON THESE DRAWINGS, THE SUBCONTRACTOR SHALL PROPOSE AN ALTERNATIVE INSTALLATION FOR APPROVAL BY THE CONTRACTOR.
- 9. SUBCONTRACTOR SHALL DETERMINE ACTUAL ROUTING OF CONDUIT, POWER, T1 CABLES AND GROUNDING CABLES AS SHOWN ON THE POWER, GROUNDING AND TELCO PLAN DRAWING. SUBCONTRACTOR SHALL UTILIZE EXISTING TRAYS AND/OR SHALL ADD NEW TRAYS AS NECESSARY. SUBCONTRACTOR SHALL CONFIRM THE ACTUAL ROUTING WITH THE CONTRACTOR AND/OR LANDLORD PRIOR TO CONSTRUCTION.
- 10. THE SUBCONTRACTOR SHALL PROTECT EXISTING IMPROVEMENTS, PAVEMENTS, CURBS, LANDSCAPING AND STRUCTURES. ANY DAMAGED PART SHALL BE REPAIRED AT SUBCONTRACTOR'S EXPENSE TO THE SATISFACTION OF THE OWNER.
- 11. SUBCONTRACTOR SHALL LEGALLY AND PROPERLY DISPOSE OF ALL SCRAP MATERIALS SUCH AS COAXIAL CABLES AND OTHER ITEMS REMOVED FROM THE EXISTING FACILITY.
- 12. SUBCONTRACTOR SHALL LEAVE PREMISES IN CLEAN CONDITION AND RETURN DISTURBED AREAS TO ORIGINAL CONDITIONS.
- 13. THE SUBCONTRACTOR SHALL SUPERVISE AND DIRECT THE PROJECT DESCRIBED HEREIN. THE SUBCONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR ALL CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES, AND PROCEDURES FOR COORDINATING ALL PORTIONS OF THE WORK UNDER THE CONTRACT.
- 14. SUBCONTRACTOR SHALL NOTIFY CHAPPELL ENGINEERING ASSOCIATES, LLC 48 HOURS IN ADVANCE OF POURING CONCRETE OR BACKFILLING TRENCHES, SEALING ROOF AND WALL PENETRATIONS AND POST DOWNS, FINISHING NEW WALLS OR FINAL ELECTRICAL CONNECTIONS FOR ENGINEERING REVIEW.
- 15. CONSTRUCTION SHALL COMPLY WITH ALL T-MOBILE STANDARDS AND SPECIFICATIONS.
- 16. SUBCONTRACTOR SHALL VERIFY ALL EXISTING DIMENSIONS AND CONDITIONS PRIOR TO COMMENCING ANY WORK. ALL DIMENSIONS OF EXISTING CONSTRUCTION SHOWN ON THE DRAWINGS MUST BE VERIFIED. SUBCONTRACTOR SHALL NOTIFY THE CONTRACTOR OF ANY DISCREPANCIES PRIOR TO ORDERING MATERIAL OR PROCEEDING WITH CONSTRUCTION.
- 17. THE EXISTING CELL SITES ARE IN FULL COMMERCIAL OPERATION. ANY CONSTRUCTION WORK BY SUBCONTRACTOR SHALL NOT DISRUPT THE EXISTING NORMAL OPERATION. ANY WORK ON EXISTING EQUIPMENT MUST BE COORDINATED WITH CONTRACTOR. ALSO, WORK SHOULD BE SCHEDULED FOR AN APPROPRIATE MAINTENANCE WINDOW USUALLY IN LOW TRAFFIC PERIODS AFTER MIDNIGHT.
- 18. IF THE EXISTING CELL SITE IS ACTIVE, ALL SAFETY PRECAUTIONS MUST BE TAKEN WHEN WORKING AROUND HIGH LEVELS OF ELECTROMAGNETIC RADIATION. EQUIPMENT SHOULD BE SHUTDOWN PRIOR TO PERFORMING ANY WORK THAT COULD EXPOSE THE WORKERS TO DANGER. PERSONAL RF EXPOSURE MONITORS ARE TO BE WORN TO ALERT OF ANY DANGEROUS EXPOSURE LEVELS.

# SITE WORK GENERAL NOTES:

- 1. THE SUBCONTRACTOR SHALL CONTACT UTILITY LOCATING SERVICES PRIOR TO THE START OF CONSTRUCTION.
- 2. ALL EXISTING ACTIVE SEWER, WATER, GAS, ELECTRIC, AND OTHER UTILITIES WHERE ENCOUNTERED IN THE WORK, SHALL BE PROTECTED AT ALL TIMES, AND WHERE REQUIRED FOR THE PROPER EXECUTION OF THE WORK, SHALL BE RELOCATED AS DIRECTED BY ENGINEERS. EXTREME CAUTION SHOULD BE USED BY THE SUBCONTRACTOR WHEN EXCAVATING OR DRILLING PIERS AROUND OR NEAR UTILITIES. SUBCONTRACTOR SHALL PROVIDE SAFETY TRAINING FOR THE WORKING CREW. THIS WILL INCLUDE BUT NOT BE LIMITED TO A) FALL PROTECTION B) CONFINED SPACE C) ELECTRICAL SAFETY D) TRENCHING AND EXCAVATION.
- 3. ALL SITE WORK SHALL BE AS INDICATED ON THE DRAWINGS AND PROJECT SPECIFICATIONS.
- 4. IF NECESSARY, RUBBISH, STUMPS, DEBRIS, STICKS, STONES AND OTHER REFUSE SHALL BE REMOVED FROM THE SITE AND DISPOSED OF LEGALLY.
- 5. THE SITE SHALL BE GRADED TO CAUSE SURFACE WATER TO FLOW AWAY FROM THE BTS EQUIPMENT AND TOWER AREAS.
- 6. NO FILL OR EMBANKMENT MATERIAL SHALL BE PLACED ON FROZEN GROUND. FROZEN MATERIALS, SNOW OR ICE SHALL NOT BE PLACED IN ANY FILL OR EMBANKMENT.
- 7. THE SUB GRADE SHALL BE COMPACTED AND BROUGHT TO A SMOOTH UNIFORM GRADE PRIOR TO FINISHED SURFACE APPLICATION.
- 8. ALL EXISTING INACTIVE SEWER, WATER, GAS, ELECTRIC AND OTHER UTILITIES, WHICH INTERFERE WITH THE EXECUTION OF THE WORK, SHALL BE REMOVED AND/OR CAPPED, PLUGGED OR OTHERWISE DISCONTINUED AT POINTS WHICH WILL NOT INTERFERE WITH THE EXECUTION OF THE WORK, SUBJECT TO THE APPROVAL OF ENGINEERING, OWNER AND/OR LOCAL UTILITIES.
- 9. THE AREAS OF THE OWNERS PROPERTY DISTURBED BY THE WORK AND NOT COVERED BY THE TOWER, EQUIPMENT OR DRIVEWAY, SHALL BE GRADED TO A UNIFORM SLOPE AND STABILIZED TO PREVENT EROSION AS SPECIFIED IN THE PROJECT SPECIFICATIONS.
- 10. SUBCONTRACTOR SHALL MINIMIZE DISTURBANCE TO EXISTING SITE DURING CONSTRUCTION. EROSION CONTROL MEASURES, IF REQUIRED DURING CONSTRUCTION, SHALL BE IN CONFORMANCE WITH THE LOCAL GUIDELINES FOR EROSION AND SEDIMENT CONTROL.
- 11. THE SUBCONTRACTOR SHALL PROVIDE SITE SIGNAGE IN ACCORDANCE WITH THE T-MOBILE SPECIFICATION FOR SITE SIGNAGE.

# **CONCRETE AND REINFORCING STEEL NOTES:**

- 1. ALL CONCRETE WORK SHALL BE IN ACCORDANCE WITH THE ACI 301, ACI 318, ACI 336, ASTM A184, ASTM A185 AND THE DESIGN AND CONSTRUCTION SPECIFICATION FOR CAST—IN—PLACE CONCRETE.
- 2. ALL CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3000 PSI AT 28 DAYS, UNLESS NOTED OTHERWISE. A HIGHER STRENGTH (400PSI) MAY BE USED. ALL CONCRETE WORK SHALL BE IN ACCORDANCE WITH THE ACI 381 CODE REQUIREMENTS
- 3. REINFORCING STEEL SHALL CONFORM TO ASTM A 615, GRADE 60, DEFORMED UNLESS NOTED OTHERWISE. WELDED WIRE FABRIC SHALL CONFORM TO ASTM A 185 WELDED STEEL WIRE FABRIC UNLESS NOTED OTHERWISE. SPLICES SHALL BE CLASS "B" AND ALL HOOKS SHALL BE STANDARD, UNO.
- 4. THE FOLLOWING MINIMUM CONCRETE COVER SHALL BE PROVIDED FOR REINFORCING STEEL UNLESS SHOWN OTHERWISE ON DRAWINGS:
- 5. A CHAMFER 34" SHALL BE PROVIDED AT ALL EXPOSED EDGES OF CONCRETE, UNO, IN ACCORDANCE WITH ACI 301 SECTION
- 6. INSTALLATION OF CONCRETE EXPANSION/WEDGE ANCHORS SHALL BE PER MANUFACTURER'S WRITTEN RECOMMENDED PROCEDURE. THE ANCHOR BOLT, DOWEL OR ROD SHALL CONFORM TO THE MANUFACTURERS RECOMMENDATION FOR EMBEDMENT DEPTH OR AS SHOWN ON THE DRAWINGS. NO REBAR SHALL BE CUT WITHOUT PRIOR CONTRACTOR APPROVAL WHEN DRILLING HOLES IN CONCRETE. SPECIAL INSPECTIONS, REQUIRED BY GOVERNING CODES, SHALL BE PERFORMED IN ORDER TO MAINTAIN MANUFACTURER'S MAXIMUM ALLOWABLE LOADS. ALL EXPANSION/WEDGE ANCHORS SHALL BE STAINLESS STEEL OR HOT DIPPED GALVANIZED. EXPANSION BOLTS SHALL BE PROVIDED BY SIMPSON OR APPROVED EQUAL.
- 7. CONCRETE CYLINDER TIES ARE NOT REQUIRED FOR SLAB ON GRADE WHEN CONCRETE IS LESS THAN 50 CUBIC YARDS (IBC1905.6.2.3) IN THAT EVENT THE FOLLOWING RECORDS SHALL BE PROVIDED BY THE CONCRETE SUPPLIER;
- (A) RESULTS OF CONCRETE CYLINDER TEST PERFORMED AT THE SUPPLIERS PLANT.
- (B) CERTIFICATION OF MINIMUM COMPRESSIVE STRENGTH FOR THE CONCRETE GRADE SUPPLIED. FOR GREATER THAN 50 CUBIC YARDS THE GC SHALL PERFORM THE CONCRETE CYLINDER TEST.
- 8. AS AN ALTERNATIVE TO ITEM 7. TEST CYLINDERS SHALL BE TAKEN INITIALLY AND THEREAFTER FOR EVERY 50 YARDS OF CONCRETE FROM EACH DIFFERENT BATCH PLANT.
- 9. EQUIPMENT SHALL NOT BE PLACED ON NEW PADS FOR SEVEN DAYS AFTER PAD IS POURED, UNLESS IT IS VERIFIED BY CYLINDER TESTS THAT COMPRESSIVE STRENGTH HAS BEEN ATTAINED.

# STRUCTURAL STEEL NOTES:

- 1. ALL STEEL WORK SHALL BE PAINTED OR GALVANIZED IN ACCORDANCE WITH THE DRAWINGS AND T-MOBILE SPECIFICATIONS UNLESS OTHERWISE NOTED. STRUCTURAL STEEL SHALL BE ASTM-A-36 UNLESS OTHERWISE NOTED ON THE SITE SPECIFIC DRAWINGS. STEEL DESIGN, INSTALLATION AND BOLTING SHALL BE IN ACCORDANCE WITH THE AMERICAN INSTITUTE OF STEEL CONSTRUCTION (AISC) "MANUAL OF STEEL CONSTRUCTION".
- 2. ALL WELDING SHALL BE PERFORMED USING E70XX ELECTRODES AND WELDING SHALL CONFORM TO AISC AND AWS D1.1. WHERE FILLET WELD SIZES ARE NOT SHOWN, PROVIDE THE MINIMUM SIZE PER TABLE J2.4 IN THE AISC "MANUAL OF STEEL CONSTRUCTION", 9TH EDITION. PAINTED SURFACES SHALL BE TOUCHED UP.
- 3. BOLTED CONNECTIONS SHALL USE BEARING TYPE ASTM A325 BOLTS  $(\frac{3}{4})$  AND SHALL HAVE MINIMUM OF TWO BOLTS UNLESS NOTED OTHERWISE. ALL BOLTS SHALL BE GALVANIZED OR STAINLESS STEEL.
- 4. NON-STRUCTURAL CONNECTIONS FOR STEEL GRATING MAY USE %" DIA. ASTM A 307 BOLTS (GALV) UNLESS NOTED OTHERWISE.
- 5. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS FOR ENGINEER REVIEW & APPROVAL ON PROJECTS REQUIRING STRUCTURAL STEFL
- 6. ALL STRUCTURAL STEEL WORK SHALL BE DONE IN ACCORDANCE WITH AISC SPECIFICATIONS.

# SOIL COMPACTION NOTES FOR SLAB ON GRADE:

- 1. EXCAVATE AS REQUIRED TO REMOVE VEGETATION AND TOPSOIL TO EXPOSE NATURAL SUBGRADE AND PLACE CRUSHED STONE AS REQUIRED.
- 2. COMPACTION CERTIFICATION: AN INSPECTION AND WRITTEN CERTIFICATION BY A QUALIFIED GEOTECHNICAL TECHNICIAN OR ENGINEER IS ACCEPTABLE.
- 3. AS AN ALTERNATE TO INSPECTION AND WRITTEN CERTIFICATION, THE "UNDISTURBED SOIL" BASE SHALL BE COMPACTED WITH "COMPACTION EQUIPMENT", LISTED BELOW, TO AT LEAST 90% MODIFIED PROCTOR MAXIMUM DENSITY PER ASTM D 1557 METHOD C.
- 4. COMPACTED SUBBASE SHALL BE UNIFORM AND LEVELED. PROVIDE 6" MINIMUM CRUSHED STONE OR GRAVEL COMPACTED IN 3" LIFTS ABOVE COMPACTED SOIL. GRAVEL SHALL BE NATURAL OR CRUSHED WITH 100% PASSING #1 SIEVE.
- 5. AS AN ALTERNATE TO ITEMS 2 AND 3, THE SUBGRADE SOILS WITH 5 PASSES OR A MEDIUM SIZED VIBRATORY PLATE COMPACTOR (SUCH AS BOMAG BPR 30/38) OR HAND-OPERATED SINGLE DRUM VIBRATORY ROLLER (SUCH AS BOMAG BW 55E). AND SOFT AREAS THAT ARE ENCOUNTERED SHOULD BE REMOVED AND REPLACED WITH A WELL-GRADED GRANULAR FILL AND COMPACTED AS STATED ABOVE.

# **COMPACTION EQUIPMENT:**

1. HAND OPERATED DOUBLE DRUN, VIBRATORY ROLLER, VIBRATORY PLATE COMPACTOR OR JUMPING JACK COMPACTOR.

# CONSTRUCTION NOTES:

1. FIELD VERIFICATION:

- SUBCONTRACTOR SHALL FIELD VERIFY SCOPE OF WORK, T-MOBILE ANTENNA PLATFORM LOCATION AND UTILITY TRENCHWORK.
- 2. COORDINATION OF WORK: SUBCONTRACTOR SHALL COORDINATE RF WORK AND PROCEDURES WITH CONTRACTOR.
- 3. CABLE LADDER RACK:
- SUBCONTRACTOR SHALL FURNISH AND INSTALL CABLE LADDER RACK, CABLE TRAY AND/OR ICE BRIDGE, AND CONDUIT AS REQUIRED TO SUPPORT CABLES TO THE NEW BTS LOCATION.

# **ELECTRICAL INSTALLATION NOTES:**

- 1. WIRING, RACEWAY, AND SUPPORT METHODS AND MATERIALS SHALL COMPLY WITH THE REQUIREMENTS OF THE NEC AND TELCORDIA.
- 2. SUBCONTRACTOR SHALL MODIFY OR INSTALL CABLE TRAY SYSTEM AS REQUIRED TO SUPPORT RF AND TRANSPORT CABLING TO THE NEW BTS EQUIPMENT. SUBCONTRACTOR SHALL SUBMIT MODIFICATIONS TO CONTRACTOR FOR APPROVAL.
- 3. ALL CIRCUITS SHALL BE SEGREGATED AND MAINTAIN MINIMUM CABLE SEPARATION AS REQUIRED BY THE NEC AND
- 4. CABLES SHALL NOT BE ROUTED THROUGH LADDER-STYLE CABLE TRAY RUNGS.
- 5. EACH END OF EVERY POWER, GROUNDING, AND T1 CONDUCTOR AND CABLE SHALL BE LABELED WITH COLOR—CODED INSULATION OR ELECTRICAL TAPE (3M BRAND, 1/2 INCH PLASTIC ELECTRICAL TAPE WITH UV PROTECTION, OR EQUAL). THE IDENTIFICATION METHOD SHALL CONFORM WITH NEC AND OSHA, AND MATCH INSTALLATION REQUIREMENTS.
- 6. POWER PHASE CONDUCTORS (I.E., HOTS) SHALL BE LABELED WITH COLOR—CODED INSULATION OR ELECTRICAL TAPE (3M BRAND, ½ INCH PLASTIC ELECTRICAL TAPE WITH UV PROTECTION, OR EQUAL). PHASE CONDUCTOR COLOR CODES SHALL CONFORM WITH THE NEC AND OSHA.
- 7. ALL ELECTRICAL COMPONENTS SHALL BE CLEARLY LABELED WITH ENGRAVED LAMACOID PLASTIC LABELS. ALL EQUIPMENT SHALL BE LABELED WITH THEIR VOLTAGE RATING, PHASE CONFIGURATION, WIRE CONFIGURATION, POWER OR AMPACITY RATING, AND BRANCH CIRCUIT ID NUMBERS (I.E., PANELBOARD AND CIRCUIT ID'S).
- 8. PANELBOARDS (ID NUMBERS) AND INTERNAL CIRCUIT BREAKERS (CIRCUIT ID NUMBERS) SHALL BE CLEARLY LABELED WITH ENGRAVED LAMACOID PLASTIC LABELS.
- 9. ALL TIE WRAPS SHALL BE CUT FLUSH WITH APPROVED CUTTING TOOL TO REMOVE SHARP EDGES.
- 10. POWER, CONTROL, AND EQUIPMENT GROUND WIRING IN TUBING OR CONDUIT SHALL BE SINGLE CONDUCTOR (#34 AWG OR LARGER), 600 V, OIL RESISTANT THHN OR THWN-2, CLASS B STRANDED COPPER CABLE RATED FOR 90 °C (WET AND DRY) OPERATION; LISTED OR LABELED FOR THE LOCATION AND RACEWAY SYSTEM USED, UNLESS OTHERWISE SPECIFIED.
- 11. SUPPLEMENTAL EQUIPMENT GROUND WIRING LOCATED INDOORS SHALL BE SINGLE CONDUCTOR (#6 AWG OR LARGER), 600 V, OIL RESISTANT THHN OR THWN-2 GREEN INSULATION, CLASS B STRANDED COPPER CABLE RATED FOR 90 °C (WET AND DRY) OPERATION; LISTED OR LABELED FOR THE LOCATION AND RACEWAY SYSTEM USED, UNLESS OTHERWISE SPECIFIED.
- 12. SUPPLEMENTAL EQUIPMENT GROUND WIRING LOCATED OUTDOORS, OR BELOW GRADE, SHALL BE SINGLE CONDUCTOR #2 AWG SOLID TINNED COPPER CABLE, UNLESS OTHERWISE SPECIFIED.
- 13. POWER AND CONTROL WIRING, NOT IN TUBING OR CONDUIT, SHALL BE MULTI-CONDUCTOR, TYPE TC CABLE (#34 AWG OR LARGER), 600 V, OIL RESISTANT THHN OR THWN-2, CLASS B STRANDED COPPER CABLE RATED FOR 90 °C (WET AND DRY) OPERATION; WITH OUTER JACKET; LISTED OR LABELED FOR THE LOCATION USED, UNLESS OTHERWISE SPECIFIED.
- 14. ALL POWER AND GROUNDING CONNECTIONS SHALL BE CRIMP—STYLE, COMPRESSION WIRE LUGS AND WIRENUTS BY HARGER (OR EQUAL). LUGS AND WIRENUTS SHALL BE RATED FOR OPERATION AT NO LESS THAN 75°C (90°C IF AVAILABLE).
- 15. RACEWAY AND CABLE TRAY SHALL BE LISTED OR LABELED FOR ELECTRICAL USE IN ACCORDANCE WITH NEMA, UL, ANSI/IEEE AND NEC.
- 16. NEW RACEWAY OR CABLE TRAY WILL MATCH THE EXISTING INSTALLATION WHERE POSSIBLE.
- 17. ELECTRICAL METALLIC TUBING (EMT) OR RIGID NONMETALLIC CONDUIT (I.E., RIGID PVC SCHEDULE 40 OR RIGID PVC SCHEDULE 80 FOR LOCATIONS SUBJECT TO PHYSICAL DAMAGE) SHALL BE USED FOR EXPOSED INDOOR LOCATIONS.
- 18. ELECTRICAL METALLIC TUBING (EMT), ELECTRICAL NONMETALLIC TUBING (ENT), OR RIGID NONMETALLIC CONDUIT (RIGID PVC, SCHEDULE 40) SHALL BE USED FOR CONCEALED INDOOR LOCATIONS.
- 19. GALVANIZED STEEL INTERMEDIATE METALLIC CONDUIT (IMC) SHALL BE USED FOR OUTDOOR LOCATIONS ABOVE
- 20. RIGID NONMETALLIC CONDUIT (I.E., RIGID PVC SCHEDULE 40 OR RIGID PVC SCHEDULE 80) SHALL BE USED UNDERGROUND; DIRECT BURIED, IN AREAS OF OCCASIONAL LIGHT VEHICLE TRAFFIC OR ENCASED IN REINFORCED CONCRETE IN AREAS OF HEAVY VEHICLE TRAFFIC.
- 21. LIQUID-TIGHT FLEXIBLE METALLIC CONDUIT (LIQUID-TITE FLEX) SHALL BE USED INDOORS AND OUTDOORS, WHERE VIBRATION OCCURS OR FLEXIBILITY IS NEEDED.
- 22. CONDUIT AND TUBING FITTINGS SHALL BE THREADED OR COMPRESSION—TYPE AND APPROVED FOR THE LOCATION
- 23. CABINETS, BOXES AND WIREWAYS SHALL BE LISTED OR LABELED FOR ELECTRICAL USE IN ACCORDANCE WITH NEMA,
- 24. CABINETS, BOXES AND WIREWAYS TO MATCH THE EXISTING INSTALLATION WHERE POSSIBLE.

USED. SETSCREW FITTINGS ARE NOT ACCEPTABLE.

UL. ANSI/IEEE AND NEC.

- 25. WIREWAYS SHALL BE EPOXY—COATED (GRAY) AND INCLUDE A HINGED COVER, DESIGNED TO SWING OPEN DOWNWARD; SHALL BE PANDUIT TYPE E (OR EQUAL); AND RATED NEMA 1 (OR BETTER) INDOORS, OR NEMA 3R (OR BETTER) OUTDOORS.
- 26. EQUIPMENT CABINETS, TERMINAL BOXES, JUNCTION BOXES, AND PULL BOXES SHALL BE GALVANIZED OR EPOXY—COATED SHEET STEEL, SHALL MEET OR EXCEED UL 50, AND RATED NEMA 1 (OR BETTER) INDOORS, OR NEMA 3R (OR BETTER) OUTDOORS.
- 27. METAL RECEPTACLE, SWITCH, AND DEVICE BOXES SHALL BE GALVANIZED, EPOXY—COATED, OR NON—CORRODING; SHALL MEET OR EXCEED UL 514A AND NEMA OS 1; AND RATED NEMA 1 (OR BETTER) INDOORS, OR WEATHER PROTECTED (WP OR BETTER) OUTDOORS.
- 28. NONMETALLIC RECEPTACLE, SWITCH, AND DEVICE BOXES SHALL MEET OR EXCEED NEMA OS 2; AND RATED NEMA 1 (OR BETTER) INDOORS, OR WEATHER PROTECTED (WP OR BETTER) OUTDOORS.
- 29. THE SUBCONTRACTOR SHALL NOTIFY AND OBTAIN NECESSARY AUTHORIZATION FROM THE CONTRACTOR BEFORE COMMENCING WORK ON THE AC POWER DISTRIBUTION PANELS.
- 30. THE SUBCONTRACTOR SHALL PROVIDE NECESSARY TAGGING ON THE BREAKERS, CABLES AND DISTRIBUTION PANELS IN ACCORDANCE WITH THE APPLICABLE CODES AND STANDARDS TO SAFEGUARD AGAINST LIFE AND PROPERTY.
- 31. ALL ELECTRICAL WORK SHALL BE PERFORMED IN ACCORDANCE WITH THE PROJECT SPECIFICATIONS, NEC AND ALL APPLICABLE LOCAL CODES.
- 32. CONDUIT ROUTINGS ARE SCHEMATIC. SUBCONTRACTOR SHALL INSTALL CONDUITS SO THAT ACCESS TO EQUIPMENT IS NOT BLOCKED.

# T-MOBILE NORTHEAST LLC


15 COMMERCE WAY, SUITE B NORTON, MA 02766 (508) 286-2700



SBA COMMUNICATIONS CORP.
134 FLANDERS ROAD, SUITE 125
WESTBOROUGH, MA 01581
(508) 251-0720



R.K. EXECUTIVE CENTRE
201 BOSTON POST ROAD WEST, SUITE 101
MARLBOROUGH, MA 01752
(508) 481-7400
www.chappellengineering.com



CHECKED BY: JMT

APPROVED BY: JM

SUBMITTALS

REV. DATE DESCRIPTION BY

0 10/29/21 ISSUED FOR REVIEW JRV

# SITE NUMBER: CTHA531A

SITE ADDRESS: 225 GRIST MILL ROAD SIMSBURY, CT 06070


SHEET TITLE


SHEET NUMBER

**GENERAL NOTES** 


GN-1

1815





NOTE:
GENERATOR DIESEL TANK TO
BE FILLED BY CONTRACTOR



GENERAC RD025 25kW AC DIESEL GENERATOR


DIMENSIONS: 103.4"L x 35.0"W x 91.7"H

WEIGHT: 2,946 lbs

QUANTITY: TOTAL OF 1

GENERATOR DETAIL

SCALE: N.T.S.




PROP. ½"Ø HILTI KWIK BOLT TZ STAINLESS
STEEL ANCHOR BOLT WITH 2" MIN.
EMBEDMENT IN CONCRETE 1CC-ESR-1917,
LARR 25701, EACH CORNER PER
MANUFACTURER'S SPECIFICATIONS (TYP.)
(SPECIAL INSPECTION REQUIRED)


NOTE:
CONTRACTOR TO VERIFY 3"
MIN. FROM EDGE OF CONCRETE
TO NEW MOUNTING BOLT.

GENERATOR MOUNTING DETAIL

SCALE: N.T.S.

3
A-2





A-2

# T-MOBILE NORTHEAST LLC


15 COMMERCE WAY, SUITE B NORTON, MA 02766 (508) 286-2700



SBA COMMUNICATIONS CORP. 134 FLANDERS ROAD, SUITE 125 WESTBOROUGH, MA 01581 (508) 251-0720



R.K. EXECUTIVE CENTRE
201 BOSTON POST ROAD WEST, SUITE 101
MARLBOROUGH, MA 01752
(508) 481-7400
www.chappellengineering.com



CHECKED BY: JMT

APPROVED BY: JM

	SUBMITTALS				
REV.	DATE	DESCRIPTION	BY		
0	10/29/21	ISSUED FOR REVIEW	JRV		

# SITE NUMBER: CTHA531A

SITE ADDRESS: 225 GRIST MILL ROAD SIMSBURY, CT 06070


SHEET TITLE


GENERATOR DETAILS


SHEET NUMBER

A-2

1815.3









# NOTE: CUT BACK (E) MAIN POWER CONDUIT, AS REQUIRED, & RECOONECT TO (P) ATS.

E-1




ONE-LINE POWER DIAGRAM

SCALE: NOT TO SCALE



SCALE: NOT TO SCALE

E-1



TYPICAL CONDUIT STUB-UP DETAIL

SCALE: NONE

TYPICAL CONDUIT STUB-UP DETAIL

E-1

# ELECTRICAL AND GROUNDING NOTES

- 1. ALL ELECTRICAL WORK SHALL CONFORM TO THE REQUIREMENTS OF THE NATIONAL ELECTRICAL CODE (NEC) AS WELL AS APPLICABLE STATE AND LOCAL CODES.
- 2. ALL ELECTRICAL ITEMS SHALL BE U.L. APPROVED OR LISTED AND PROCURED PER SPECIFICATION REQUIREMENTS.
- 3. THE ELECTRICAL WORK INCLUDES ALL LABOR AND MATERIAL DESCRIBED BY DRAWINGS AND SPECIFICATION INCLUDING INCIDENTAL WORK TO PROVIDE COMPLETE OPERATING AND APPROVED ELECTRICAL SYSTEM.
- 4. GENERAL CONTRACTOR SHALL PAY FEES FOR PERMITS, AND IS RESPONSIBLE FOR OBTAINING SAID PERMITS AND COORDINATION OF INSPECTIONS.
- 5. ELECTRICAL AND TELCO WIRING OUTSIDE A BUILDING AND EXPOSED TO WEATHER SHALL BE IN WATER TIGHT GALVANIZED RIGID STEEL CONDUITS OR SCHEDULE 80 PVC (AS PERMITTED BY CODE) AND WHERE REQUIRED IN LIQUID TIGHT FLEXIBLE METAL OR NONMETALLIC CONDUITS.
- 6. BURIED CONDUIT SHALL BE SCHEDULE 40 PVC.
- 7. ELECTRICAL WIRING SHALL BE COPPER WITH TYPE XHHW, THWN, OR THININSULATION.
- 8. RUN ELECTRICAL CONDUIT OR CABLE BETWEEN ELECTRICAL UTILITY DEMARCATION POINT AND PROJECT OWNER CELL SITE PPC AS INDICATED ON THIS DRAWING. PROVIDE FULL LENGTH PULL ROPE. COORDINATE INSTALLATION WITH UTILITY COMPANY.
- 9. RUN TELCO CONDUIT OR CABLE BETWEEN TELEPHONE UTILITY DEMARCATION POINT AND PROJECT OWNER CELL SITE TELCO CABINET AND BTS CABINET AS INDICATED ON THIS DRAWING PROVIDE FULL LENGTH PULL ROPE IN INSTALLED TELCO CONDUIT. PROVIDE GREENLEE CONDUIT MEASURING TAPE AT EACH END.
- 10. WHERE CONDUIT BETWEEN BTS AND PROJECT OWNER CELL SITE PPC AND BETWEEN BTS AND PROJECT OWNER CELL SITE TELCO SERVICE CABINET ARE UNDERGROUND USE PVC, SCHEDULE 40 CONDUIT. ABOVE THE GROUND PORTION OF THESE CONDUITS SHALL BE PVC CONDUIT.
- 11. ALL EQUIPMENT LOCATED OUTSIDE SHALL HAVE NEMA 3R ENCLOSURE.
- 12. PPC SUPPLIED BY PROJECT OWNER.
- 13. GROUNDING SHALL COMPLY WITH NEC ART. 250. ADDITIONALLY, GROUNDING, BONDING AND LIGHTNING PROTECTION SHALL BE DONE IN ACCORDANCE WITH "T-MOBILE BTS SITE GROUNDING STANDARDS".
- 14. GROUND COAXIAL CABLE SHIELDS MINIMUM AT BOTH ENDS USING MANUFACTURERS COAX CABLE GROUNDING KITS SUPPLIED BY PROJECT
- 15. USE #6 COPPER STRANDED WIRE WITH GREEN COLOR INSULATION FOR ABOVE GRADE GROUNDING (UNLESS OTHERWISE SPECIFIED) AND #2 SOLID TINNED BARE COPPER WIRE FOR BELOW GRADE GROUNDING AS INDICATED ON THE DRAWING.
- 16. ALL GROUND CONNECTIONS TO BE BURNDY HYGROUND COMPRESSION TYPE CONNECTORS OR CADWELD EXOTHERMIC WELD. DO NOT ALLOW BARE COPPER WIRE TO BE IN CONTACT WITH GALVANIZED STEEL.
- 17. ROUTE GROUNDING CONDUCTORS ALONG THE SHORTEST AND STRAIGHTEST PATH POSSIBLE, EXCEPT AS OTHERWISE INDICATED. GROUNDING LEADS SHOULD NEVER BE BENT AT RIGHT ANGLE. ALWAYS MAKE AT LEAST 12" RADIUS BENDS. #6 WIRE CAN BE BENT AT 6" RADIUS WHEN NECESSARY. BOND ANY METAL OBJECTS WITHIN 6 FEET OF PROJECT OWNER EQUIPMENT OR CABINET TO MASTER GROUND BAR OR GROUNDING
- 18. CONNECTIONS TO GROUND BARS SHALL BE MADE WITH TWO HOLE COMPRESSION TYPE COPPER LUGS. APPLY OXIDE INHIBITING COMPOUND TO ALL LOCATIONS.
- 19. APPLY OXIDE INHIBITING COMPOUND TO ALL COMPRESSION TYPE GROUND CONNECTIONS.
- 20. CONTRACTOR SHALL PROVIDE AND INSTALL OMNI DIRECTIONAL ELECTRONIC MARKER SYSTEM (EMS) BALLS OVER EACH GROUND ROD AND BONDING POINT BETWEEN EXIST. TOWER/ MONOPOLE GROUNDING RING AND EQUIPMENT GROUNDING RING.
- 21. CONTRACTOR SHALL TEST COMPLETED GROUND SYSTEM AND RECORD RESULTS FOR PROJECT CLOSE—OUT DOCUMENTATION. 5 OHMNS MINIMUM
- 22. CONTRACTOR SHALL CONDUCT ANTENNA, COAX, AND LNA RETURN-LOSS AND DISTANCE- TO-FAULT MEASUREMENTS (SWEEP TESTS) AND RECORD RESULTS FOR PROJECT CLOSE OUT.

T-MOBILE NORTHEAST LLC


15 COMMERCE WAY, SUITE B NORTON, MA 02766 (508) 286-2700



SBA COMMUNICATIONS CORP. 134 FLANDERS ROAD, SUITE 125 WESTBOROUGH, MA 01581 (508) 251-0720



R.K. EXECUTIVE CENTRE
201 BOSTON POST ROAD WEST, SUITE 101
MARLBOROUGH, MA 01752
(508) 481-7400
www.chappellengineering.com



CHECKED BY: JN

APPROVED BY: JMT

			• • • • •
	S	UBMITTALS	
REV.	DATE	DESCRIPTION	1
			_
			_
			+
			+
0	10/20/21	ISSUED FOR REVIEW	+.

SITE NUMBER: CTHA531A

SITE ADDRESS: 225 GRIST MILL ROAD SIMSBURY, CT 06070


SHEET TITLE

ELECTRIC & GROUNDING DETAILS

SHEET NUMBER

E-


1815.326



GROUND BAR (EGB)

SCALE: NOT TO SCALE

4
E-1



NOTES:
 "DOUBLING UP" OR "STACKING" OF CONNECTION IS NOT PERMITTED.
 OXIDE INHIBITING COMPOUND TO BE USED AT ALL LOCATIONS.
 CADWELL DOWNLEADS FROM UPPER EGB, LOWER EGB AND MGB.

TYPICAL GROUND BAR CONNECTIONS DETAIL 5
SCALE: NOT TO SCALE E-1

# EXHIBIT 7

Generac RD025 25 KW 25kw Diesel Specifications

**Standby Power Rating** 25 kW, 31.25 kVA, 60 Hz







Image used for illustration purposes only

# **Codes and Standards**

Not all codes and standards apply to all configurations. Contact factory for details.



UL2200, UL508, UL489, UL142



CSA 22.2





BS5514 and DIN 6271



**SAE J1349** 



NFPA 37, 70, 99



ISO 3046, 8528, 9001



NEMA ICS1, ICS10, MG1, 250, ICS6, AB1



an National Standards Institute ANSI/IEEE C62.41

# **Powering Ahead**

For over 50 years, Generac has led the industry with innovative design and superior manufacturing.

Generac ensures superior quality by designing and manufacturing most of its generator components, including alternators, enclosures and base tanks, control systems and communications software.

Generac's gensets utilize a wide variety of options, configurations and arrangements, allowing us to meet the standby power needs of practically every application.

Generac searched globally to ensure the most reliable engines power our generators. We choose only engines that have already been proven in heavy-duty industrial application under adverse conditions.

Generac is committed to ensuring our customers' service support continues after their generator purchase.

# RD025 | 2.2L | 25 kW

# INDUSTRIAL DIESEL GENERATOR SET

**EPA Certified Stationary Emergency** 

# **Standard Features**

# **ENGINE SYSTEM**

- Cold Weather Kit
- Oil Drain Extension
- Heavy Duty Air Cleaner
- Fan Guard
- Stainless Steel Flexible Exhaust Connection
- · Factory Filled Oil & Coolant
- Critical Exhaust Silencer

#### **GENERATOR SET**

- Sound Attenuated Aluminum Enclosure
- Internal Genset Vibration Isolation
- · Separation of Circuits High/Low Voltage
- Wrapped Exhaust Piping
- Standard Factory Testing
- 5 Year Limited Warranty
- Ready to Accept Full Load in <10 Seconds
- E-Stop

# **Electrical System**

- Battery Charging Alternator
- Battery Cables
- Battery Tray
- Rubber-Booted Engine Electrical Connections
- Solenoid Activated Starter Motor
- Smart Battery Charger

# **ALTERNATOR SYSTEM**

- Class H Insulation Material
- 2/3 Pitch
- Skewed Stator
- Sealed Bearings
- Low Temperature Rise (>120°C)
- Low THD (<5%)

# **Cooling System**

**GENERAC**<sup>®</sup>

**INDUSTRIAL** 

- Closed Coolant Recovery System
- · Factory-Installed Radiator
- 50/50 Ethylene Glycol Antifreeze
- Radiator Drain Extension
- Can Operate at up to 122°F (50°C) Ambient Temperature

# **Fuel System**

- · Fuel Lockoff Solenoid
- · Primary Fuel Filter
- Stainless Steel Fuel Lines

# **TANKS**

- 24 Hour Run Time Tank
- UL142 Listed Tank

# **CONTROL SYSTEM**



# **Evolution ™ Controller**

- Two-Line Plain Text LCD Display
- Programmable Start Delay Between 10-30 seconds
- 10 second Engine Start Sequence
- 5 second Engine Warm Up
- 1 minute Engine Cool-Down
- Starter Lock-Out
- Smart Battery Charger
- Automatic Voltage Regulation with Over and Under Protection
- Automatic Low Oil Pressure Shutdown
- Overspeed Shutdown
- High Temperature Shutdown

- Overcrank Protection
- · Safety Fused
- · Failure to Transfer Protection
- Low Battery Protection
- 50 Even Run Log
- Future Set Capable Exerciser
- Incorrect Wiring Protection
- Internal Fault Protection
- · Common External Fault Capability
- · Governor Failure Protection

# Optional Shipped Loose and Field Install Kits

## **ENGINE SYSTEM**

Base Plug Kit

# **GENERATOR SET**

- O Paint Kit
- O Scheduled Maintance Kit

# **CONTROL SYSTEM**

○ Mobile Link <sup>TM</sup> and Adapter Kit

# TANKS

- O Spill Box
- O 90% Fuel Alarm
- Tank Risers
- O Spill Box Drainback Kit
- O Vent Extension Support Kit
- O 5 Day Run Time Tank

# RD025 | 2.2L | 25 kW

# INDUSTRIAL DIESEL GENERATOR SET

**EPA Certified Stationary Emergency** 



# **APPLICATION AND ENGINEERING DATA**

# **ENGINE SPECIFICATIONS**

$\cap$	_	_	_		ī
l-	e.	n	Н.	ГA	

Make	Perkins
EPA Emission Compliance	Tier 4 Interim
Cylinder #	4
Туре	In-Line
Displacement - in <sup>3</sup> (L)	2.22 (135)
Bore - in (mm)	3.3 (84.0)
Stroke - in (mm)	3.9 (100.0)
Compression Ratio	23.3:1
Intake Air Method	Turbocharged/Aftercooled
Piston Type	Aluminum
Crankshaft Type	Forged Steel
Engine Block Type	Cast Iron

# Engine Governing

Governor	Electronic
Frequency Regulation (Steady State)	±0.25%

# Lubrication System

Oil Pump Type	Gear
Oil Filter Type	Full Flow Cartridge
Crankcase Capacity with Filters- qt (L)	11.2 (10.6)

# Cooling System

Cooling System Type	Closed Recovery
Fan Type	Pusher
Fan Speed- rpm	1,980
Fan Diameter - in (mm)	18.0 (457.2)

# Fuel System

Fuel Type	Ultra Low Sulfur Diesel Fuel		
Fuel Specification	ASTM		
Fuel Pump Type	Mechanical Engine Driven Gear		
Injector Type	Mechanical		
Fuel Supply Lin (mm/in)	7.94/0.31 (ID)		
Fuel Return Line (mm/in)	4.76/.19 (ID)		
Fuel Filtering (microns)	25		

# Engine Electrical System

System Voltage	12 VDC
Battery Charger Alternator	Standard
Battery Size	See Battery Index 0161970SBY
Battery Voltage	12 VDC
Ground Polarity	Negative

# **ALTERNATOR SPECIFICATIONS**

Standard Model	Generac
Poles	4
Field Type	Rotating
Insulation Class - Rotor	Н
Insulation Class - Stator	Н
Total Harmonic Distortion	<5%
Telephone Interference Factor (TIF)	<50

Standard Excitation	Direct
Bearings	Single Sealed
Coupling	Flexible Disc
Prototype Short Circuit Test	Yes
Voltage Regulator Type	Full Digital
Number of Sensed Phases	2
Regulation Accuracy (Steady State)	±1%

# RD025 | 2.2L | 25 kW

# INDUSTRIAL DIESEL GENERATOR SET

**EPA Certified Stationary Emergency** 

# **OPERATING DATA**

## **POWER RATINGS**

Standby

GENERAC\* | INDUSTRIAL

		•	
Single-Phase 120/480 VAC @0.1pf	25 kW	Amps: 104	
Three-Phase 120/208 VAC @0.8pf	25 kW	Amps: 87	
Three-Phase 120/240 VAC @0.8pf	25 kW	Amps: 75	
Three-Phase 277/480 VAC @0.8pf	25 kW	Amps: 37	

# **MOTOR STARTING CAPABILITIES (sKVA)**

# sKVA vs. Voltage Dip at 30%

120/240 V, Single-Phase at 0.4pf	168
120/208 V, Three-Phase at 0.4pf	144
120/240 V, Three-Phase at 0.4pf	125
120/240 V, Three-Phase at 0.4pf	64

# **FUEL CONSUMPTION RATES\***

Percent Load	Diesel gal/hr (L/hr)
25%	0.97 (3.67)
50%	1.37 (5.19)
75%	1.97 (7.46)
100%	2.77 (10.49)

<sup>\*</sup> Fuel supply installation must accommodate fuel consumption rates at 100% load.

# **COOLING**

		Standby
Air Flow (Radiator and Alternator)	ft³/min (m³/min)	2800 (79)
Coolant System Capacity	gal (L)	2.5 (9.5)
Heat Rejection to Coolant	BTU/hr (MJ/hr)	128,638 (135.7)
Max. Operating Ambient Temperature	°F (°C)	122 (50)
Maximum Operating Ambient Temperature (Before Derate)	See Bulletin No. 0199270SSD	
Maximum Radiator Backpressure	in H <sub>2</sub> O (kPa)	0.50 (0.12)


# **COMBUSTION AIR REQUIREMENTS**


	Standby
Flow at Rated Power ft <sup>3</sup> /min	(m <sup>3</sup> /min) 88 (2.5)

ENGINE			EXHAUST		
		Standby			Standby
Rated Engine Speed	rpm	1,800	Exhaust Flow (Rated Output)	ft³/min (m³/min)	296.6 (8.4)
			Exhaust Temp (Rated Output - Post Silencer)	°F (°C)	930 (499)

**EPA Certified Stationary Emergency** 

# **DIMENSIONS AND WEIGHTS\***





# Weights and Dimensions


Unit Weight - Ibs	Unit Weight with Skid - Ibs	Dimensions (L x W x H) in
2,811	2,849	84.2 x 35.0 x 91.7

25kW Fuel Consumption	with fuel tank 103.4" 35" x 91.7"
Fuel Tank Gross Total Capacity	240 103.4 33 X 91.7
Fuel Tank Gross Usable Capacity	229
Fuel Tank Net Usable Capacity (Run Hours Based on Net Usable Capacity)	206
Run Hours 100% Load	98
Run Hours 75% Load	125
Run Hours 50% Load	161

Sound Emission Data

Rated Load Sound Output at 23ft - dB(A) 65

<sup>\*</sup> All measurements are approximate and for estimation purposes only. Drawing is for illustration purposes only, not to scale.



Specification characteristics may change without notice. Dimensions and weights are for preliminary purposes only. Please consult a Generac Power Systems Industrial Dealer for detailed installation drawings.

# EXHIBIT 8

Map showing nearest wetlands

