



January 9, 2024

VIA ELECTRONIC MAIL

Melanie A. Bachman, Executive Director

Connecticut Siting Council

10 Franklin Square

New Britain, CT 06051

RE: CSC Approval EM-AT&T-131-221005 CT5250 Spring Street

Generator Installation 626 Spring Street, Town of Southington Connecticut

Dear Ms. Bachman,

The purpose of this letter is to notify the Siting Council that construction activity associated with the above-referenced decisions has been completed.

If you have any questions or need any additional information regarding this facility, please do not hesitate to contact me.

Sincerely,

Catherine Conklin

Site Acquisition Specialist

General Dynamics Wireless Services

4603 Kemper Street

Rockville, MD 20853

(301) 266-0258

catherine.conklin@qdit.com

GENERAL DYNAMICS
Information Technology

Generator Contractor Notice of Completion

I, Greg Marsh - Site Wireless, confirm that the awarded scope of work at site 10071248 - SOUTHLINGTON FL is complete, and all work meets industry standards and jurisdictional code requirements. All required inspections were completed, and all permits are closed. Please find the required notice of completion form with photos, etc. attached for your review and acceptance.

GC Signature Greg Marsh

You MUST copy and paste IDs from OneVizion here
In order for the system to receive this document.

Site Xitor ID 10012112837

Project Xitor ID 10020706212

Workflow ID 521517-B00227

Generator Contractor Notice of Completion

General Site Information	
FA Number	10071248
Address Line 1	
Address Line 2	OVERLAY - GSM -SOUTHINGTON FLORI
City, State, Zip	SOUTHINGTON, CT 06489

Contractor Information	
Contractor Name	Site Wireless
PM or POC	Greg Marsh
Phone Number	860-729-9357
Email Address	gregmarsh@sitewireless.net

Final Accounting	
Base PO Amount	
Approved Work Authorizations	
Total Due at Final Acceptance	
Release of Liens	

Only ONE ITEM per field. Please ZIP multiple items. Place photo icon directly on the red indicator.

Documentation	
Daily CHA Forms (zipped)	<input type="radio"/>
Permits Closed Out	<input type="radio"/>
Fuel Receipt (if applicable)	<input type="radio"/>
Redline CDs	<input type="radio"/>
Pre-Start Checklist	

Remember to RESIZE large photos. Also, ZIP Multiple Photos! Only one item allowed per field.

Notice of Completion - Photos

<u>General Site Information</u>		
Item #	Description	Photo
C1-GD	ATS installed and Grounded as per CD's	○
C2-GD	All foundations are oriented as per CD's	○
C3-GD	All foundations set, Square, Level & Correct Size as per CD's	○
C4-GD	All Conduits installed as per CD's	○
C5-GD	Automatic Transfer Switch (ATS) Installed (if applicable) / Cam-Lock	○
C6-GD	All wiring from the generator to the ATS correct gauge	
C7-GD	Generator Control & Alarm Wires Installed and Labeled w/66 block	
C8-GD	Generator frame attached to ground system with 2 hole lug	○
C9-GD	Housekeeping: All trash removed	○
C10-GD	Remove construction materials and clean site	○
C11-GD	Generator undamaged & clean	○
C12-GD	Fuel Tank Installed level and as per CD's	○

Item #	Description	Photo
C13-GD	Initial Fueling Complete, filled to 80%	
C14-GD	Individual alarms labeled and run to the 66 alarm block in shelter	
C15-AT&T	All documentation left on site including manual and keys	
C17-AT&T	Install information added to log book in site	○
C18-AT&T	Generator Commissioning Complete	○
C22-AT&T	Signage installed on generator	○
C23-AT&T	Padlocks installed on ATS and fuel door	○
A1	Pre-Construction Photos-General site area	○
A2	Foundation rebar photos, measure rebar size and spacing	○
A3	Generator Anchor Bolts to Slab, 2 each side	○
A4	Trench depth photos	
A5	Conduit installation depth	○
A6	CAD Weld from generator ground to existing ground ring	○

Item #	Description	Photo
A7	Post Construction Photos	○
B5	ATS Serial #	○
B6	Engine serial #	○
B7	Labeling of circuit breakers and panel schedule	○
B8	Site signage for compliance	
B9	Daily Logs-Site Log Book Photo Required	○



GENERAC
**INDUSTRIAL
POWER**

Southway, Spring 07

FOR FUEL & OTHER
OPERATIONAL
INSTRUCTIONS
CALL LOCAL
GENERAC SERVICE
TECHNICAL SUPPORT



AT&T
DIESEL FUEL
COMBUSTIBLE
NO SMOKING
NO OPEN FLAMES
FUEL TANK CAPACITY GALLS