

Robinson+Cole

KENNETH C. BALDWIN


280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

ORIGINAL

Also admitted in Massachusetts

February 4, 2015

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051



Re: **EM-VER-132-140609 – Cellco Partnership d/b/a Verizon Wireless**
151 Sand Hill Road, South Windsor, Connecticut

Dear Ms. Bachman:

Attached is an Existing Telecommunications Facility Tower Certification Letter for the Sandy Hill Road tower verifying that the structural modifications required to accommodate Cellco's antenna modifications have been completed. All construction associated with the above-referenced exempt modification filing has now been completed.

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Kenneth C. Baldwin".

Kenneth C. Baldwin

Attachment

Copy to:

Sandy M. Carter

Brian Ragozzine

Mark Gauger

CEN TEK engineering

Centered on Solutions™

February 3, 2015

Mr. Mark Gauger
Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Existing Telecommunications Facility Tower Certification Letter

Project: Verizon South Windsor 3
151 Sand Hill Road
South Windsor, CT

Tower Owner: SBA Communications

Engineer: FDH Engineering
6521 Meridien Drive
Raleigh, NC 27616

Centek Project No.: 14055.037

CSC Exempt Mod Reference No.: EM-VER-132-140609

Dear Mr. Gauger,


We are providing this "Existing Telecommunications Facility Tower Certification Letter" with regard to the antenna upgrade by Verizon Wireless at the above referenced project.

The following are the basis for substantiating compliance with the FDH Engineering structural analysis report (FDH Project No. 1423RK1400) dated March 5, 2014:

- Review of the FDH structural analysis report dated 03/05/2014.
- Field observations by Centek personnel of the coax and RRH installation on 01/21/2015 which determined all coax lines, RRH's and accessory equipment were installed in general compliance with the recommendations of the structural analysis report prepared by FDH Engineering on 03/05/2014.

The structural analysis prepared by FDH Engineering demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the referenced structural analysis.

Sincerely,


Carlo F. Centore, PE
Principal ~ Structural Engineer

