

May 19, 2016

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-137-141215 – Cellco Partnership d/b/a Verizon Wireless
7 Broadway Avenue Extension, Stonington, Connecticut**

Dear Ms. Bachman:

On January 5, 2015, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 7 Broadway Avenue Extension in Stonington, Connecticut. The modifications involved the replacement of its antennas and installation of remote radio heads.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter confirming that it has complied with the recommendations made in the structural report included with its filing. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the installation was completed according to the structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment
Copy to:
Tim Parks

May 18, 2016

Mr. Tim Parks

Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon Mystic S
7 Broadway Avenue Extension, Stonington, CT

Tower Owner: MCM
40 Woodland Street, Hartford, CT

Engineer: All-Points Technology Corporation, P.C.
3 Saddlebrook Drive, Killingworth, CT

Centek Project No.: 15003.067

CSC Exempt Mod Reference No.: EM-VER-137-141215

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by All-Points Technology Corporation 11/14/14:

- Review of All-Points Technology Corporation Structural Report.
- Field observations by Centek Engineering personnel 02/26/16 of the completed modifications that were installed in general compliance with the recommendations of the structural report prepared by All-Points Technology Corporation.

The modification design prepared by All- Points Technology Corporation demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,



Carlo F. Centore, PE
Principal - Structural

