

# INFINIGY®

FROM ZERO TO INFINIGY  
the solutions are endless

1033 WATERVLIET SHAKER RD, ALBANY, NY 12205

---

February 15, 2021

Jason Blinkhorn  
Project Manager  
401-787-6007  
jblinkhorn@qualtekwireless.com  
16 Esquire Rd, N Billerica MA 01862

**RE: PE Close Out Letter**  
**AT&T Site Name:** Thompson Quinebaug Road  
**AT&T Site ID:** CTL01088  
**FA Site Number:** 10065743  
**Site Address:** 720 Quinebaug Road  
Thompson, CT 06277

To Whom It May Concern,

Infinigy has conducted a post construction review of the above-mentioned site. Infinigy has prepared the drawings for the above-mentioned site and as such, we have conducted a final review of the proposed installation for the sole purpose to verify that the installation was completed in accordance with the site plans.

Based on our review of the Signed and Sealed Engineering Drawings for this site completed by Infinigy (Revision 1, Dated 10/7/19), and contractor-provided As-Built Drawings & closeout photos, the following items deviate from the original site plans:

- Existing DC Power Plant & Battery rack was replaced in the existing equipment shelter at ground level.

The above deviations do not alter the overall integrity of the project, and therefore, it is the opinion of Infinigy that the site was built in general conformance with the site plans as prepared by Infinigy.

Please free to contact me at (518) 690-0790 if you have any questions or require additional information.

Sincerely,

Chris Warren, P.E.  
Infinigy Engineering



New York Georgia California New Jersey Colorado Florida New Hampshire

INFINIGY®