

November 22, 2016

VIA EMAIL AND OVERNIGHT DELIVERY

Ms. Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

RE: T-Mobile Northeast LLC – CT11860A
Notice of Exempt Modification
48 Quail Trail, Trumbull, CT
Pole 838
LAT: 41-13-57.66N
LNG: 73-10-20.11W

Dear Ms. Bachman:

T-Mobile Northeast LLC ("T-Mobile") currently maintains three (3) antennas at the 105' level on the existing 95' transmission tower located at 48 Quail Trail, Trumbull, CT. The structure is owned by Eversource Energy, their use of the structure was approved by the Council on December 14, 2000 (Docket No. 496). T-Mobile submitted a Petition for a 10' extension on this structure, which was approved by the Council on December 4, 2008 (Petition 872).

Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A.16-50j-72(b)(2). In accordance with R.C.S.A. 16-50j-73, a copy of this letter is being sent to Timothy M. Herbst, First Selectman, Town of Trumbull, and the property owner, Eversource Energy.

The planned modifications to the facility fall squarely within those activities explicitly provided for in RC.S.A. 16-50j-72(b)(s).

1. The proposed modifications will not result in an increase in the height of the existing structure. T-Mobile proposes to swap (3) antennas, at a centerline height of 105' on the existing 95' structure.
2. The proposed modifications will not require the extension of the site boundary. There will be no effect on the site compound or T-Mobile's leased area.
3. The proposed modifications will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local

criteria. The incremental effect of the proposed changes will be negligible.

4. The operation of the replacement antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard. As indicated in the attached power density calculations, T-Mobile's operations at the site will result in a power density of 2.50%; the combined site operations will result in a total power density of 2.50%.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site. T-Mobile will swap antennas on the existing mounts and the coax lines will be run within the existing cable tray.
6. The existing structure, and its foundation can support T-Mobile's proposed loading, as indicated in the attached structural analysis.

For the foregoing reasons, T-Mobile respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitute an exempt modification under R.C.S.A. J 6-50j-72(b)(2) .

Please feel free to call me with any questions or concerns regarding this matter. Thank you for your consideration.

Respectfully submitted,



By: _____
Jamie Ford, Agent for T-Mobile
jford@verticaldevelopmentllc.com
774-248-5373

Attachments

cc: Timothy M. Herbst, First Selectman, Town of Trumbull
Eversource Energy

NOTES:

1. PROPOSED T-MOBILE INSTALLATION SHALL CONSIST OF THE REPLACEMENT OF THREE (3) DIRECTIONAL PANEL ANTENNAS MOUNTED AT A CENTERLINE ELEVATION OF ±105' AGL.

PROPOSED T-MOBILE ANTENNAS, TYP. OF THREE (3) MOUNTED TO EXISTING ANTENNA MAST ATTACHED TO EVERSOURCE TRANSMISSION STRUCTURE.

TWELVE (12) EXISTING T-MOBILE 1-5/8"Ø COAX CABLES AND SIX (6) PROPOSED 1-5/8" COAX CABLES ROUTED ALONG TRANSMISSION STRUCTURE EXTERIOR.

EXISTING UTILITY BACKBOARD.

EXISTING T-MOBILE PPC CABINET MOUNTED ON FRAME TO REMAIN.

EXISTING T-MOBILE ICE BRIDGE ABOVE.

EXISTING GPS ANTENNA (TYP. OF 2) MOUNTED TO ICE BRIDGE.

EXISTING T-MOBILE ERICSSON RBS 6102 EQUIPMENT CABINET ON CONC. PAD TO REMAIN.


EXISTING 95' TALL EVERSOURCE TRANSMISSION STRUCTURE.

EXISTING WOOD POLE.

EXISTING T-MOBILE ERICSSON RBS 3106 EQUIPMENT CABINET ON CONC. PAD TO REMAIN.

EXISTING 8' TALL WOOD STOCKADE FENCE, TYP.

1
L-1
SITE PLAN
SCALE: 1" = 5'



LEASE EXHIBIT

THIS LEASE PLAN IS DIAGRAMMATIC IN NATURE AND IS INTENDED TO PROVIDE GENERAL INFORMATION REGARDING THE LOCATION AND SIZE OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. THE SITE LAYOUT WILL BE FINALIZED UPON COMPLETION OF SITE SURVEY AND FACILITY DESIGN.

TOWER COORDINATES: LAT.: 41°-13'-57.74"
LANG.: 73°-10'-19.87"

GROUND ELEVATION: 228± A.M.S.L.

COORDINATES AND GROUND ELEVATION REFERENCED FROM GOOGLE EARTH.

T-MOBILE_RAN_TEMPLATE:
704Bu_OUTDOOR

T-MOBILE_RF_CONFIGURATION:
1HP_704Bu




SITE KEY PLAN

SCALE: 1" = 150'



REV.	DATE	BY	CHK'D BY	DESCRIPTION
1	10/20/16	FPE	HMR	LEASE EXHIBIT
0	10/11/16	FPE	HMR	LEASE EXHIBIT - ISSUED FOR CLIENT REVIEW



CENTEK engineering
Centered on Solutions™
www.CentekEng.com
(203) 488-0580
(203) 488-8587 Fax
63-2 North Branford Road, Branford, CT 06405

T-MOBILE NORTHEAST LLC
CT860/CL&P TRUMBULL
SITE ID: CT11860A
48 QUAIL TRAIL
TRUMBULL, CT 06611

DATE: 10/05/16
SCALE: AS SHOWN
JOB NO. 16159.04

SHEET NO.
L-1

LEASE EXHIBIT

THIS LEASE PLAN IS DIAGRAMMATIC IN NATURE AND IS INTENDED TO PROVIDE GENERAL INFORMATION REGARDING THE LOCATION AND SIZE OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. THE SITE LAYOUT WILL BE FINALIZED UPON COMPLETION OF SITE SURVEY AND FACILITY DESIGN.

PROPOSED T-MOBILE ANTENNAS, TYP. OF THREE (3) MOUNTED TO EXISTING ANTENNA MAST ATTACHED TO EVERSOURCE TRANSMISSION STRUCTURE.

EXISTING 95' TALL TOWER EVERSOURCE TRANSMISSION STRUCTURE.

TWELVE (12) EXISTING T-MOBILE 1-5/8"Ø COAX CABLES AND SIX (6) PROPOSED 1-5/8" COAX CABLES ROUTED ALONG TRANSMISSION STRUCTURE EXTERIOR.

EXISTING T-MOBILE ICE BRIDGE, TYP.


EXISTING T-MOBILE ERICSSON RBS 6102 CABINET ON CONC. PAD TO REMAIN.

EXISTING GPS ANTENNA (TYP. OF 2).

EXISTING T-MOBILE ERICSSON RBS 3106 EQUIPMENT CABINET ON CONC. PAD TO REMAIN.

EXISTING 8' TALL WOOD STOCKADE FENCE, TYP.


⊕ EXISTING/PROPOSED T-MOBILE ANTENNAS
EL. ±105-0" A.G.L.



GRAPHIC SCALE



(IN FEET)
1 inch = 10 ft.



EXISTING T-MOBILE STAND OFF ARM, TYP. THREE (3) TOTAL.

PROPOSED T-MOBILE ANTENNA, TYP. OF 1 PER SECTOR, TO REPLACE EXISTING ANTENNA. MODEL: SBNHH-1D65A (DIMS: 55.0"Lx11.9"Wx7.1"D)

1
L-2

EAST ELEVATION

SCALE: 1" = 10'

2
L-2

ANTEANNA LAYOUT PLAN

NOT TO SCALE

1	10/20/16	FPE	HMR	LEASE EXHIBIT					
0	10/11/16	FPE	HMR	LEASE EXHIBIT					
REV.	DATE	DRAWN BY	CHK'D BY	DESCRIPTION					

PROFESSIONAL ENGINEER SEAL

CENTEK engineering
 Centered on SolutionsSM
 www.CentekEng.com
 (203) 488-0580
 (203) 488-8587 Fax
 63-2 North Branford Road, Branford, CT 06405

T-MOBILE NORTHEAST LLC
CT860/CL&P TRUMBULL
 SITE ID: CT11860A
 48 QUAIL TRAIL
 TRUMBULL, CT 06611

DATE: 10/05/16
 SCALE: AS SHOWN
 JOB NO. 16159.04

SHEET NO.
L-2

**Structural Analysis of
Antenna Mast and Pole**


T-Mobile Site Ref: CT11860A

*Eversource Structure No. 838
95' Electric Transmission Pole*

*48 Quail Trail
Trumbull, CT*

CEN TEK Project No. 16159.04

Date: October 24, 2016



Prepared for:
T-Mobile USA
35 Griffin Road
Bloomfield, CT 06002

Table of Contents

SECTION 1 - REPORT

- INTRODUCTION
- PRIMARY ASSUMPTIONS USED IN THE ANALYSIS
- ANALYSIS
- DESIGN BASIS
- RESULTS
- CONCLUSION

SECTION 2 - CONDITIONS & SOFTWARE

- STANDARD ENGINEERING CONDITIONS
- GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAMS
 - RISA 3-D
 - PLS POLE

SECTION 3 - DESIGN CRITERIA

- CRITERIA FOR DESIGN OF PCS FACILITIES ON OR EXTENDING ABOVE METAL ELECTRIC TRANSMISSION TOWERS
- NU DESIGN CRITERIA TABLE
- PCS SHAPE FACTOR CRITERIA
- WIRE LOADS SHEET

SECTION 4 - DRAWINGS

- EL-1 POLE AND MAST ELEVATION

SECTION 5 - TIA-222-G LOAD CALCULATIONS FOR MAST ANALYSIS

- MAST WIND & ICE LOAD

SECTION 6 - MAST ANALYSIS PER TIA-222G

- LOAD CASES AND COMBINATIONS (TIA LOADING)
- RISA 3-D ANALYSIS REPORT
- MAST CONNECTION TO TOWER ANALYSIS

**SECTION 7 - NECS/NU LOAD CALCULATIONS FOR OBTAINING
MAST REACTIONS APPLIED TO UTILITY STRUCTURE**

- MAST WIND LOAD

**SECTION 8 - MAST ANALYSIS PER NESC/NU FOR OBTAINING
REACTIONS APPLIED TO UTILITY STRUCTURE**

- LOAD CASES AND COMBINATIONS (NESC/NU LOADING)
- RISA 3-D ANALYSIS REPORT

**SECTION 9 - PLS POLE RESULTS FROM MAST REACTIONS
CALCULATED IN RISA WITH NESC/NU CRITERIA**

- COAX CABLE LOAD ON CL&P TOWER CALCULATION
- PLS REPORT
- ANCHOR BOLT ANALYSIS
- FOUNDATION ANALYSIS

SECTION 10 - REFERENCE MATERIAL

- RFDS SHEET
- EQUIPMENT CUT SHEETS

Introduction

The purpose of this report is to analyze the existing mast and 95' utility pole located at 48 Quail Trail in Trumbull, CT for the proposed antenna and equipment upgrade by T-Mobile.

The existing/proposed loads consist of the following:

- **T-MOBILE (Existing to be removed):**
Antennas: Three (3) RFS APX16DWV-16DWVS-E-A20 panel antennas mounted on a mast with a RAD center elevation of 105-ft above tower base plate.
- **T-MOBILE (Existing to remain):**
Coax Cables: Twelve (12) 1-5/8" \varnothing coax cables running on the outside of the tower as indicated in section 4 of this report.
- **T-MOBILE (Proposed):**
Antennas: Three (3) Andrew SBNHH-1D65A panel antennas mounted on three (3) existing standoff arms to the existing pipe mast with a RAD center elevation of 105-ft above tower base plate.
Coax Cables: Six (6) 1-5/8" \varnothing coax cables running on the outside of the tower as indicated in section 4 of this report.

Primary assumptions used in the analysis

- ASCE Manual No. 72, "Design of Steel Transmission Pole Structures Second Edition", defines steel stresses for evaluation of the utility pole.
- All utility pole members are adequately protected to prevent corrosion of steel members.
- All proposed antenna mounts are modeled as listed above.
- Pipe mast will be properly installed and maintained.
- No residual stresses exist due to incorrect pole erection.
- All bolts are appropriately tightened providing the necessary connection continuity.
- All welds conform to the requirements of AWS D1.1.
- Pipe mast and utility pole will be in plumb condition.
- Utility pole was properly installed and maintained and all members were properly designed, detailed, fabricated, and installed and have been properly maintained since erection.
- Any deviation from the analyzed loading will require a new analysis for verification of structural adequacy.

A n a l y s i s

Structural analysis of the existing antenna mast was independently completed using the current version of RISA-3D computer program licensed to CENTEK Engineering, Inc.

The existing mast consisting of a 12-in x 28.25-ft long SCH. 40 pipe (O.D. = 12.75”) connected at two points to the existing tower was analyzed for its ability to resist loads prescribed by the TIA-222G standard. Section 5 of this report details these gravity and lateral wind loads. NESC prescribed loads were also applied to the mast in order to obtain reactions needed for analyzing the utility pole structure. These loads are developed in Section 7 of this report. Load cases and combinations used in RISA-3D for TIA-222-G loading and for NESC/NU loading are listed in report Sections 6 and 8, respectively.

An envelope solution was first made to determine maximum and minimum forces, stresses, and deflections to confirm the selected section as adequate. Additional analyses were then made to determine the NESC forces to be applied to the pole structure.

The RISA-3D program contains a library of all AISC shapes and corresponding section properties are computed and applied directly within the program. The program’s Steel Code Check option was also utilized. The forces calculated in RISA-3D using NESC guidelines were then applied to the pole using PLS-Pole. Maximum usage for the pole was calculated considering the additional forces from the mast and associated appurtenances.

D e s i g n B a s i s

Our analysis was performed in accordance with TIA-222-G, ASCE Manual No. 72 – “Design of Steel Transmission Pole Structures Second Edition”, NESC C2-2007 and Northeast Utilities Design Criteria.

▪ UTILITY POLE ANALYSIS

The purpose of this analysis is to determine the adequacy of the existing utility pole to support the proposed antenna loads. The loading and design requirements were analyzed in accordance with the NU Design Criteria Table, NESC C2-2007 ~ Construction Grade B, and ASCE Manual No. 72.

Load cases considered:

Load Case 1: NESC Heavy

Wind Pressure.....	4.0 psf
Radial Ice Thickness.....	0.5”
Vertical Overload Capacity Factor.....	1.50
Wind Overload Capacity Factor.....	2.50
Wire Tension Overload Capacity Factor.....	1.65

Load Case 2: NESC Extreme

Wind Speed.....	110 mph ⁽¹⁾
Radial Ice Thickness.....	0”

Note 1: NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading, 1.25 x Gust Response Factor (wind speed: 3-second gust)

▪ **MAST ASSEMBLY ANALYSIS**

Mast, appurtenances and connections to the utility tower were analyzed and designed in accordance with the NU Design Criteria Table, TIA-222-G and AISC standards.

Load cases considered:

Load Case 1:

Wind Speed..... 97 mph ^(2016 CSBC Appendix-N)
 Radial Ice Thickness..... 0"

Load Case 2:

Wind Pressure..... 50 mph wind pressure
 Radial Ice Thickness..... 0.75"

Results

▪ **MAST ASSEMBLY**

The existing mast was determined to be structurally **adequate**.

Member	Stress Ratio (% of capacity)	Result
12" Sch. 40 Pipe	17.3%	PASS
3/4" Ø ASTM A325 Bolt	14.7%	PASS

▪ **UTILITY POLE**

This analysis finds that the subject utility pole is adequate to support the proposed antenna mast and related appurtenances. The pole stresses meet the requirements set forth by the ASCE Manual No. 72, "Design of Steel Transmission Pole Structures Second Edition", for the applied NESC Heavy and Hi-Wind load cases. The detailed analysis results are provided in Section 9 of this report. The analysis results are summarized as follows:

A maximum usage of **68.59%** occurs in the utility pole base plate under the **NESC Heavy** loading condition.

POLE SECTION:

The utility pole was found to be within allowable limits.

Tower Section	Elevation	Stress Ratio (% of capacity)	Result
Tube Number 2	9.25-54.25' (AGL)	68.59%	PASS

BASE PLATE:

The base plate was found to be within allowable limits from the PLS output based on 16 bend lines.

Tower Component	Design Limit	Stress Ratio (percentage of capacity)	Result
Base Plate	Bending	61.82%	PASS

▪ FOUNDATION AND ANCHORS

The existing foundation consists of a 10-ft square x 14-ft long reinforced concrete pier with (16) rock anchors. The base of the tower is connected to the foundation by means of (20) 2.25"Ø, ASTM A615-75 anchor bolts embedded into the concrete foundation structure. Foundation information was obtained from NUSCO drawing # 01103-60000.

BASE REACTIONS:

From PLS-Pole analysis of pole based on NESC/NU prescribed loads.

Load Case	Shear	Axial	Moment
NESC Heavy Wind	47.97 kips	63.68 kips	3540.23 ft-kips
NESC Extreme Wind	49.98 kips	34.68 kips	3462.89 ft-kips

Note 1 – 10% increase applied to tower base reactions per OTRM 051

ANCHOR BOLTS:

The anchor bolts were found to be within allowable limits.

Tower Component	Design Limit	Stress Ratio (% of capacity)	Result
Anchor Bolts	Tension	58.71%	PASS

FOUNDATION:

The foundation was found to be within allowable limits.

Foundation	Design Limit	Allowable Limit	Proposed Loading ⁽⁴⁾	Result
Reinf. Conc. Pier w/ Rock Anchors	OTM ⁽¹⁾	1.0 FS ⁽²⁾	1.97 FS ⁽²⁾	PASS
	Bearing Pressure	50 ksf ⁽³⁾	39.6 ksf	PASS

Note 1: OTM denotes overturning moment.

Note 2: FS denotes Factor of Safety

Note 3: Bearing Capacity based on Weak Rock.

Note 4: 10% increase to PLS base reactions used in foundation analysis per OTRM 051.


Conclusion


This analysis shows that the subject utility pole **is adequate** to support the proposed T-Mobile equipment upgrade.

The analysis is based, in part on the information provided to this office by Eversource and T-Mobile. If the existing conditions are different than the information in this report, CENTEK engineering, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.

Respectfully Submitted by:


 Timothy J. Lynn, PE
 Structural Engineer



STANDARD CONDITIONS FOR FURNISHING OF
PROFESSIONAL ENGINEERING SERVICES ON
EXISTING STRUCTURES

All engineering services are performed on the basis that the information used is current and correct. This information may consist of, but is not necessarily limited to:

- Information supplied by the client regarding the structure itself, its foundations, the soil conditions, the antenna and feed line loading on the structure and its components, or other relevant information.
- Information from the field and/or drawings in the possession of CENTEK engineering, Inc. or generated by field inspections or measurements of the structure.
- It is the responsibility of the client to ensure that the information provided to CENTEK engineering, Inc. and used in the performance of our engineering services is correct and complete. In the absence of information to the contrary, we assume that all structures were constructed in accordance with the drawings and specifications and are in an un-corroded condition and have not deteriorated. It is therefore assumed that its capacity has not significantly changed from the “as new” condition.
- All services will be performed to the codes specified by the client, and we do not imply to meet any other codes or requirements unless explicitly agreed in writing. If wind and ice loads or other relevant parameters are to be different from the minimum values recommended by the codes, the client shall specify the exact requirement. In the absence of information to the contrary, all work will be performed in accordance with the latest revision of ANSI/ASCE10 & ANSI/EIA-222.
- All services are performed, results obtained, and recommendations made in accordance with generally accepted engineering principles and practices. CENTEK engineering, Inc. is not responsible for the conclusions, opinions and recommendations made by others based on the information we supply.

GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ RISA - 3 D

RISA-3D Structural Analysis Program is an integrated structural analysis and design software package for buildings, bridges, tower structures, etc.

Modeling Features:

- Comprehensive CAD-like graphic drawing/editing capabilities that let you draw, modify and load elements as well as snap, move, rotate, copy, mirror, scale, split, merge, mesh, delete, apply, etc.
- Versatile drawing grids (orthogonal, radial, skewed)
- Universal snaps and object snaps allow drawing without grids
- Versatile general truss generator
- Powerful graphic select/unselect tools including box, line, polygon, invert, criteria, spreadsheet selection, with locking
- Saved selections to quickly recall desired selections
- Modification tools that modify single items or entire selections
- Real spreadsheets with cut, paste, fill, math, sort, find, etc.
- Dynamic synchronization between spreadsheets and views so you can edit or view any data in the plotted views or in the spreadsheets
- Simultaneous view of multiple spreadsheets
- Constant in-stream error checking and data validation
- Unlimited undo/redo capability
- Generation templates for grids, disks, cylinders, cones, arcs, trusses, tanks, hydrostatic loads, etc.
- Support for all units systems & conversions at any time
- Automatic interaction with RISASection libraries
- Import DXF, RISA-2D, STAAD and ProSteel 3D files
- Export DXF, SDNF and ProSteel 3D files

Analysis Features:

- Static analysis and P-Delta effects
- Multiple simultaneous dynamic and response spectra analysis using Gupta, CQC or SRSS mode combinations
- Automatic inclusion of mass offset (5% or user defined) for dynamic analysis
- Physical member modeling that does not require members to be broken up at intermediate joints
- State of the art 3 or 4 node plate/shell elements
- High-end automatic mesh generation — draw a polygon with any number of sides to create a mesh of well-formed quadrilateral (NOT triangular) elements.
- Accurate analysis of tapered wide flanges - web, top and bottom flanges may all taper independently
- Automatic rigid diaphragm modeling
- Area loads with one-way or two-way distributions
- Multiple simultaneous moving loads with standard AASHTO loads and custom moving loads for bridges, cranes, etc.
- Torsional warping calculations for stiffness, stress and design
- Automatic Top of Member offset modeling
- Member end releases & rigid end offsets
- Joint master-slave assignments
- Joints detachable from diaphragms
- Enforced joint displacements
- 1-Way members, for tension only bracing, slipping, etc.

- 1-Way springs, for modeling soils and other effects
- Euler members that take compression up to their buckling load, then turn off.
- Stress calculations on any arbitrary shape
- Inactive members, plates, and diaphragms allows you to quickly remove parts of structures from consideration
- Story drift calculations provide relative drift and ratio to height
- Automatic self-weight calculations for members and plates
- Automatic subgrade soil spring generator

Graphics Features:

- Unlimited simultaneous model view windows
- Extraordinary “true to scale” rendering, even when drawing
- High-speed redraw algorithm for instant refreshing
- Dynamic scrolling stops right where you want
- Plot & print virtually everything with color coding & labeling
- Rotate, zoom, pan, scroll and snap views
- Saved views to quickly restore frequent or desired views
- Full render or wire-frame animations of deflected model and dynamic mode shapes with frame and speed control
- Animation of moving loads with speed control
- High quality customizable graphics printing

Design Features:

- Designs concrete, hot rolled steel, cold formed steel and wood
- ACI 1999/2002, BS 8110-97, CSA A23.3-94, IS456:2000, EC 2-1992 with consistent bar sizes through adjacent spans
- Exact integration of concrete stress distributions using parabolic or rectangular stress blocks
- Concrete beam detailing (Rectangular, T and L)
- Concrete column interaction diagrams
- Steel Design Codes: AISC ASD 9th, LRFD 2nd & 3rd, HSS Specification, CAN/CSA-S16.1-1994 & 2004, BS 5950-1-2000, IS 800-1984, Euro 3-1993 including local shape databases
- AISI 1999 cold formed steel design
- NDS 1991/1997/2001 wood design, including Structural Composite Lumber, multi-ply, full sawn
- Automatic spectra generation for UBC 1997, IBC 2000/2003
- Generation of load combinations: ASCE, UBC, IBC, BOCA, SBC, ACI
- Unbraced lengths for physical members that recognize connecting elements and full lengths of members
- Automatic approximation of K factors
- Tapered wide flange design with either ASD or LRFD codes
- Optimization of member sizes for all materials and all design codes, controlled by standard or user-defined lists of available sizes and criteria such as maximum depths
- Automatic calculation of custom shape properties
- Steel Shapes: AISC, HSS, CAN, ARBED, British, Euro, Indian, Chilean
- Light Gage Shapes: AISI, SSMA, Dale / Incor, Dietrich, Marino\WARE
- Wood Shapes: Complete NDS species/grade database
- Full seamless integration with RISAFoot (Ver 2 or better) for advanced footing design and detailing
- Plate force summation tool

Results Features:

- Graphic presentation of color-coded results and plotted designs
- Color contours of plate stresses and forces with quadratic smoothing, the contours may also be animated
- Spreadsheet results with sorting and filtering of: reactions, member & joint deflections, beam & plate forces/stresses, optimized sizes, code designs, concrete reinforcing, material takeoffs, frequencies and mode shapes
- Standard and user-defined reports
- Graphic member detail reports with force/stress/deflection diagrams and detailed design calculations and expanded diagrams that display magnitudes at any dialed location
- Saved solutions quickly restore analysis and design results.

GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ PLS - TOWER

PLS-TOWER is a Microsoft Windows program for the analysis and design of steel latticed towers used in electric power lines or communication facilities. Both self-supporting and guyed towers can be modeled. The program performs design checks of structures under user specified loads. For electric power structures it can also calculate maximum allowable wind and weight spans and interaction diagrams between different ratios of allowable wind and weight spans.

Modeling Features:

- Powerful graphics module (stress usages shown in different colors)
- Graphical selection of joints and members allows graphical editing and checking
- Towers can be shown as lines, wire frames or can be rendered as 3-d polygon surfaces
- Can extract geometry and connectivity information from a DXF CAD drawing
- CAD design drawings, title blocks, drawing borders or photos can be tied to structure model
- XML based post processor interface
- Steel Detailing Neutral File (SDNF) export to link with detailing packages
- Can link directly to line design program PLS-CADD
- Automatic generation of structure files for PLS-CADD
- Databases of steel angles, rounds, bolts, guys, etc.
- Automatic generation of joints and members by symmetries and interpolations
- Automated mast generation (quickly builds model for towers that have regular repeating sections) via graphical copy/paste
- Steel angles and rounds modeled either as truss, beam or tension-only elements
- Guys are easily handled (can be modeled as exact cable elements)

Analysis Features:

- Automatic handling of tension-only members
- Automatic distribution of loads in 2-part suspension insulators (v-strings, horizontal vees, etc.)
- Automatic calculation of tower dead, ice, and wind loads as well as drag coefficients according to:
 - ASCE 74-1991
 - NESC 2002
 - NESC 2007
 - IEC 60826:2003
 - EN50341-1:2001 (CENELEC)
 - EN50341-3-9:2001 (UK NNA)
 - EN50341-3-17:2001 (Portugal NNA)
 - ESAA C(b)1-2003 (Australia)
 - TPNZ (New Zealand)
 - REE (Spain)
 - EIA/TIA 222-F
 - ANSI/TIA 222-G
 - CSA S37-01
- Automated microwave antenna loading as per EIA/TIA 222-F and ANSI/TIA 222-G
- Minimization of problems caused by unstable joints and mechanisms
- Automatic bandwidth minimization and ability to solve large problems
- Design checks according to (other standards can be added easily):
 - ASCE Standard 10-90

CENTEK Engineering, Inc.
Structural Analysis – 95-ft Pole # 838
T-Mobile Antenna Upgrade – CT11860A
Trumbull, CT
October 24, 2016

- AS 3995 (Australian Standard 3995)
- BS 8100 (British Standard 8100)
- EN50341-1 (CENELEC, both empirical and analytical methods are available)
- ECCS 1985
- NGT-ECCS
- PN-90/B-03200
- EIA/TIA 222-F
- ANSI/TIA 222-G
- CSA S37-01
- EDF/RTE Resal
- IS 802 (India Standard 802)

Results Features:

- Design summaries printed for each group of members
 - Easy to interpret text, spreadsheet and graphics design summaries
 - Automatic determination of allowable wind and weight spans
 - Automatic determination of interaction diagrams between allowable wind and weight spans
 - Capability to batch run multiple tower configurations and consolidate the results
 - Automated optimum angle member size selection and bolt quantity determination
- Tool for interactive angle member sizing and bolt quantity determination.

Criteria for Design of PCS Facilities On or
Extending Above Metal Electric Transmission
Towers & Analysis of Transmission Towers
Supporting PCS Masts ⁽¹⁾

Introduction

This criteria is the result from an evaluation of the methods and loadings specified by the separate standards, which are used in designing telecommunications towers and electric transmission towers. That evaluation is detailed elsewhere, but in summary; the methods and loadings are significantly different. This criteria specifies the manner in which the appropriate standard is used to design PCS facilities including masts and brackets (hereafter referred to as “masts”), and to evaluate the electric transmission towers to support PCS masts. The intent is to achieve an equivalent level of safety and security under the extreme design conditions expected in Connecticut and Massachusetts.

ANSI Standard TIA-222 covering the design of telecommunications structures specifies a working strength/allowable stress design approach. This approach applies the loads from extreme weather loading conditions, and designs the structure so that it does not exceed some defined percentage of failure strength (allowable stress).

ANSI Standard C2-2007 (National Electrical Safety Code) covering the design of electric transmission metal structures is based upon an ultimate strength/yield stress design approach. This approach applies a multiplier (overload capacity factor) to the loads possible from extreme weather loading conditions, and designs the structure so that it does not exceed its ultimate strength (yield stress).

Each standard defines the details of how loads are to be calculated differently. Most of the NU effort in “unifying” both codes was to establish what level of strength each approach would provide, and then increasing the appropriate elements of each to achieve a similar level of security under extreme weather loadings.

Two extreme weather conditions are considered. The first is an extreme wind condition (hurricane) based upon a 50-year recurrence (2% annual probability). The second is a winter condition combining wind and ice loadings.

The following sections describe the design criteria for any PCS mast extending above the top of an electric transmission tower, and the analysis criteria for evaluating the loads on the transmission tower from such a mast from the lower portions of such a mast, and loads on the pre-existing electric lower portions of such a mast, and loads on the pre-existing electric transmission tower and the conductors it supports.

| Note 1: Prepared from documentation provide from Northeast Utilities.

P C S M a s t

The PCS facility (mast, external cable/trays, including the initial and any planned future support platforms, antennas, etc. extending the full height above the top level of the electric transmission structure) shall be designed in accordance with the provisions of TIA 222-G:

E L E C T R I C T R A N S M I S S I O N T O W E R

The electric transmission tower shall be analyzed using yield stress theory in accordance with the attached table titled “NU Design Criteria”. This specifies uniform loadings (different from the TIA loadings) on the each of the following components of the installed facility:

- PCS mast for its total height above ground level, including the initial and planned future support platforms, antennas, etc. above the top of an electric transmission structure.
- Conductors are related devices and hardware.
- Electric transmission structure. The loads from the PCS facility and from the electric conductors shall be applied to the structure at conductor and PCS mast attachment points, where those load transfer to the tower.

The uniform loadings and factors specified for the above components in the table are based upon the National Electrical Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to TIA and its loads and factors with the exceptions noted above. (Note that the NESC does not require the projected wind surfaces of structures and equipment to be increased by the ice covering.)

In the event that the electric transmission tower is not sufficient to support the additional loadings of the PCS mast, reinforcement will be necessary to upgrade the strength of the overstressed members.



Attachment A

NU Design Criteria

			Basic Wind Speed V (MPH)	Pressure Q (PSF)	Height Factor Kz	Gust Factor Gh	Load or Stress Factor	Force Coef - Shape Factor	
Ice Condition	TIA/EIA	Antenna Mount	TIA	TIA (.75Wi)	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA	
	NESC Heavy	Tower/Pole Analysis with antennas extending above top of Tower/Pole (Yield Stress)	-----	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole (on two faces)	-----	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU						
High Wind Condition	TIA/EIA	Antenna Mount	85	TIA	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA	
	NESC Extreme Wind	Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna					1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading Height above ground level based on top of Tower/Pole					1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU						
NESC Extreme Ice with Wind Condition*		Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna					1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load Height above ground level based on top of Tower/Pole					1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU						

* Only for Structures Installed after 2007

Communication Antennas on Transmission Structures (CL&P & WMECo Only)

Northeast Utilities Approved by: KMS (NU)	Design NU Confidential Information	OTRM 059	Rev.1 03/17/2011
		Page 7 of 9	



Shape Factor Criteria shall be per TIA Shape Factors.

- 2) STEP 2 - The electric transmission structure analysis and evaluation shall be performed in accordance with NESC requirements and shall include the mast and antenna loads determined from NESC applied loading conditions (not TIA/EIA Loads) on the structure and mount as specified below, and shall include the wireless communication mast and antenna loads per NESC criteria)

The structure shall be analyzed using yield stress theory in accordance with Attachment A, "NU Design Criteria." This specifies uniform loadings (different from the TIA loadings) on each of the following components of the installed facility:

- a) Wireless communication mast for its total height above ground level, including the initial and any planned future equipment (Support Platforms, Antennas, TMA's etc.) above the top of an electric transmission structure.
- b) Conductors and related devices and hardware (wire loads will be provided by NU).
- c) Electric Transmission Structure
 - i) The loads from the wireless communication equipment components based on NESC and NU Criteria in Attachment A, and from the electric conductors shall be applied to the structure at conductor and wireless communication mast attachment points, where those loads transfer to the tower.
 - ii) Shape Factor Multiplier:

NESC Structure Shape	Cd
Polyround (for polygonal steel poles)	1.3
Flat	1.6
Open Lattice	3.2

- iii) When Coaxial Cables are mounted along side the pole structure, the shape multiplier shall be:

Mount Type	Cable Cd	Pole Cd
Coaxial Cables on outside periphery (One layer)	1.45	1.45
Coaxial Cables mounted on stand offs	1.6	1.3

- d) The uniform loadings and factors specified for the above components in Attachment A, "NU Design Criteria" are based upon the National Electric Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to the TIA and its loads and factors with the exceptions noted above.

Note: The NESC does not require ice load be included in the supporting structure. (Ice on conductors and shield wire only, and NU will provide these loads).

- e) Mast reaction loads shall be evaluated for local effects on the transmission structure members at the attachment points.



Job :
Description:

Spec. Number
Computed by
Checked by

Page of
Sheet of
Date 9/29/09
Date

INPUT DATA

TOWER ID:

838

Structure Height (ft) :

95

Wind Zone : Central CT (green)

Wind Speed : 90.5711047 mph

Tower Type : Suspension
 Strain

Extreme Wind Model : PCS Addition

Shield Wire Properties:

	BACK	AHEAD
NAME =	OPGW-120	OPGW-120
DESCRIPTION =	6-Groove	6-Groove
STRANDING =	10/9 FOCAS	10/9 FOCAS
DIAMETER =	0.738 in	0.738 in
WEIGHT =	0.518 lb/ft	0.518 lb/ft

Conductor Properties:

		BACK	AHEAD		
Number of Conductors per phase	NAME =	LAPWING	LAPWING	1	Number of Conductors per phase
	1	1590.000	1590.000		
		45/7 ACSR	45/7 ACSR		
	DIAMETER =	1.504 in	1.504 in		
	WEIGHT =	1.790 lb/ft	1.790 lb/ft		

Insulator Weight =

0

 lbs

Broken Wire Side = AHEAD SPAN

Horizontal Line Tensions:

	BACK		AHEAD	
	Shield	Conductor	Shield	Conductor
NESC HEAVY =	6,000	11,400	6,000	11,400
EXTREME WIND =	6,016	12,178	6,016	12,178
LONG. WIND =	na	na	na	na
250D COMBINED =	na	na	na	na
NESC W/O OLF =	na	na	na	na
60 DEG F NO WIND =	2,045	5,625	2,045	5,625

Line Geometry:

				SUM
LINE ANGLE (deg) =	BACK:	8	AHEAD:	8
WIND SPAN (ft) =	BACK:	262	AHEAD:	262
WEIGHT SPAN (ft) =	BACK:	396	AHEAD:	396
				15
				524
				792



Job :

Description:

Spec. Number

Computed by

Checked by

Page of

Sheet of

Date 9/29/09

Date

WIRE LOADING AT ATTACHMENTS

TOWER ID:

838

Wind Span =

524 ft

 Weight Span =

792 ft

 Total Angle =

15 degrees

Broken Wire Span =

AHEAD SPAN

 Type of Insulator Attachment =

STRAIN

1. NESC RULE 250B Heavy Loading:

	INTACT CONDITION			BROKEN WIRE CONDITION		
	Horizontal	Longitudinal	Vertical	Horizontal	Longitudinal	Vertical
Shield Wire =	3,426 lb	0 lb	1,530 lb	1,713 lb	9,810 lb	765 lb
Conductor =	6,160 lb	0 lb	3,607 lb	3,080 lb	18,639 lb	1,803 lb

2. NESC RULE 250C Transverse Extreme Wind Loading:

	Horizontal	Longitudinal	Vertical
Shield Wire =	2,614 lb	0 lb	472 lb
Conductor =	5,302 lb	0 lb	1,630 lb

3. NESC RULE 250C Longitudinal Extreme Wind Loading:

	Horizontal	Longitudinal	Vertical
Shield Wire =	#VALUE!	#VALUE!	472 lb
Conductor =	#VALUE!	#VALUE!	1,630 lb

4. NESC RULE 250D Extreme Ice & Wind Loading:

	Horizontal	Longitudinal	Vertical
Shield Wire =	#VALUE!	#VALUE!	2,122 lb
Conductor =	#VALUE!	#VALUE!	3,884 lb

5. NESC RULE 250B w/o OLF's

	Horizontal	Longitudinal	Vertical
Shield Wire =	#VALUE!	#VALUE!	1,020 lb
Conductor =	#VALUE!	#VALUE!	2,405 lb

6. 60 Deg. F, No Wind

	Horizontal	Longitudinal	Vertical
Shield Wire =	551 lb	0 lb	410 lb
Conductor =	1,515 lb	0 lb	1,418 lb

7. Construction

	Horizontal	Longitudinal	Vertical
Shield Wire =	826 lb	0 lb	615 lb
Conductor =	2,273 lb	0 lb	2,127 lb

NOTE: All loads include required overload factors (OLF's).



Job :
Description:

Spec. Number
Computed by
Checked by

Page of
Sheet of
Date 9/29/09
Date

INPUT DATA

TOWER ID: 838

Structure Height (ft) : 95

Wind Zone : Central CT (green)

Wind Speed : 90.5711047 mph

Tower Type : Suspension
 Strain

Extreme Wind Model : PCS Addition

Shield Wire Properties:

	BACK	AHEAD
NAME =	3/8 AW	3/8 AW
DESCRIPTION =	3/8	3/8
STRANDING =	7 #8 Al Weld	7 #8 Al Weld
DIAMETER =	0.385 in	0.385 in
WEIGHT =	0.262 lb/ft	0.262 lb/ft

Conductor Properties:

		BACK	AHEAD		
NAME =		LAPWING	LAPWING		
Number of Conductors per phase	1	1590.000	1590.000	1	Number of Conductors per phase
		45/7 ACSR	45/7 ACSR		
DIAMETER =		1.504 in	1.504 in		
WEIGHT =		1.790 lb/ft	1.790 lb/ft		

Insulator Weight = 0 lbs

Broken Wire Side = AHEAD SPAN

Horizontal Line Tensions:

	BACK		AHEAD	
	Shield	Conductor	Shield	Conductor
NESC HEAVY =	4,200	11,400	4,200	11,400
EXTREME WIND =	3,440	12,178	3,440	12,178
LONG. WIND =	na	na	na	na
250D COMBINED =	na	na	na	na
NESC W/O OLF =	na	na	na	na
60 DEG F NO WIND =	1,234	5,625	1,234	5,625

Line Geometry:

					SUM
LINE ANGLE (deg) =	BACK:	8	AHEAD:	8	15
WIND SPAN (ft) =	BACK:	262	AHEAD:	262	524
WEIGHT SPAN (ft) =	BACK:	396	AHEAD:	396	792



Job :

Description:

Spec. Number

Computed by

Checked by

Page of

Sheet of

Date 9/29/09

Date

WIRE LOADING AT ATTACHMENTS

TOWER ID:

838

Wind Span =	524 ft
Weight Span =	792 ft
Total Angle =	15 degrees

Broken Wire Span =	AHEAD SPAN
Type of Insulator Attachment =	STRAIN

1. NESC RULE 250B Heavy Loading:

	INTACT CONDITION			BROKEN WIRE CONDITION		
	Horizontal	Longitudinal	Vertical	Horizontal	Longitudinal	Vertical
Shield Wire =	2,471 lb	0 lb	965 lb	1,236 lb	6,867 lb	482 lb
Conductor =	6,160 lb	0 lb	3,607 lb	3,080 lb	18,639 lb	1,803 lb

2. NESC RULE 250C Transverse Extreme Wind Loading:

	Horizontal	Longitudinal	Vertical
Shield Wire =	1,457 lb	0 lb	238 lb
Conductor =	5,302 lb	0 lb	1,630 lb

3. NESC RULE 250C Longitudinal Extreme Wind Loading:

	Horizontal	Longitudinal	Vertical
Shield Wire =	#VALUE!	#VALUE!	238 lb
Conductor =	#VALUE!	#VALUE!	1,630 lb

4. NESC RULE 250D Extreme Ice & Wind Loading:

	Horizontal	Longitudinal	Vertical
Shield Wire =	#VALUE!	#VALUE!	1,571 lb
Conductor =	#VALUE!	#VALUE!	3,884 lb

5. NESC RULE 250B w/o OLF's

	Horizontal	Longitudinal	Vertical
Shield Wire =	#VALUE!	#VALUE!	643 lb
Conductor =	#VALUE!	#VALUE!	2,405 lb


6. 60 Deg. F, No Wind

	Horizontal	Longitudinal	Vertical
Shield Wire =	332 lb	0 lb	207 lb
Conductor =	1,515 lb	0 lb	1,418 lb

7. Construction

	Horizontal	Longitudinal	Vertical
Shield Wire =	499 lb	0 lb	311 lb
Conductor =	2,273 lb	0 lb	2,127 lb

NOTE: All loads include required overload factors (OLF's).



1 TOWER & MAST ELEVATION
EL-1 SCALE: NOT TO SCALE

2 COAX PLAN
EL-1 SCALE: NOT TO SCALE

3 COAX PLAN
EL-1 SCALE: NOT TO SCALE

REVISIONS		
00	10/24/16	ISSUED FOR REVIEW

CEN TEK engineering
Centered on Solutions™
www.CentekEng.com

(203) 488-0580
(203) 488-8387 Fax
63-2 North Branford Road, Branford, CT 06405

CT11860A
EVERSOURCE 838

48 QUAIL TRAIL
TRUMBULL, CT 06611

PROJECT NO:	16159.04
DRAWN BY:	TJL
CHECKED BY:	CFC
SCALE:	AS NOTED
DATE:	10/19/16



TOWER AND MAST ELEVATION

EL-1

DWG. 1 OF 1

Development of Design Heights, Exposure Coefficients, and Velocity Pressures Per TIA-222-G

Wind Speeds

Basic Wind Speed $V := 97$ mph (User Input - 2016 CSBC Appendix N)
 Basic Wind Speed with Ice $V_i := 50$ mph (User Input per Annex B of TIA-222-G)

Input

Structure Type = Structure_Type := Pole (User Input)
 Structure Category = SC := III (User Input)
 Exposure Category = Exp := C (User Input)
 Structure Height = h := 95 ft (User Input)
 Height to Center of Antennas = $z_{AT\&T} := 105$ ft (User Input)
 Radial Ice Thickness = $I_r := 0.75$ in (User Input per Annex B of TIA-222-G)
 Radial Ice Density = $I_d := 56.00$ pcf (User Input)
 $K_a := 0.8$ (User Input)

Output

Wind Direction Probability Factor = $K_d := \begin{cases} 0.95 & \text{if Structure_Type} = \text{Pole} \\ 0.85 & \text{if Structure_Type} = \text{Lattice} \end{cases} = 0.95$ (Table 2-2 of TIA/EIA-222-G)

Importance Factor = $I := \begin{cases} 0.87 & \text{if SC} = 1 \\ 1.00 & \text{if SC} = 2 \\ 1.15 & \text{if SC} = 3 \end{cases} = 1.15$ (Table 2-3 of TIA/EIA-222-G)

Velocity Pressure Coefficient = $K_{z_{AT\&T}} := 2.01 \left(\left(\frac{z_{AT\&T}}{z_g} \right)^{\frac{2}{\alpha}} \right) = 1.279$

Velocity Pressure w/o Ice = $q_{z_{AT\&T}} := 0.00256 \cdot K_d \cdot K_{z_{AT\&T}} \cdot V^2 \cdot I = 33.649$

Velocity Pressure with Ice = $q_{ice,AT\&T} := 0.00256 \cdot K_d \cdot K_{z_{AT\&T}} \cdot V_i^2 \cdot I = 8.941$

Gust Response Factor = $G_H := 1.35$

Development of Wind & Ice Load on Mast

Mast Data:

	(Pipe 12" Sch. 40)	(User Input)
Mast Shape =	Round	(User Input)
Mast Diameter =	$D_{mast} := 12.75$ in	(User Input)
Mast Length =	$L_{mast} := 28.25$ ft	(User Input)
Mast Thickness =	$t_{mast} := 0.375$ in	(User Input)
Mast Aspect Ratio =	$A_{r_{mast}} := \frac{12L_{mast}}{D_{mast}} = 26.6$	
Mast Force Coefficient =	$C_{a_{mast}} = 1.2$	

Wind Load (without ice)

Mast Projected Surface Area = $A_{mast} := \frac{D_{mast}}{12} = 1.063$ sf/ft

Total Mast Wind Force = $q_{z_{AT\&T}} G_H C_{a_{mast}} A_{mast} = 58$ plf **BLC 5**

Wind Load (with ice)

Mast Projected Surface Area w/ Ice = $A_{ICE_{mast}} := \frac{(D_{mast} + 2 \cdot I_r)}{12} = 1.188$ sf/ft

Total Mast Wind Force w/ Ice = $q_{z_{ice,AT\&T}} G_H C_{a_{mast}} A_{ICE_{mast}} = 17$ plf **BLC 4**

Gravity Loads (without ice)

Weight of the mast = Self Weight (Computed internally by Risa-3D) plf **BLC 1**

Gravity Loads (ice only)

Ice Area per Linear Foot = $A_{i_{mast}} := \frac{\pi}{4} [(D_{mast} + I_r \cdot 2)^2 - D_{mast}^2] = 31.8$ sq in

Weight of Ice on Mast = $W_{ICE_{mast}} := I_d \cdot \frac{A_{i_{mast}}}{144} = 12$ plf **BLC 3**

Development of Wind & Ice Load on Antennas

Proposed Antenna Data:

Antenna Model =	Andrew SBNHH-1D65A	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 55.5$	in (User Input)
Antenna Width =	$W_{ant} := 11.9$	in (User Input)
Antenna Thickness =	$T_{ant} := 7.1$	in (User Input)
Antenna Weight =	$WT_{ant} := 34$	lbs (User Input)
Number of Antennas =	$N_{ant} := 3$	(User Input)
Antenna Aspect Ratio =	$Ar_{ant} := \frac{L_{ant}}{W_{ant}} = 4.7$	
Antenna Force Coefficient =	$Ca_{ant} = 1.3$	

Wind Load (without ice)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 4.6$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 13.8$	sf

Total Antenna Wind Force =

$F_{ant} := qZ_{AT\&T} \cdot G_H \cdot Ca_{ant} \cdot K_a \cdot A_{ant} = 648$ lbs **BLC 5**

Wind Load (with ice)

Surface Area for One Antenna w/ Ice =	$SA_{ICEant} := \frac{(L_{ant} + 2 \cdot Ir) \cdot (W_{ant} + 2 \cdot Ir)}{144} = 5.3$	sf
Antenna Projected Surface Area w/ Ice =	$A_{ICEant} := SA_{ICEant} \cdot N_{ant} = 15.9$	sf

Total Antenna Wind Force w/ Ice =

$F_{ant} := qZ_{ice} \cdot AT\&T \cdot G_H \cdot Ca_{ant} \cdot K_a \cdot A_{ICEant} = 199$ lbs **BLC 4**

Gravity Load (without ice)

Weight of All Antennas =

$WT_{ant} \cdot N_{ant} = 102$ lbs **BLC 2**

Gravity Loads (ice only)

Volume of Each Antenna =	$V_{ant} := L_{ant} \cdot W_{ant} \cdot T_{ant} = 4689$	cu in
Volume of Ice on Each Antenna =	$V_{ice} := (L_{ant} + 2 \cdot Ir) \cdot (W_{ant} + 2 \cdot Ir) \cdot (T_{ant} + 2 \cdot Ir) - V_{ant} = 1879$	cu in
Weight of Ice on Each Antenna =	$W_{ICEant} := \frac{V_{ice}}{1728} \cdot Id = 61$	lbs

Weight of Ice on All Antennas =

$W_{ICEant} \cdot N_{ant} = 183$ lbs **BLC 3**

Development of Wind & Ice Load on Antenna Mounts

Mount Data:

Mount Type: Valmort Standoff Ams

Mount Shape = Flat (User Input)

Mount Projected Surface Area = $CaAa := 5$ sf (User Input)

Mount Projected Surface Area w/ Ice = $CaAa_{ice} := 9$ sf (User Input)

Mount Weight = $WT_{mnt} := 150$ lbs (User Input)

Mount Weight w/ Ice = $WT_{mnt.ice} := 400$ lbs

Wind Load (without ice)

Total Mount Wind Force = $F_{mnt} := qz_{AT\&T} \cdot G_H \cdot CaAa = 227$ lbs **BLC 5**

Wind Load (with ice)

Total Mount Wind Force = $F_{mnt} := qz_{ice.AT\&T} \cdot G_H \cdot CaAa_{ice} = 109$ lbs **BLC 4**

Gravity Loads (without ice)

Weight of All Mounts = $WT_{mnt} = 150$ lbs **BLC 2**

Gravity Loads (ice only)

Weight of Ice on All Mounts = $WT_{mnt.ice} - WT_{mnt} = 250$ lbs **BLC 3**

Development of Wind & Ice Load on Coax Cables

Coax Cable Data:

Coax Type =	HELIAX 1-5/8"	
Shape =	Round	(User Input)
Coax Outside Diameter =	$D_{coax} := 1.98$	in (User Input)
Coax Cable Length =	$L_{coax} := 30$	ft (User Input)
Weight of Coax per foot =	$Wt_{coax} := 1.04$	plf (User Input)
Total Number of Coax =	$N_{coax} := 18$	(User Input)
No. of Coax Projecting Outside Face of Mast =	$NP_{coax} := 4$	(User Input)

Coax aspect ratio, $Ar_{coax} := \frac{(L_{coax} \cdot 12)}{D_{coax}} = 181.8$

Coax Cable Force Factor Coefficient = $Ca_{coax} = 1.2$

Wind Load (without ice)

Coax projected surface area = $A_{coax} := \frac{(NP_{coax} \cdot D_{coax})}{12} = 0.7$ sf/ft

Total Coax Wind Force = $F_{coax} := Ca_{coax} \cdot qz_{AT\&T} \cdot G_H \cdot A_{coax} = 36$ plf **BLC 5**

Wind Load (with ice)

Coax projected surface area w/ Ice = $AICE_{coax} := \frac{(NP_{coax} \cdot D_{coax} + 2 \cdot Ir)}{12} = 0.8$ sf/ft

Total Coax Wind Force w/ Ice = $F_{i_{coax}} := Ca_{coax} \cdot qz_{ice} \cdot AT\&T \cdot G_H \cdot AICE_{coax} = 11$ plf **BLC 4**

Gravity Loads (without ice)

Weight of all cables w/o ice $WT_{coax} := Wt_{coax} \cdot N_{coax} = 19$ plf **BLC 2**

Gravity Loads (ice only)

Ice Area per Linear Foot = $Ai_{coax} := \frac{\pi}{4} [(D_{coax} + 2 \cdot Ir)^2 - D_{coax}^2] = 6.4$ sq in

Ice Weight All Coax per foot = $WT_{i_{coax}} := N_{coax} \cdot Id \cdot \frac{Ai_{coax}}{144} = 45$ plf **BLC 3**

CEN TEK engineering, INC.
Consulting Engineers
63-2 North Branford Road
Branford, CT 06405

Subject: **Analysis of TIA-222G Wind and Ice Loads for Analysis of Mast Only**
Tabulated Load Cases
Location: **Trumbull, CT**

Ph. 203-488-0580 / Fax. 203-488-8587

Date: 10/18/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16159.04

Load Case	Description
1	Self Weight (Mast)
2	Weight of Appurtenances
3	Weight of Ice Only
4	TIA Wind with Ice
5	TIA Wind

Footnotes:

CENTEK engineering, INC.
Consulting Engineers
 63-2 North Branford Road
 Branford, CT 06405
 Ph. 203-488-0580 / Fax. 203-488-8587

Subject: **Analysis of TIA-222G Wind and Ice Loads for Analysis of Mast Only**
Load Combinations Table

Location: **Trumbull, CT**

Date: 10/18/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16159.04

Load Combination	Description	Envelope Wind													
		Soultion	Factor	P-Delta	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor	BLC
1	1.2D + 1.6W	1	1	Y	1	1.2	2	1.2	5	1.6					
2	0.9D + 1.6W	1	1	Y	1	0.9	2	0.9	5	1.6					
3	1.2D + 1.0Di + 1.0Wi	1	1	Y	1	1.2	2	1.2	3	1.0	4	1.0			

Footnotes:
 BLC = Basic Load Case
 D = Dead Load
 Di = Dead Load of Ice
 W = Wind Load
 Wi = Wind Load w/ Ice

Mast Top Connection:


Maximum Design Reactions at Brace:

Vertical =	Vert := 1.9-kips	(User Input)
Horizontal =	Horz := 6.2-kips	(User Input)
Moment =	Moment := 0	(User Input)

Bolt Data:

Bolt Grade =	A325	(User Input)
Number of Bolts =	$n_b := 6$	(User Input)
Bolt Diameter =	$d_b := 0.75\text{in}$	(User Input)
Design Tensile Stress =	$F_{t.all} := 67.5\text{-ksi}$	(User Input)
Design Shear Stress =	$F_{v.all} := 40.5\text{-ksi}$	(User Input)
Bolt Eccentricity from C.L. Mast =	$e := 21.125\text{-in}$	(User Input)
Vertical Spacing Between Top and Bottom Bolts =	$S_{vert} := 9\text{-in}$	(User Input)
Horizontal Spacing Between Bolts =	$S_{horz} := 20.5\text{-in}$	(User Input)

Bolt Area = $a_b := \frac{1}{4} \cdot \pi \cdot d_b^2 = 0.442\text{-in}^2$



Check Bolt Stresses:

Wind Acting Parallel to Stiffener Plate:

Shear Force per Bolt =

$$F_{v.conn} := \frac{Vert}{n_b} = 0.317 \cdot \text{kips}$$

Shear Stress per Bolt =

$$F_{v.act} := \frac{F_{v.conn}}{a_b} = 0.717 \cdot \text{ksi}$$

$$\text{Condition1} := \text{if}(F_{v.act} < F_{v.all}, \text{"OK"}, \text{"Overstressed"})$$

Condition1 = "OK"

Allowable Tensile Stress Adjusted for Shear =

$$F_{t.adj} := \sqrt{F_{t.all}^2 - 4.39 \cdot F_{v.act}^2} = 67.48 \cdot \text{ksi}$$

Moment From Mast Eccentricity =

$$M_{par} := Vert \cdot e = 40.1 \cdot \text{kips} \cdot \text{in}$$

Total Tension Force =

$$F_{tension} := Horz = 6.2 \cdot \text{kips}$$

Tension Force Each Bolt =

$$F_{tension.bolt} := \frac{F_{tension}}{n_b} + \frac{M_{par}}{S_{vert} \cdot 2} = 3.263 \cdot \text{kips}$$

Tension Stress Each Bolt =

$$F_{t.act} := \frac{F_{tension.bolt}}{a_b} = 7.4 \cdot \text{ksi}$$

$$\text{Condition2} := \text{if}(F_{t.act} < F_{t.adj}, \text{"OK"}, \text{"Overstressed"})$$

Condition2 = "OK"

Wind Acting Perpendicular to Stiffener Plate:

Shear Force per Bolt =

$$F_{v.conn} := \frac{\sqrt{Vert^2 + Horz^2}}{n_b} = 1.081 \cdot \text{kips}$$

Shear Stress per Bolt =

$$F_{v.act} := \frac{F_{v.conn}}{a_b} = 2.446 \cdot \text{ksi}$$

$$\text{Condition3} := \text{if}(F_{v.act} < F_{v.all}, \text{"OK"}, \text{"Overstressed"})$$

Condition3 = "OK"

Allowable Tensile Stress Adjusted for Shear =

$$F_{t.adj} := \sqrt{F_{t.all}^2 - 4.39 \cdot F_{v.act}^2} = 67.31 \cdot \text{ksi}$$

Moment from Mast Eccentricity =

$$M_{perp} := Horz \cdot e = 131 \cdot \text{kips} \cdot \text{in}$$

Tension Force per Bolt =

$$F_{tension.conn} := \frac{M_{perp}}{S_{horz} \cdot 3} + \frac{M_{par}}{S_{vert} \cdot 2} = 4.36 \cdot \text{kips}$$

Tension Stress Each Bolt =

$$F_{tension.act} := \frac{F_{tension.conn}}{a_b} = 9.868 \cdot \text{ksi}$$

$$\text{Condition4} := \text{if}(F_{tension.act} < F_{t.adj}, \text{"OK"}, \text{"Overstressed"})$$

Condition4 = "OK"

Mast Connection to Bottom Bracket:

Design Reactions at Brace:

Axial = Axial := 0.7·kips (User Input)
 Shear = Shear := 0.5·kips (User Input)
 Moment = Moment := 6.5·kips-ft (User Input)

Anchor Bolt Data:

Bolt Grade = A325 (User Input)
 Design Shear Stress = $F_V := 40.5\text{-ksi}$ (User Input)
 Design Tension Stress = $F_T := 67.5\text{-ksi}$ (User Input)
 Total Number of Bolts = $n_b := 4$ (User Input)
 Number of Bolts Tension Side Parallel = $n_{b.par} := 2$ (User Input)
 Number of Bolts Tension Side Diagonal = $n_{b.diag} := 1$ (User Input)
 Bolt Diameter = $d_b := 1\text{in}$ (User Input)
 Bolt Spacing X Direction = $S_x := 11\text{-in}$ (User Input)
 Bolt Spacing Z Direction = $S_z := 11\text{-in}$ (User Input)

Base Plate Data:

Base Plate Steel = A36 (User Input)
 Allowable Yield Stress = $F_y := 36\text{-ksi}$ (User Input)
 Base Plate Width = $Pl_w := 14.5\text{-in}$ (User Input)
 Base Plate Thickness = $Pl_t := 1\text{-in}$ (User Input)
 Bolt Edge Distance = $B_E := 1.75\text{-in}$ (User Input)
 Pole Diameter = $D_p := 12.75\text{-in}$ (User Input)

Base Plate Data:

Weld Grade = E70XX (User Input)
 Weld Yield Stress = $F_{yw} := 70\text{-ksi}$ (User Input)
 Weld Size = $sw := 0.3125\text{-in}$ (User Input)

Anchor Bolt Check:

Bolt Area =	$a_b := \frac{1}{4} \cdot \pi \cdot d_b^2 = 0.785 \cdot \text{in}^2$
Bolt Spacing Diag. Direction =	$S_{\text{diag}} := \sqrt{S_x^2 + S_z^2} = 15.56 \cdot \text{in}$
Tension Load per Bolt Parallel =	$T_{\text{par}} := \frac{\text{Moment}}{S_x \cdot n_b \cdot \text{par}} - \frac{\text{Axial}}{n_b} = 3.37 \cdot \text{kips}$
Tension Load per Bolt Diagonal =	$T_{\text{diag}} := \frac{\text{Moment}}{S_{\text{diag}} \cdot n_b \cdot \text{diag}} - \frac{\text{Axial}}{n_b} = 4.84 \cdot \text{kips}$
Actual Shear Stress =	$f_v := \frac{\text{Shear}}{a_b \cdot n_b} = 0.16 \cdot \text{ksi}$
	Condition1 := if($f_v < F_v$, "OK", "Overstressed")
	Condition1 = "OK"
Allowable Tensile Stress Adjusted for Shear =	$F_{t,\text{adj}} := \sqrt{F_T^2 - 4.39 \cdot f_v^2} = 67.499 \cdot \text{ksi}$
Tension per bolt =	$T := \text{if}(T_{\text{par}} > T_{\text{diag}}, T_{\text{par}}, T_{\text{diag}}) = 4.839 \cdot \text{kips}$
Actual Tensile Stress =	$f_t := \frac{T}{a_b} = 6.16 \cdot \text{ksi}$
	Condition2 := if($f_t < F_{t,\text{adj}}$, "OK", "Overstressed")
	Condition2 = "OK"

Base Plate Check:

Allowable Bending Stress =	$F_b := 0.9 \cdot F_y = 32.4 \cdot \text{ksi}$
Plate Bending Width =	$Z := (P l_w \cdot \sqrt{2} - D_p) = 7.76 \cdot \text{in}$
Moment Arm =	$K := \frac{(S_{\text{diag}} - D_p)}{2} = 1.4 \cdot \text{in}$
Moment in Base Plate =	$M := K \cdot T = 6.79 \cdot \text{kips} \cdot \text{in}$
Section Modulus =	$S_Z := \frac{1}{6} \cdot Z \cdot P l_t^2 = 1.29 \cdot \text{in}^3$
Bending Stress =	$f_b := \frac{M}{S_Z} = 5.25 \cdot \text{ksi}$
	Condition3 := if($f_b < F_b$, "OK", "Overstressed")
	Condition3 = "OK"

Subject:

Mast Connection to Bottom Bracket

Location:

Trumbull, CT

Rev. 0: 10/24/16

Prepared by: T.J.L. Checked by: C.F.C.
 Job No. 16159.04

Base Plate to Mast Weld Check:

Allowable Weld Stress =

$$F_W := 0.45 \cdot F_{yW} = 31.5 \text{ ksi}$$

$$c := \frac{D_p}{2} + sw \cdot 0.707 = 6.6 \text{ in}$$

Weld Moment of Inertia =

$$I_W := \frac{\pi}{64} \cdot \left[(D_p + 2sw \cdot 0.707)^4 - D_p^4 \right] = 189.4 \text{ in}^4$$

Section Modulus of Weld =

$$S_W := \frac{I_W}{c} = 28.71 \text{ in}^3$$

Weld Stress =

$$f_W := \frac{\text{Moment}}{S_W} = 2.72 \text{ ksi}$$

$$\text{Condition4} := \text{if}(f_W < F_W, \text{"OK"}, \text{"Overstressed"})$$

Condition4 = "OK"

Mast Bottom Connection:

Maximum Design Reactions at Brace:

Vertical =	Vert := 0.7-kips	(User Input)
Horizontal =	Horz := 0.5-kips	(User Input)
Moment =	Moment := 6.5-ft-kips	(User Input)


Bolt Data:

Bolt Grade =	A325	(User Input)
Number of Bolts =	$n_b := 16$	(User Input)
Bolt Diameter =	$d_b := 0.75\text{in}$	(User Input)
Design Tensile Stress =	$F_{t.all} := 67.5\text{-ksi}$	(User Input)
Design Shear Stress =	$F_{v.all} := 40.5\text{-ksi}$	(User Input)
Bolt Eccentricity from C.L. Mast =	$e := 21.125\text{-in}$	(User Input)
Vertical Spacing Between Top and Bottom Bolts =	$S_{vert} := 21\text{-in}$	(User Input)
Horizontal Spacing Between Bolts =	$S_{horz} := 27.25\text{-in}$	(User Input)

Bolt Area = $a_b := \frac{1}{4} \cdot \pi \cdot d_b^2 = 0.442\text{-in}^2$

Wind Parallel →

↑
Wind Perpendicular



Check Bolt Stresses:

Wind Acting Parallel to Stiffener Plate:

Shear Force per Bolt =

$$F_{v.conn} := \frac{Vert}{n_b} = 0.044 \cdot \text{kips}$$

Shear Stress per Bolt =

$$F_{v.act} := \frac{F_{v.conn}}{a_b} = 0.099 \cdot \text{ksi}$$

$$\text{Condition1} := \text{if}(F_{v.act} < F_{v.all}, \text{"OK"}, \text{"Overstressed"})$$

Condition1 = "OK"

Allowable Tensile Stress Adjusted for Shear =

$$F_{t.adj} := \sqrt{F_{t.all}^2 - 4.39 \cdot F_{v.act}^2} = 67.5 \cdot \text{ksi} \quad (\text{AISC 9th Ed. Table J3.3})$$

Moment From Mast Eccentricity =

$$M_{par} := \text{Vert} \cdot e + \text{Moment} = 92.8 \cdot \text{kips} \cdot \text{in}$$

Total Tension Force =

$$F_{tension} := \text{Horz} = 0.5 \cdot \text{kips}$$

Tension Force Each Bolt =

$$F_{tension.bolt} := \frac{F_{tension}}{n_b} + \frac{M_{par}}{S_{vert} \cdot 2} = 2.24 \cdot \text{kips}$$

Tension Stress Each Bolt =

$$F_{t.act} := \frac{F_{tension.bolt}}{a_b} = 5.1 \cdot \text{ksi}$$

$$\text{Condition2} := \text{if}(F_{t.act} < F_{t.adj}, \text{"OK"}, \text{"Overstressed"})$$

Condition2 = "OK"

Wind Acting Perpendicular to Stiffener Plate:

Shear Force per Bolt =

$$F_{v.conn} := \frac{\sqrt{\left(\text{Vert} + \frac{\text{Moment} \cdot 2}{S_{horz} \cdot n_b} \right)^2 + \text{Horz}^2}}{n_b} = 0.073 \cdot \text{kips}$$

Shear Stress per Bolt =

$$F_{v.act} := \frac{F_{v.conn}}{a_b} = 0.166 \cdot \text{ksi}$$

$$\text{Condition3} := \text{if}(F_{v.act} < F_{v.all}, \text{"OK"}, \text{"Overstressed"})$$

Condition3 = "OK"

Allowable Tensile Stress Adjusted for Shear =

$$F_{t.adj} := \sqrt{F_{t.all}^2 - 4.39 \cdot F_{v.act}^2} = 67.5 \cdot \text{ksi} \quad (\text{AISC 9th Ed. Table J3.3})$$

Moment from Mast Eccentricity =

$$M_{perp} := \text{Horz} \cdot e = 11 \cdot \text{kips} \cdot \text{in}$$

Tension Force per Bolt =

$$F_{tension.conn} := \frac{M_{perp} \cdot 2}{S_{horz} \cdot n_b} + \frac{M_{par}}{S_{vert} \cdot 2} = 2.258 \cdot \text{kips}$$

Tension Stress Each Bolt =

$$F_{tension.act} := \frac{F_{tension.conn}}{a_b} = 5.11 \cdot \text{ksi}$$

$$\text{Condition4} := \text{if}(F_{tension.act} < F_{t.adj}, \text{"OK"}, \text{"Overstressed"})$$

Condition4 = "OK"

Basic Components

Heavy Wind Pressure =	p := 4.00	psf	(User Input NESC 2007 Figure 250-1 & Table 250-1)
Basic Windspeed =	V := 110	mph	(User Input NESC 2007 Figure 250-2(e))
Radial Ice Thickness =	Ir := 0.50	in	(User Input)
Radial Ice Density =	Id := 56.0	pcf	(User Input)

Factors for Extreme Wind Calculation

Elevation of Top of PCS Mast Above Grade =	TME := 105	ft	(User Input)
Multiplier Gust Response Factor =	m := 1.25		(User Input - Only for NESC Extreme wind case)
NESC Factor =	kv := 1.43		(User Input from NESC 2007 Table 250-3 equation)
Importance Factor =	I := 1.0		(User Input from NESC 2007 Section 250.C.2)

Velocity Pressure Coefficient = $Kz := 2.01 \cdot \left(\frac{TME}{900} \right)^{\frac{2}{9.5}} = 1.279$ (NESC 2007 Table 250-2)

Exposure Factor = $Es := 0.346 \left[\frac{33}{(0.67 \cdot TME)} \right]^{\frac{1}{7}} = 0.311$ (NESC 2007 Table 250-3)

Response Term = $Bs := \frac{1}{\left(1 + 0.375 \cdot \frac{TME}{220} \right)} = 0.848$ (NESC 2007 Table 250-3)

Gust Response Factor = $Grf := \frac{\left[1 + \left(2.7 \cdot Es \cdot Bs \cdot \frac{1}{2} \right) \right]}{kv^2} = 0.867$ (NESC 2007 Table 250-3)

Wind Pressure = $qz := 0.00256 \cdot Kz \cdot V^2 \cdot Grf \cdot I = 34.3$ psf (NESC 2007 Section 250.C.2)

Shape Factors

Shape Factor for Round Members =	Cd _R := 1.3	(User Input)
Shape Factor for Flat Members =	Cd _F := 1.6	(User Input)
Shape Factor for Coax Cables Attached to Outside of P de =	Cd _{coax} := 1.45	(User Input)

NUS Design Criteria Issued April 12, 2007

Overload Factors

NU Design Criteria Table

Overload Factors for Wind Loads:

NESC Heavy Loading =	2.5	(User Input)	Apply in Risa-3D Analysis
NESC Extreme Loading =	1.0	(User Input)	Apply in Risa-3D Analysis

Overload Factors for Vertical Loads:

NESC Heavy Loading =	1.5	(User Input)	Apply in Risa-3D Analysis
NESC Extreme Loading =	1.0	(User Input)	Apply in Risa-3D Analysis

Development of Wind & Ice Load on PCS Mast

Mast Data:

(Pipe 12" Sch. 40)

Mast Shape =	Round	(User Input)
Mast Diameter =	$D_{mast} := 12.75$ in	(User Input)
Mast Length =	$L_{mast} := 28.25$ ft	(User Input)
Mast Thickness =	$t_{mast} := 0.375$ in	(User Input)

Wind Load (NESE Extreme)

Mast Projected Surface Area = $A_{mast} := \frac{D_{mast}}{12} = 1.063$ sf/ft

Total Mast Wind Force (Below NU Structure) = $qz \cdot C_d R \cdot A_{mast} = 59$ plf **BLC 5**

Wind Load (NESE Heavy)

Mast Projected Surface Area w/ Ice = $A_{ICE_{mast}} := \frac{(D_{mast} + 2 \cdot I_r)}{12} = 1.146$ sf/ft

Total Mast Wind Force w/ Ice = $p \cdot C_d R \cdot A_{ICE_{mast}} = 6$ plf **BLC 4**

Gravity Loads (without ice)

Weight of the mast = Self Weight (Computed internally by Risa-3D) plf **BLC 1**

Gravity Loads (ice only)

Ice Area per Linear Foot = $A_{i_{mast}} := \frac{\pi}{4} [(D_{mast} + I_r \cdot 2)^2 - D_{mast}^2] = 20.8$ sq in

Weight of Ice on Mast = $W_{ICE_{mast}} := I_d \cdot \frac{A_{i_{mast}}}{144} = 8$ plf **BLC 3**

Development of Wind & Ice Load on Antennas

Proposed Antenna Data:

Antenna Model =	SBNHH-1D65A	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 55.5$	in (User Input)
Antenna Width =	$W_{ant} := 11.9$	in (User Input)
Antenna Thickness =	$T_{ant} := 7.1$	in (User Input)
Antenna Weight =	$WT_{ant} := 34$	lbs (User Input)
Number of Antennas =	$N_{ant} := 3$	(User Input)

Wind Load (NESC Extreme)

Assumes Maximum Possible Wind Pressure Applied to all Antennas Simultaneously

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 4.6$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 13.8$	sf

Total Antenna Wind Force = $F_{ant} := qz \cdot C_d \cdot A_{ant} = 945$ lbs **BLC 5**

Wind Load (NESC Heavy)

Assumes Maximum Possible Wind Pressure Applied to all Antennas Simultaneously

Surface Area for One Antenna w/ Ice =	$SA_{ICEant} := \frac{(L_{ant} + 1) \cdot (W_{ant} + 1)}{144} = 5.1$	sf
Antenna Projected Surface Area w/ Ice =	$A_{ICEant} := SA_{ICEant} \cdot N_{ant} = 15.2$	sf

Total Antenna Wind Force w/ Ice = $F_{i_{ant}} := p \cdot C_d \cdot A_{ICEant} = 97$ lbs **BLC 4**

Gravity Load (without ice)

Weight of All Antennas = $WT_{ant} \cdot N_{ant} = 102$ lbs **BLC 2**

Gravity Load (ice only)

Volume of Each Antenna =	$V_{ant} := L_{ant} \cdot W_{ant} \cdot T_{ant} = 4689$	cu in
Volume of Ice on Each Antenna =	$V_{ice} := (L_{ant} + 1) \cdot (W_{ant} + 1) \cdot (T_{ant} + 1) - V_{ant} = 1214$	cu in
Weight of Ice on Each Antenna =	$W_{ICEant} := \frac{V_{ice}}{1728} \cdot \rho = 39$	lbs

Weight of Ice on All Antennas = $W_{ICEant} \cdot N_{ant} = 118$ lbs **BLC 3**

Development of Wind & Ice Load on Antenna Mounts

Mount Data:

Mount Type:	Valmort Standoff A ms
Mount Shape =	Flat (User Input)
Mount Projected Surface Area =	CdAa := 5 sf (User Input)
Mount Projected Surface Area w/ Ice =	CdAa _{ice} := 9 sf (User Input)
Mount Weight =	WT _{mnt} := 150 lbs (User Input)
Mount Weight w/ Ice =	WT _{mnt.ice} := 400 lbs

Wind Load (NESC Extreme)

Total Mount Wind Force = $F_{mnt} := qz \cdot CdAa \cdot m = 215$ lbs **BLC 5,7**

Wind Load (NESC Heavy)

Total Mount Wind Force w/ Ice = $F_{i,mnt} := p \cdot CdAa_{ice} = 36$ lbs **BLC 4,6**

Gravity Loads (without ice)

(per TIA/EIA-222-F-1996)

Weight of All Mounts = $WT_{mnt} = 150$ lbs **BLC 2**

Gravity Load (ice only)

(per TIA/EIA-222-F-1996)

Weight of Ice on All Mounts = $WT_{mnt.ice} - WT_{mnt} = 250$ lbs **BLC 3**

Development of Wind & Ice Load on Coax Cables

Coax Cable Data:

Coax Type =	HELIAX 1-5/8"	
Shape =	Round	(User Input)
Coax Outside Diameter =	$D_{coax} := 1.98$	in (User Input)
Coax Cable Length =	$L_{coax} := 30$	ft (User Input)
Weight of Coax per foot =	$Wt_{coax} := 1.04$	plf (User Input)
Total Number of Coax =	$N_{coax} := 18$	(User Input)
No. of Coax Projecting Outside Face of PCS Mast =	$NP_{coax} := 4$	(User Input)

Wind Load (NESC Extreme)

Coax projected surface area = $A_{coax} := \frac{(NP_{coax} D_{coax})}{12} = 0.7$ sf/ft

Total Coax Wind Force (Above NU Structure) = $F_{coax} := qz \cdot Cd_{coax} \cdot A_{coax} \cdot m = 41$ plf **BLC 5**

Wind Load (NESC Heavy)

Coax projected surface area w/ Ice = $A_{ICE_{coax}} := \frac{(NP_{coax} D_{coax} + 2 \cdot lr)}{12} = 0.7$ sf/ft

Total Coax Wind Force w/ Ice = $F_{i_{coax}} := p \cdot Cd_{coax} \cdot A_{ICE_{coax}} = 4$ plf **BLC 4**

Gravity Loads (without ice)

Weight of all cables w/o ice $WT_{coax} := Wt_{coax} \cdot N_{coax} = 19$ plf **BLC 2**

Gravity Load (ice only)

Ice Area per Linear Foot = $A_{i_{coax}} := \frac{\pi}{4} [(D_{coax} + 2 \cdot lr)^2 - D_{coax}^2] = 3.9$ sq in

Ice Weight All Coax per foot = $WT_{i_{coax}} := N_{coax} \cdot ld \cdot \frac{A_{i_{coax}}}{144} = 27$ plf **BLC 3**

CEN TEK engineering, INC.
Consulting Engineers
63-2 North Branford Road
Branford, CT 06405

Subject: **Analysis of NESC Heavy Wind and NESC Extreme Wind
for Obtaining Reactions Applied to Utility Pole
Tabulated Load Cases**
Location: **Trumbull, CT**

Ph. 203-488-0580 / Fax. 203-488-8587

Date: 10/18/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16159.04

Load Case	Description
1	Self Weight (Mast)
2	Weight of Appurtenances
3	Weight of Ice Only
4	NESC Heavy Wind
5	NESC Extreme Wind

Footnotes:

CENTEK engineering, INC.
Consulting Engineers
 63-2 North Branford Road
 Branford, CT 06405
 Ph. 203-488-0580 / Fax. 203-488-8587

Subject: **Analysis of NESC Heavy Wind and NESC Extreme Wind
 for Obtaining Reactions Applied to Utility Pole
 Load Combinations Table**

Location: **Trumbull, CT**

Date: 10/18/16

Prepared by: T.J.L.

Checked by: C.F.C.

Job No. 16159.04

Load Combination	Description	Envelope Soultion	Wind Factor	P-Delta	BLC Factor	BLC Factor	BLC Factor	BLC Factor	BLC Factor	BLC Factor	BLC Factor	
1	NESC Heavy Wind		1		1	1.5	2	1.5	3	1.5	4	2.5
2	NESC Extreme Wind		1		1	1	2	1	5	1		

Footnotes:
 (1) BLC = Basic Load Case

Coax Cable on Pole

Distance Between Coax Cable Attach Points =

Coaxial Cable Span =

$$\text{CoaxSpan} := \begin{pmatrix} 10 \\ 10 \\ 10 \\ 10 \\ 10 \\ 10 \\ 10 \\ 10 \end{pmatrix} \cdot \text{ft} \quad (\text{User Input})$$

Diameter of Coax Cable =

$$D_{\text{coax}} := 1.98 \cdot \text{in} \quad (\text{User Input})$$

Weight of Coax Cable =

$$W_{\text{coax}} := 1.04 \cdot \text{plf} \quad (\text{User Input})$$

Number of Coax Cables =

$$N_{\text{coax}} := 18 \quad (\text{User Input})$$

Number of Projected Coax Cables =

$$NP_{\text{coax}} := 3 \quad (\text{User Input})$$

Extreme Wind Pressure =

$$qz := 34.3 \cdot \text{psf} \quad (\text{User Input})$$

Heavy Wind Pressure =

$$p := 4 \cdot \text{psf} \quad (\text{User Input})$$

Radial Ice Thickness =

$$I_r := 0.5 \cdot \text{in} \quad (\text{User Input})$$

Radial Ice Density =

$$I_d := 56 \cdot \text{pcf} \quad (\text{User Input})$$

Shape Factor =

$$C_{d_{\text{coax}}} := 1.6 \quad (\text{User Input})$$

Overload Factor for NESC Heavy Wind Load =

$$OF_{\text{HW}} := 2.5 \quad (\text{User Input})$$

Overload Factor for NESC Extreme Wind Load =

$$OF_{\text{EW}} := 1.0 \quad (\text{User Input})$$

Overload Factor for NESC Heavy Vertical Load =

$$OF_{\text{HV}} := 1.5 \quad (\text{User Input})$$

Overload Factor for NESC Extreme Vertical Load =

$$OF_{\text{EV}} := 1.0 \quad (\text{User Input})$$

Wind Area with Ice =

$$A_{\text{ice}} := (NP_{\text{coax}} \cdot D_{\text{coax}} + 2 \cdot I_r) = 6.94 \cdot \text{in}$$

Wind Area without Ice =

$$A := (NP_{\text{coax}} \cdot D_{\text{coax}}) = 5.94 \cdot \text{in}$$

Ice Area per Linear Ft =

$$A_{i_{\text{coax}}} := \frac{\pi}{4} \cdot \left[(D_{\text{coax}} + 2 \cdot I_r)^2 - D_{\text{coax}}^2 \right] = 0.027 \cdot \text{ft}^2$$

Weight of Ice on All Coax Cables =

$$W_{\text{ice}} := A_{i_{\text{coax}}} \cdot I_d \cdot N_{\text{coax}} = 27.269 \cdot \text{plf}$$

Heavy Vertical Load =

$$\text{Heavy}_{\text{Vert}} := \overrightarrow{\left[(N_{\text{coax}} \cdot W_{\text{coax}} + W_{\text{ice}}) \cdot \text{CoaxSpan} \cdot \text{OFHV} \right]}$$

Heavy Transverse Load =

$$\text{Heavy}_{\text{Trans}} := \overrightarrow{\left(p \cdot A_{\text{ice}} \cdot C_{d_{\text{coax}}} \cdot \text{CoaxSpan} \cdot \text{OFHW} \right)}$$

$$\text{Heavy}_{\text{Vert}} = \begin{pmatrix} 690 \\ 690 \\ 690 \\ 690 \\ 690 \\ 690 \\ 690 \\ 690 \end{pmatrix} \text{ lb}$$

$$\text{Heavy}_{\text{Trans}} = \begin{pmatrix} 93 \\ 93 \\ 93 \\ 93 \\ 93 \\ 93 \\ 93 \\ 93 \end{pmatrix} \text{ lb}$$

Extreme Vertical Load =


$$\text{Extreme}_{\text{Vert}} := \overrightarrow{\left[(N_{\text{coax}} \cdot W_{\text{coax}}) \cdot \text{CoaxSpan} \cdot \text{OFEV} \right]}$$

Extreme Transverse Load =

$$\text{Extreme}_{\text{Trans}} := \overrightarrow{\left[(qz \cdot A \cdot C_{d_{\text{coax}}}) \cdot \text{CoaxSpan} \cdot \text{OFEW} \right]}$$

$$\text{Extreme}_{\text{Vert}} = \begin{pmatrix} 187 \\ 187 \\ 187 \\ 187 \\ 187 \\ 187 \\ 187 \\ 187 \end{pmatrix} \text{ lb}$$

$$\text{Extreme}_{\text{Trans}} = \begin{pmatrix} 272 \\ 272 \\ 272 \\ 272 \\ 272 \\ 272 \\ 272 \\ 272 \end{pmatrix} \text{ lb}$$



Anchor Bolt Analysis:

Input Data:

Bolt Force:

Maximum Tensile Force = $T_{Max} := 143\text{-kips}$ (User Input from PLS-Pole)

Anchor Bolt Data:

Use ASTM A615 Grade 75

Number of Anchor Bolts = $N := 20$ (User Input)

Bolt "Column" Distance = $l := 3.0\text{-in}$ (User Input)

Bolt Ultimate Strength = $F_u := 100\text{-ksi}$ (User Input)

Bolt Yield Strength = $F_y := 75\text{-ksi}$ (User Input)

Bolt Modulus = $E := 29000\text{-ksi}$ (User Input)

Diameter of Anchor Bolts = $D := 2.25\text{-in}$ (User Input)

Threads per Inch = $n := 4.5$ (User Input)

Anchor Bolt Analysis:

Calculated Anchor Bolt Properties:

Net Area of Bolt =
$$A_n := \frac{\pi}{4} \cdot \left(D - \frac{0.9743\text{-in}}{n} \right)^2 = 3.248\text{-in}^2$$

Bolt Tension Check:

Allowable Tensile Force (Net Area) = $T_{ALL.Net} := 1.0 \cdot (A_n \cdot F_y) = 243.576\text{-kips}$

Bolt Tension % of Capacity = $\frac{T_{Max}}{T_{ALL.Net}} = 58.71\%$

Condition1 =
$$\text{Condition1} := \text{if} \left(\frac{T_{Max}}{T_{ALL.Net}} \leq 1.00, \text{"OK"}, \text{"Overstressed"} \right)$$

Condition1 = "OK"

Foundation:

Input Data:

Tower Data

Overturing Moment = OM := 4039.1.1-ft-kips = 4443-ft-kips (User Input from PLS-Pole)
 Shear Force = Shear := 52-kip·1.1 = 57.2-kips (User Input from PLS-Pole)
 Axial Force = Axial := 58-kip·1.1 = 63.8-kips (User Input from PLS-Pole)
 Tower Height = $H_t := 95$ -ft (User Input)

Footing Data:

Depth to Bottom of Footing = $D_f := 13.5$ -ft (User Input)
 Length of Pier = $L_p := 14$ -ft (User Input)
 Extension of Pier Above Grade = $L_{pag} := 0.5$ -ft (User Input)
 Width of Pier = $W_p := 10$ -ft (User Input)
 Depth of Soil = $D_{soil} := 13.5$ -ft (User Input)
 Depth of Rock = $D_{rock} := 18$ -ft (User Input)


Material Properties:


Concrete Compressive Strength = $f_c := 3500$ -psi (User Input)
 Steel Reinforcement Yield Strength = $f_y := 60000$ -psi (User Input)
 Anchor Bolt Yield Strength = $f_{ya} := 75000$ -psi (User Input)
 Internal Friction Angle of Soil = $\Phi_s := 30$ -deg (User Input)
 Allowable Soil Bearing Capacity = $q_s := 4000$ -psf (User Input)
 Allowable Rock Bearing Capacity = $q_{rock} := 50000$ -psf (User Input)
 Unit Weight of Soil = $\gamma_{soil} := 120$ -pcf (User Input)
 Unit Weight of Concrete = $\gamma_{conc} := 150$ -pcf (User Input)
 Unit Weight of Rock = $\gamma_{rock} := 160$ -pcf (User Input)
 Foundation Bouyancy = Bouyancy := 0 (User Input) (Yes=1 / No=0)
 Depth to Neglect = $n := 1.0$ -ft (User Input)
 Cohesion of Clay Type Soil = $c := 0$ -ksf (User Input) (Use 0 for Sandy Soil)
 Seismic Zone Factor = $Z := 2$ (User Input) (UBC-1997 Fig 23-2)
 Coefficient of Friction Between Concrete = $\mu := 0.45$ (User Input)

Rock Anchor Properties:

ASTM A615 Grade 60

Bolt Ultimate Strength =	$F_u := 90\text{-ksi}$	(User Input)	
Bolt Yield Strength =	$F_y := 60\text{-ksi}$	(User Input)	
Anchor Diameter =	$d_{ra} := 3.81\text{-in}$	(User Input)	(3 # 10 Bars)
Hole Diameter =	$d_{Hole} := 4\text{-in}$	(User Input)	
Grout Strength =	$\tau := 120\text{-psi}$	(User Input)	(Assumed Conservative Value)
Distance to Rock Anchor Group 1 =	$D_{a1} := 24\text{-in}$	(User Input)	
Distance to Rock Anchor Group 2 =	$D_{a2} := 48\text{-in}$	(User Input)	
Number of Rock Anchors in Group 1 =	$N_{a1} := 4$	(User Input)	
Number of Rock Anchors in Group 2 =	$N_{a2} := 10$	(User Input)	
Total Number of Rock Anchors =	$N_{atot} := 16$	(User Input)	





Area 1 =	$A1_s := \frac{1}{2} \cdot \tan(\Phi_s) \cdot D_{soil}^2 = 52.611 \text{ft}^2$	sf
Area 2 =	$A2_s := \tan(\Phi_s) \cdot D_{rock} \cdot D_{soil} = 140.296 \text{ft}^2$	sf
Distance to Centroid 1 =	$Y1 := \tan(\Phi_s) \cdot D_{rock} + \frac{1}{3} \cdot \tan(\Phi_s) \cdot D_{soil} = 12.99 \text{ft}$	ft
Distance to Centroid 2 =	$Y2 := \frac{1}{2} \cdot \tan(\Phi_s) \cdot D_{rock} = 5.196 \text{ft}$	ft
Distance from Toe to Centroid of Soil =	$Y_{soil} := \frac{(A1_s \cdot Y1 + A2_s \cdot Y2)}{(A1_s + A2_s)} + W_p = 17.32 \text{ft}$	ft
Area 1 =	$A1_r := \frac{1}{2} \cdot \tan(\Phi_s) \cdot D_{rock}^2 = 93.531 \text{ft}^2$	sf
Area 2 =	$A2_r := W_p \cdot D_{rock} = 180 \text{ft}^2$	sf
Distance to Centroid 1 =	$Y1 := W_p + \frac{1}{3} \cdot \tan(\Phi_s) \cdot D_{rock} = 13.464 \text{ft}$	ft
Distance to Centroid 2 =	$Y2 := \frac{W_p}{2} = 5 \text{ft}$	ft
Distance from Toe to Centroid of Rock =	$Y_{rock} := \frac{(A1_r \cdot Y1 + A2_r \cdot Y2)}{(A1_r + A2_r)} = 7.89 \text{ft}$	ft

Stability of Footing:

Adjusted Concrete Unit Weight = $\gamma_c := \text{if}(\text{Bouyancy} = 1, \gamma_{\text{conc}} - 62.4\text{pcf}, \gamma_{\text{conc}}) = 150\text{-pcf}$

Adjusted Soil Unit Weight = $\gamma_s := \text{if}(\text{Bouyancy} = 1, \gamma_{\text{soil}} - 62.4\text{pcf}, \gamma_{\text{soil}}) = 120\text{-pcf}$

Coefficient of Lateral Soil Pressure = $K_p := \frac{1 + \sin(\Phi_s)}{1 - \sin(\Phi_s)} = 3$

Passive Pressure = $P_{\text{top}} := 0 = 0\text{-ksf}$

$P_{\text{bot}} := K_p \cdot \gamma_s \cdot D_{\text{soil}} + c \cdot 2 \cdot \sqrt{K_p} = 4.86\text{-ksf}$

$P_{\text{ave}} := \frac{P_{\text{top}} + P_{\text{bot}}}{2} = 2.43\text{-ksf}$

$A_p := W_p \cdot (L_p - L_{\text{pag}}) = 135\text{ft}^2$

Ultimate Shear = $S_u := P_{\text{ave}} \cdot A_p = 328.05\text{-kip}$

Weight of Concrete Pad = $WT_c := (W_p^2 \cdot L_p) \cdot \gamma_c = 210\text{-kip}$

Total Weight of Soil = $WT_{\text{Stot}} := (A1_s + A2_s) \cdot W_p \cdot \gamma_s = 231.5\text{-kips}$

Total Weight of Rock = $WT_{\text{Rtot}} := (A1_r + A2_r) \cdot W_p \cdot \gamma_{\text{rock}} = 437.6\text{-kips}$

Resisting Moment = $M_r := (WT_c + \text{Axial}) \cdot \frac{W_p}{2} + S_u \cdot \frac{(L_p - L_{\text{pag}})}{3} + WT_{\text{Stot}} \cdot Y_{\text{soil}} + WT_{\text{Rtot}} \cdot Y_{\text{rock}} = 10310\text{-kip-ft}$

Overturing Moment = $M_{\text{ot}} := \text{OM} + \text{Shear} \cdot L_p = 5244\text{-kip-ft}$

Factor of Safety Actual = $FS := \frac{M_r}{M_{\text{ot}}} = 1.97$

Factor of Safety Required = $FS_{\text{req}} := 1.0$

OverTurning_Moment_Check := $\text{if}(FS \geq FS_{\text{req}}, \text{"Okay"}, \text{"No Good"})$

OverTurning_Moment_Check = "Okay"

Rock Anchor Check:

Polar Moment of Inertia = $I_p := (D_{a1}^2 \cdot N_{a1} + D_{a2}^2 \cdot N_{a2}) = 25344 \cdot \text{in}^2$

$$T_2 := \frac{M_{ot} \cdot D_{a2}}{I_p} = 119.2 \cdot \text{kips}$$

$$T_1 := \frac{M_{ot} \cdot D_{a1}}{I_p} = 59.6 \cdot \text{kips}$$

Maximum Tension Force = $T_{Max} := \max(T_2, T_1) = 119.2 \cdot \text{kips}$

Gross Area of Bolt = $A_g := \frac{\pi}{4} \cdot d_{ra}^2 = 11.401 \cdot \text{in}^2$

Allowable Tension = $T_{all} := 0.75 \cdot A_g \cdot F_u = 769.6 \cdot \text{kips}$

$$\frac{T_{Max}}{T_{all}} = 15.5\%$$

Condition1 := if($T_{Max} < T_{all}$, "OK", "NG")

Condition1 = "OK"

Check Bond Strength:

Bond Strength = $\text{Bond_Strength} := d_{Hole} \cdot \pi \cdot D_{rock} \cdot \tau = 326 \cdot \text{kips}$

$$\frac{T_{Max}}{\text{Bond_Strength}} = 36.6\%$$

Condition2 := if($T_{Max} < \text{Bond_Strength}$, "OK", "NG")

Condition2 = "OK"

Bearing Pressure Caused by Footing:

Area of the Mat = $A_{mat} := \frac{\left(W_p \cdot \frac{W_p}{2} \right)}{2} = 25 \text{ft}^2$

Maximum Pressure in Mat = $P_{max} := \frac{W T_c + \text{Axial} + T_1 \cdot \frac{N_{a1}}{2} + T_2 \cdot \frac{N_{a2}}{2}}{A_{mat}} = 39.554 \cdot \text{ksf}$

Max_Pressure_Check := if($P_{max} < q_{rock}$, "Okay", "No Good")

Max_Pressure_Check = "Okay"

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

CT11860A_1.1_L700

Section 1 - Site Information

Site ID: CT11860A	Site Name: CT860/CL&P Trumbull	Latitude: 41.23250000
Status: Draft	Site Class: Monopole	Longitude: -73.17220000
Version: 1.1	Site Type: Structure Non Building	Address: 48 Quail Trail
Project Type: L700	Solution Type:	City, State: Trumbull, CT
Approved: Not Approved	Plan Year:	Region: NORTHEAST
Approved By: Not Approved	Market: CONNECTICUT	
Last Modified: 9/23/2016 7:01:54 AM	Vendor: Ericsson	
Last Modified By: GSM1900\AMurill9	Landlord: CL&P	

RAN Template: 704Bu Outdoor		AL Template: 1HP_704Bu		
Sector Count: 3	Antenna Count: 3	Coax Line Count: 18	TMA Count: 0	RRU Count: 3


Section 2 - Existing Template Images

----- This section is intentionally blank. -----

Section 3 - Proposed Template Images

704Bu.png

704Bu Cabinet View



Notes:

Section 4 - Siteplan Images

----- This section is intentionally blank. -----

DRAFT

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

Section 6 - A&L Equipment

Existing Template: 4B
Proposed Template: 1HP_704Bu

Sector 1 (Existing) view from behind

Coverage Type	A - Outdoor Macro			
Antenna	1			
Antenna Model	APX16DWV-16DWV-S-E-A20 (Quad)			
Azimuth	50			
M. Tilt	0			
Height	105			
Ports	P1		P2	
Active Tech.	U1900	G1900	U2100	L2100
Dark Tech.				
Restricted Tech.				
Decomm. Tech.				
E. Tilt	2		2	
Cables	1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft.
	1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft.
TMA's				
Diplexers / Combiners				
Radio				
Sector Equipment				

Unconnected Equipment:

Scope of Work:

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

Sector 1 (Proposed) view from behind			
Coverage Type	A - Outdoor Macro		
Antenna	1		
Antenna Model	SBNHH-1D65A (Hex)		
Azimuth	50		
M. Tilt	0		
Height	105		
Ports	P1	P2	P3
Active Tech.	U1900 G1900	U2100 L2100	L700
Dark Tech.			
Restricted Tech.			
Decomm. Tech.			
E. Tilt	2	2	2
Cables	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.
TMA's			
Diplexers / Combiners			
Radio			
Sector Equipment			
Unconnected Equipment:			
Scope of Work:			
Install Bias-T's up top for RET's			

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

Sector 2 (Existing) view from behind			
Coverage Type	A - Outdoor Macro		
Antenna	1		
Antenna Model	APX16DWV-16DWV-S-E-A20 (Quad)		
Azimuth	170		
M. Tilt	0		
Height	105		
Ports	P1		P2
Active Tech.	U1900 G1900	U2100 L2100	
Dark Tech.			
Restricted Tech.			
Decomm. Tech.			
E. Tilt	7	8	
Cables	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	
TMA's			
Diplexers / Combiners			
Radio			
Sector Equipment			
Unconnected Equipment:			
Scope of Work:			

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

Sector 2 (Proposed) view from behind			
Coverage Type	A - Outdoor Macro		
Antenna	1		
Antenna Model	SBNHH-1D65A (Hex)		
Azimuth	170		
M. Tilt	0		
Height	105		
Ports	P1	P2	P3
Active Tech.	U1900 G1900	U2100 L2100	L700
Dark Tech.			
Restricted Tech.			
Decomm. Tech.			
E. Tilt	2	2	2
Cables	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.
TMAs			
Diplexers / Combiners			
Radio			
Sector Equipment			
Unconnected Equipment:			
Scope of Work:			
Install Bias-T's up top for RET's			

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

Sector 3 (Existing) view from behind			
Coverage Type	A - Outdoor Macro		
Antenna	1		
Antenna Model	APX16DWV-16DWV-S-E-A20 (Quad)		
Azimuth	300		
M. Tilt	0		
Height	105		
Ports	P1		P2
Active Tech.	U1900 G1900	U2100 L2100	
Dark Tech.			
Restricted Tech.			
Decomm. Tech.			
E. Tilt	2	2	
Cables	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	
TMAs			
Diplexers / Combiners			
Radio			
Sector Equipment			
Unconnected Equipment:			
Scope of Work:			

RAN Template: 704Bu Outdoor	A&L Template: 1HP_704Bu
---------------------------------------	---------------------------------------

Sector 3 (Proposed) view from behind			
Coverage Type	A - Outdoor Macro		
Antenna	1		
Antenna Model	SBNHH-1D65A (Hex)		
Azimuth	300		
M. Tilt	0		
Height	105		
Ports	P1	P2	P3
Active Tech.	U1900 G1900	U2100 L2100	L700
Dark Tech.			
Restricted Tech.			
Decomm. Tech.			
E. Tilt	2	2	2
Cables	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.	1-5/8" Coax - 150 ft. 1-5/8" Coax - 150 ft.
TMA's			
Diplexers / Combiners			
Radio			
Sector Equipment			
Unconnected Equipment:			
Scope of Work:			
Install Bias-T's up top for RET's			



SBNHH-1D65A

Andrew® Tri-band Antenna, 698–896 and 2x 1695–2360 MHz, 65° horizontal beamwidth, internal RET. Both high bands share the same electrical tilt.

- Interleaved dipole technology providing for attractive, low wind load mechanical package

Electrical Specifications

Frequency Band, MHz	698–806	806–896	1695–1880	1850–1990	1920–2180	2300–2360
Gain, dBi	13.6	13.7	16.5	16.9	17.1	17.6
Beamwidth, Horizontal, degrees	66	61	70	65	62	61
Beamwidth, Vertical, degrees	17.6	15.9	7.1	6.6	6.2	5.5
Beam Tilt, degrees	0–18	0–18	0–10	0–10	0–10	0–10
USLS, dB	16	13	13	13	12	12
Front-to-Back Ratio at 180°, dB	25	27	28	28	27	29
CPR at Boresight, dB	20	16	20	23	17	20
CPR at Sector, dB	10	5	11	6	1	4
Isolation, dB	25	25	25	25	25	25
Isolation, Intersystem, dB	30	30	30	30	30	30
VSWR Return Loss, dB	1.5 14.0	1.5 14.0	1.5 14.0	1.5 14.0	1.5 14.0	1.5 14.0
PIM, 3rd Order, 2 x 20 W, dBc	-153	-153	-153	-153	-153	-153
Input Power per Port, maximum, watts	350	350	350	350	350	300
Polarization	±45°	±45°	±45°	±45°	±45°	±45°
Impedance	50 ohm	50 ohm	50 ohm	50 ohm	50 ohm	50 ohm

Electrical Specifications, BASTA*

Frequency Band, MHz	698–806	806–896	1695–1880	1850–1990	1920–2180	2300–2360
Gain by all Beam Tilts, average, dBi	13.1	13.1	16.1	16.5	16.7	17.2
Gain by all Beam Tilts Tolerance, dB	±0.5	±0.5	±0.5	±0.3	±0.5	±0.4
	0° 13.4	0° 13.4	0° 16.0	0° 16.3	0° 16.5	0° 17.0
Gain by Beam Tilt, average, dBi	9° 13.1	9° 13.1	5° 16.2	5° 16.5	5° 16.8	5° 17.3
	18° 12.7	18° 12.7	10° 16.1	10° 16.5	10° 16.6	10° 16.9
Beamwidth, Horizontal Tolerance, degrees	±3.1	±5.4	±2.8	±4	±6.6	±4.6
Beamwidth, Vertical Tolerance, degrees	±1.8	±1.4	±0.3	±0.4	±0.5	±0.3
USLS, dB	15	14	15	15	15	14
Front-to-Back Total Power at 180° ± 30°, dB	22	21	26	26	24	25
CPR at Boresight, dB	22	16	22	25	21	22
CPR at Sector, dB	10	6	12	8	5	4

* CommScope® supports NGMN recommendations on Base Station Antenna Standards (BASTA). To learn more about the benefits of BASTA, [download the whitepaper Time to Raise the Bar on BSAs.](#)

General Specifications

Antenna Brand	Andrew®
Antenna Type	DualPol® multiband with internal RET
Band	Multiband
Brand	DualPol® Teletilt®
Operating Frequency Band	1695 – 2360 MHz 698 – 896 MHz

SBNHH-1D65A

POWERED BY



Mechanical Specifications

Color	Light gray
Lightning Protection	dc Ground
Radiator Material	Aluminum Low loss circuit board
Radome Material	Fiberglass, UV resistant
RF Connector Interface	7-16 DIN Female
RF Connector Location	Bottom
RF Connector Quantity, total	6
Wind Loading, maximum	445.0 N @ 150 km/h 100.0 lbf @ 150 km/h
Wind Speed, maximum	241.4 km/h 150.0 mph

Dimensions

Depth	180.0 mm 7.1 in
Length	1409.0 mm 55.5 in
Width	301.0 mm 11.9 in
Net Weight	15.2 kg 33.5 lb

Remote Electrical Tilt (RET) Information

Input Voltage	10–30 Vdc
Power Consumption, idle state, maximum	2.0 W
Power Consumption, normal conditions, maximum	13.0 W
Protocol	3GPP/AISG 2.0 (Multi-RET)
RET Interface	8-pin DIN Female 8-pin DIN Male
RET Interface, quantity	1 female 1 male
RET System	Teletilt®

Regulatory Compliance/Certifications

Agency

RoHS 2011/65/EU
China RoHS SJ/T 11364-2006
ISO 9001:2008

Classification

Compliant by Exemption
Above Maximum Concentration Value (MCV)
Designed, manufactured and/or distributed under this quality management system



Included Products

BSAMNT-1 — Wide Profile Antenna Downtilt Mounting Kit for 2.4 - 4.5 in (60 - 115 mm) OD round members. Kit contains one scissor top bracket set and one bottom bracket set.

RADIO FREQUENCY EMISSIONS ANALYSIS REPORT
EVALUATION OF HUMAN EXPOSURE POTENTIAL
TO NON-IONIZING EMISSIONS

T-Mobile Existing Facility

Site ID: CT11860A

CT860/CL&P Trumbull
48 Quail Trail
Trumbull, CT 06611

November 22, 2016

EBI Project Number: 6216005487

Site Compliance Summary	
Compliance Status:	COMPLIANT
Site total MPE% of FCC general public allowable limit:	2.50 %

November 22, 2016

T-Mobile USA
Attn: Jason Overbey, RF Manager
35 Griffin Road South
Bloomfield, CT 06002

Emissions Analysis for Site: **CT11860A – CT860/CL&P Trumbull**

EBI Consulting was directed to analyze the proposed T-Mobile facility located at **48 Quail Trail, Trumbull, CT**, for the purpose of determining whether the emissions from the Proposed T-Mobile Antenna Installation located on this property are within specified federal limits.

All information used in this report was analyzed as a percentage of current Maximum Permissible Exposure (% MPE) as listed in the FCC OET Bulletin 65 Edition 97-01 and ANSI/IEEE Std C95.1. The FCC regulates Maximum Permissible Exposure in units of microwatts per square centimeter ($\mu\text{W}/\text{cm}^2$). The number of $\mu\text{W}/\text{cm}^2$ calculated at each sample point is called the power density. The exposure limit for power density varies depending upon the frequencies being utilized. Wireless Carriers and Paging Services use different frequency bands each with different exposure limits, therefore it is necessary to report results and limits in terms of percent MPE rather than power density.

All results were compared to the FCC (Federal Communications Commission) radio frequency exposure rules, 47 CFR 1.1307(b)(1) – (b)(3), to determine compliance with the Maximum Permissible Exposure (MPE) limits for General Population/Uncontrolled environments as defined below.

General population/uncontrolled exposure limits apply to situations in which the general public may be exposed or in which persons who are exposed as a consequence of their employment may not be made fully aware of the potential for exposure or cannot exercise control over their exposure. Therefore, members of the general public would always be considered under this category when exposure is not employment related, for example, in the case of a telecommunications tower that exposes persons in a nearby residential area.

Public exposure to radio frequencies is regulated and enforced in units of microwatts per square centimeter ($\mu\text{W}/\text{cm}^2$). The general population exposure limit for the 700 MHz Band is approximately 467 $\mu\text{W}/\text{cm}^2$, and the general population exposure limit for the 1900 MHz (PCS) and 2100 MHz (AWS) bands is 1000 $\mu\text{W}/\text{cm}^2$. Because each carrier will be using different frequency bands, and each frequency band has different exposure limits, it is necessary to report percent of MPE rather than power density.

Occupational/controlled exposure limits apply to situations in which persons are exposed as a consequence of their employment and in which those persons who are exposed have been made fully aware of the potential for exposure and can exercise control over their exposure. Occupational/controlled exposure limits also apply where exposure is of a transient nature as a result of incidental passage through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over his or her exposure by leaving the area or by some other appropriate means.

Additional details can be found in FCC OET 65.

CALCULATIONS

Calculations were done for the proposed T-Mobile Wireless antenna facility located at **48 Quail Trail, Trumbull, CT**, using the equipment information listed below. All calculations were performed per the specifications under FCC OET 65. Since T-Mobile is proposing highly focused directional panel antennas, which project most of the emitted energy out toward the horizon, all calculations were performed assuming a lobe representing the maximum gain of the antenna per the antenna manufactures supplied specifications, minus 10 dB, was focused at the base of the tower. For this report the sample point is the top of a 6-foot person standing at the base of the tower.

For all calculations, all equipment was calculated using the following assumptions:

- 1) 2 GSM channels (PCS Band - 1900 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 2) 2 UMTS channels (PCS Band - 1900 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 3) 2 UMTS channels (AWS Band – 2100 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 4) 2 LTE channels (AWS Band – 2100 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 60 Watts per Channel
- 5) 1 LTE channel (700 MHz Band) was considered for each sector of the proposed installation. This channel has a transmit power of 30 Watts.

- 6) Since all radios are ground mounted there are additional cabling losses accounted for. For each ground mounted RF path the following losses were calculated. 0.84 dB of additional cable loss for all ground mounted 700 MHz Channels, 1.55 dB of additional cable loss for all ground mounted 1900 MHz channels and 1.59 dB of additional cable loss for all ground mounted 2100 MHz channels. This is based on manufacturers Specifications for 105 feet of 1-5/8" coax cable on each path.
- 7) All radios at the proposed installation were considered to be running at full power and were uncombined in their RF transmissions paths per carrier prescribed configuration. Per FCC OET Bulletin No. 65 - Edition 97-01 recommendations to achieve the maximum anticipated value at each sample point, all power levels emitting from the proposed antenna installation are increased by a factor of 2.56 to account for possible in-phase reflections from the surrounding environment. This is rarely the case, and if so, is never continuous.
- 8) For the following calculations the sample point was the top of a 6-foot person standing at the base of the tower. The maximum gain of the antenna per the antenna manufactures supplied specifications minus 10 dB was used in this direction. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.
- 9) The antennas used in this modeling are the **Commscope SBNHH-1D65A** for 700 MHz, 1900 MHz (PCS) and 2100 MHz (AWS) channels. This is based on feedback from the carrier with regards to anticipated antenna selection. The **Commscope SBNHH-1D65A** has a maximum gain of **14.7 dBd** at its main lobe at 1900 MHz and 2100 MHz and a maximum gain of **10.9 dBd** at its main lobe at 700 MHz. The maximum gain of the antenna per the antenna manufactures supplied specifications, minus 10 dB, was used for all calculations. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.
- 10) The antenna mounting height centerline of the proposed antennas is **105 feet** above ground level (AGL).
- 11) Emissions values for additional carriers were taken from the Connecticut Siting Council active database. Values in this database are provided by the individual carriers themselves.
- 12) All calculations were done with respect to uncontrolled / general public threshold limits.

T-Mobile Site Inventory and Power Data

Sector:	A	Sector:	B	Sector:	C
Antenna #:	1	Antenna #:	1	Antenna #:	1
Make / Model:	Commscope SBNHH-1D65A	Make / Model:	Commscope SBNHH-1D65A	Make / Model:	Commscope SBNHH-1D65A
Gain:	14.7 dBd	Gain:	14.7 dBd	Gain:	14.7 dBd
Height (AGL):	105	Height (AGL):	105	Height (AGL):	105
Frequency Bands	700 MHz / 1900 MHz (PCS) / 2100 MHz (AWS)	Frequency Bands	700 MHz / 1900 MHz (PCS) / 2100 MHz (AWS)	Frequency Bands	700 MHz / 1900 MHz (PCS) / 2100 MHz (AWS)
Channel Count	9	Channel Count	9	Channel Count	9
Total TX Power(W):	330	Total TX Power(W):	330	Total TX Power(W):	330
ERP (W):	6,466.23	ERP (W):	6,466.23	ERP (W):	6,466.23
Antenna A1 MPE%	2.50	Antenna B1 MPE%	2.50	Antenna C1 MPE%	2.50

Site Composite MPE%	
Carrier	MPE%
T-Mobile (Per Sector Max)	2.50 %
No Additional Carriers Per CSC Active Database	NA
Site Total MPE %:	2.50 %

T-Mobile Sector A Total:	2.50 %
T-Mobile Sector B Total:	2.50 %
T-Mobile Sector C Total:	2.50 %
Site Total:	2.50 %

T-Mobile _per sector	# Channels	Watts ERP (Per Channel)	Height (feet)	Total Power Density ($\mu\text{W}/\text{cm}^2$)	Frequency (MHz)	Allowable MPE ($\mu\text{W}/\text{cm}^2$)	Calculated % MPE
T-Mobile AWS - 2100 MHz LTE	2	1,227.87	105	9.01	AWS - 2100 MHz	1000	0.90%
T-Mobile AWS - 2100 MHz UMTS	2	613.93	105	4.50	AWS - 2100 MHz	1000	0.45%
T-Mobile PCS - 1950 MHz UMTS	2	619.61	105	4.55	PCS - 1950 MHz	1000	0.45%
T-Mobile PCS - 1950 MHz GSM	2	619.61	105	4.55	PCS - 1950 MHz	1000	0.45%
T-Mobile 700 MHz LTE	1	304.17	105	1.12	700 MHz	467	0.24%
						Total:	2.50%

Summary

All calculations performed for this analysis yielded results that were **within** the allowable limits for general public exposure to RF Emissions.

The anticipated maximum composite contributions from the T-Mobile facility as well as the site composite emissions value with regards to compliance with FCC's allowable limits for general public exposure to RF Emissions are shown here:

T-Mobile Sector	Power Density Value (%)
Sector A:	2.50 %
Sector B:	2.50 %
Sector C:	2.50 %
T-Mobile Per Sector Maximum:	2.50 %
Site Total:	2.50 %
Site Compliance Status:	COMPLIANT

The anticipated composite MPE value for this site assuming all carriers present is **2.50%** of the allowable FCC established general public limit sampled at the ground level. This is based upon values listed in the Connecticut Siting Council database for existing carrier emissions.

FCC guidelines state that if a site is found to be out of compliance (over allowable thresholds), that carriers over a 5% contribution to the composite value will require measures to bring the site into compliance. For this facility, the composite values calculated were well within the allowable 100% threshold standard per the federal government.