



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

May 13, 2019

Ray Perry  
Airosmith Development  
32 Clinton Street  
Saratoga Springs, NY 12866

RE: **EM-SPRINT-156-190308** – Sprint notice of intent to modify an existing telecommunications facility located at 668 Jones Hill Road, West Haven, Connecticut.

Dear Mr. Perry:

The Connecticut Siting Council (Council) hereby denies your request to modify the above-referenced existing telecommunications facility, pursuant to Section 16-50j-73 of the Regulations of Connecticut State Agencies.

This exempt modification request was submitted to the Council on March 8, 2019. Council staff reviewed this request for completeness and had identified a deficiency that was more fully described in a notice of incompleteness letter to the requesting entity dated March 14, 2019 (attached) and a second letter of incompleteness dated April 4, 2019 (attached). The Council recommended that Airosmith Development provide a Structural Analysis Report (SA) that references the correct antenna mount and a Construction Drawing (CD) that references the correct date of the SA, on or before May 10, 2019. To date, the Council has not received the requested SA and CD.

Thus, the proposed modification is not in compliance with the exemption criteria in Section 16-50j-72 (b) of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman  
Executive Director

Enclosure: 1<sup>st</sup> Incomplete Letter for EM-SPRINT-156-190308, dated March 14, 2019  
2<sup>nd</sup> Incomplete Letter for EM-SPRINT-156-190308, dated April 4, 2019

MAB/IN/emr

c: The Honorable Nancy R. Rossi, Mayor, City of West Haven  
Fred A. Messore, Commissioner of Planning and Development, City of West Haven  
American Tower Corporation



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

April 4, 2019.

Ray Perry  
Airosmith Development  
32 Clinton Street  
Saratoga Springs, NY 12866

RE: **EM-SPRINT-156-190308** – Sprint notice of intent to modify an existing telecommunications facility located at 668 Jones Hill Road, West Haven, Connecticut.

Dear Mr. Perry:

The Connecticut Siting Council (Council) received a notice of intent to modify the above-referenced facility on March 8, 2019. On March 14, 2019, the Council issued a letter (enclosed) stating that the request for exempt modification was incomplete because the Structural Analysis Report (SA) references the 2016 Connecticut State Building Code (CSBC). The 2018 CSBC became effective on October 1, 2018 and should have been applied to this project. Also, the SA did not account for the proposed mount modifications as shown in the Construction Drawings (CD), and the Antenna Mount Analysis (MA) referenced in the CD was not provided. The Council recommended that Airosmith Development provide an updated SA and MA that reference the current 2018 CSBC and the proposed antenna mount modifications referenced above, on or before April 19, 2019.

On April 3, 2019, the Council received a SA dated March 20, 2019 which referenced the 2018 CSBC, a MA dated April 1, 2019 and CD dated February 13, 2019. However, the SA lists the proposed antenna mount as SitePro1 RMV5-296 T-Arms. This is inconsistent with the MA and CD, which list the proposed antenna mount as a SitePro1 RMQP-396 Platform mount. Also, the date of the SA referenced in structural notes on sheet A-2 of the CD is not consistent with the SA provided in the response.

Therefore, the exempt modification request remains incomplete at this time. The Council recommends that Airosmith Development provide a SA that references the correct antenna mount and a CD that references the correct date of the SA, on or before May 10, 2019. If additional time is needed to gather the requested information, please submit a written request for an extension of time prior to May 10, 2019. **Please provide an electronic version and one hard copy of the SA and CD for the incomplete request to be rendered complete and processed.**

This notice of incompleteness shall have the effect of tolling the Federal Communications Commission (FCC) 60-day timeframe in accordance with Paragraph 217 of the FCC Wireless Infrastructure Report and Order issued on October 21, 2014 (FCC 14-153).

Thank you for your attention to this matter. Should you have any questions, please feel free to contact me at 860-827-2951.

Sincerely,

Melanie Bachman  
Executive Director

MAB/IN/emr

Enclosure: Incomplete Letter dated March 14, 2019.

c: The Honorable Nancy R. Rossi, Mayor, City of West Haven  
Fred A. Messoro, Commissioner of Planning and Development, City of West Haven  
S: EMS\_TS\_1\_BYTOWN\_WestHaven\_JonesHillRd\_SPRINT\_2ndincomplete\_tr\_JonesHillRd.docx



Affirmative Action - Equal Opportunity Employer



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL
Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935 Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
www.ct.gov/csc

March 14, 2019

Ray Perry
Airosmith Development
32 Clinton Street
Saratoga Springs, NY 12866

RE: EM-SPRINT-156-190308 - Sprint notice of intent to modify an existing telecommunications facility located at 668 Jones Hill Road, West Haven, Connecticut.

Dear Mr. Perry:

The Connecticut Siting Council (Council) received a notice of intent to modify the above-referenced facility on March 8, 2019.

According to Section 16-50j-71 of the Regulations of Connecticut State Agencies, "...any modification, as defined in Section 16-50j-2a of the Regulations of Connecticut State Agencies, to an existing tower site, except as specified in Sections 16-50j-72 and 16-50j-88 of the Regulations of Connecticut State Agencies, may have a substantial adverse environmental effect."

Staff has reviewed this exempt modification request for completeness and has identified a deficiency in the Structural Analysis Report (SA) dated October 23, 2018 and prepared by American Tower Corporation. The above-referenced document refers to the 2016 Connecticut State Building Code (CSBC); however, the 2018 CSBC became effective on October 1, 2018 and should be applied to this project. Also, the SA does not account for the proposed antenna mount modifications as indicated on sheets A-2 and A-3 of the Construction Drawings (CD) dated February 13, 2019 and prepared by Infimigv.

In addition the structural notes on sheet A-2 of the CD references a Mount Analysis Report (MA) dated December 12, 2018 and prepared by American Tower Corporation. This MA has not been provided with the request for exempt modification.

Therefore, the exempt modification request is incomplete at this time. The Council recommends that Airosmith Development provide an updated SA and MA that reference the current 2018 CSBC and the proposed antenna mount modifications referenced above, on or before April 19, 2019. If additional time is needed to gather the requested information, please submit a written request for an extension of time prior to April 19, 2019.

This notice of incompleteness shall have the effect of tolling the Federal Communications Commission (FCC) 60-day timeframe in accordance with Paragraph 217 of the FCC Wireless Infrastructure Report and Order issued on October 21, 2014 (FCC 14-153).

Thank you for your attention to this matter. Should you have any questions, please feel free to contact me at 860-827-2951.

Sincerely,

Melanie Bachman
Executive Director

MAB/FOC/CW/in

c: The Honorable Nancy R. Rossi, Mayor, City of West Haven
Fred A. Messore, Commissioner of Planning and Development, City of West Haven

S:\EMS\_TS\1\_BYTOWN\WestHaven-JonesHillRd\_SitePlan\_Sprint-156-190308\_incomplete\tr\_JonesHillRd.docx



## Robidoux, Evan

---

**From:** Ray Perry <rperry@airosmithdevelopment.com>  
**Sent:** Wednesday, April 03, 2019 12:01 PM  
**To:** Robidoux, Evan  
**Cc:** CSC-DL Siting Council  
**Subject:** RE: Council Incomplete Letter for EM-SPRINT-156-190308-JonesHillRd-WestHaven  
**Attachments:** em-sprint-156-190308\_incompleteltr\_JonesHillRd.pdf; CT52XC076\_DO Macro Redesign\_Final CDs\_4-3-2019.pdf; CT52XC076\_DO Macro Redesign\_MA\_Contingent Pass\_S&S\_04-01-19.pdf; CT52XC076\_DO MACRO Redesign\_SA Pass\_3-25-2018.pdf

Hello,

Please see the attached revised SA & CD's as well as the MA. Please also let me know if you would like paper copies sent as a supplement to this application.


Thank you,  
Ray

Ray Perry  
*Site Acquisition | Airosmith Development*  
32 Clinton Street | Saratoga Springs | New York | 12866  
(518) 796-9165 phone | (518) 306-1711 fax  
[rperry@asdwireless.com](mailto:rperry@asdwireless.com)

**From:** Robidoux, Evan  
**Sent:** Monday, March 18, 2019 8:26 AM  
**To:** Ray Perry  
**Cc:** CSC-DL Siting Council  
**Subject:** Council Incomplete Letter for EM-SPRINT-156-190308-JonesHillRd-WestHaven

Please see the attached correspondence.

Evan Robidoux  
Clerk Typist  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

March 14, 2019

Ray Perry  
Airosmith Development  
32 Clinton Street  
Saratoga Springs, NY 12866

RE: **EM-SPRINT-156-190308** – Sprint notice of intent to modify an existing telecommunications facility located at 668 Jones Hill Road, West Haven, Connecticut.

Dear Mr. Perry:

The Connecticut Siting Council (Council) received a notice of intent to modify the above-referenced facility on March 8, 2019.

According to Section 16-50j-71 of the Regulations of Connecticut State Agencies, "...any modification, as defined in Section 16-50j-2a of the Regulations of Connecticut State Agencies, to an existing tower site, except as specified in Sections 16-50j-72 and 16-50j-88 of the Regulations of Connecticut State Agencies, may have a substantial adverse environmental effect."

Staff has reviewed this exempt modification request for completeness and has identified a deficiency in the Structural Analysis Report (SA) dated October 23, 2018 and prepared by American Tower Corporation. The above-referenced document refers to the 2016 Connecticut State Building Code (CSBC); however, the 2018 CSBC became effective on October 1, 2018 and should be applied to this project. Also, the SA does not account for the proposed antenna mount modifications as indicated on sheets A-2 and A-3 of the Construction Drawings (CD) dated February 13, 2019 and prepared by Infinigy.

In addition the structural notes on sheet A-2 of the CD references a Mount Analysis Report (MA) dated December 12, 2018 and prepared by American Tower Corporation. This MA has not been provided with the request for exempt modification.

Therefore, the exempt modification request is incomplete at this time. The Council recommends that Airosmith Development provide an updated SA and MA that reference the current 2018 CSBC and the proposed antenna mount modifications referenced above, on or before April 19, 2019. If additional time is needed to gather the requested information, please submit a written request for an extension of time prior to April 19, 2019.

This notice of incompleteness shall have the effect of tolling the Federal Communications Commission (FCC) 60-day timeframe in accordance with Paragraph 217 of the FCC Wireless Infrastructure Report and Order issued on October 21, 2014 (FCC 14-153).

Thank you for your attention to this matter. Should you have any questions, please feel free to contact me at 860-827-2951.

Sincerely,

Melanie Bachman  
Executive Director

MAB/FOC/CW/in

c: The Honorable Nancy R. Rossi, Mayor, City of West Haven  
Fred A. Messore, Commissioner of Planning and Development, City of West Haven

S: EMS\_TS1\_BYTOWN-WestHaven JonesHillRd\_Sprint-156-190308\_incomplete\_tr\_JonesHillRd.docx

