

December 21, 2015

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

**Re: TS-VER-156-140714 – Cellco Partnership d/b/a Verizon Wireless
24 Rockdale Road, West Haven, Connecticut**

Dear Ms. Bachman:

On August 4, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 24 Rockdale Road in West Haven, Connecticut. The modifications involved the replacement of its antennas, the installation of remote radio heads and the installation of a new fiber optic antenna cable.

As a condition of the acknowledgement, Cellco is required to provide the Council with a letter stating that Cellco's modifications were consistent with those referenced in the Structural Analysis Report. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the modifications were completed as required.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks
Rachel A. Mayo

13824646-v1

December 17, 2015

Mr. Tim Parks

Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon West Haven
24 Rockdale Road, West Haven

Tower Owner: Radio Communications Corp.

Engineer: KM Consulting Engineers
32 W. Upper Ferry Road, Ewing, New Jersey 08628

Centek Project No.: 15003.069

CSC Exempt Mod Reference No.: TS-VER-156-140714

Dear Mr. Parks,


We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by KM Consulting Engineers, Inc. (KM Project Number: 120514.0):

- Review of the KM Consulting Engineers, Inc. Tower Reinforcement Drawings and Specifications dated 05/14/2014.
- Field observations by Centek Engineering personnel on 09/16/2015 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the Tower Reinforcement Drawings and Specifications dated 05/14/2014.

The modification design prepared by KM Engineers, Inc. demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,


Carlo F. Centore, PE
Principal - Structural

