


KENNETH C. BALDWIN

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345



Also admitted in Massachusetts

October 22, 2015

ORIGINAL

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-158-140313 – Cellco Partnership d/b/a Verizon Wireless
20 Post Office Lane, Westport, Connecticut**

Dear Ms. Bachman:

On April 1, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 20 Post Office Lane in Westport, Connecticut. The modifications involved the replacement of its antennas, the installation of remote radio heads and the installation of a new fiber optic antenna cable.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that Cellco's modifications were consistent with those referenced in the Structural Analysis Report. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the modifications were completed as required.

If you have any questions please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Kenneth C. Baldwin".

Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks

Rachel A. Mayo

14232752-v1

October 21, 2015

Mr. Tim Parks
Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon Westport South
20 post Office Ln, Westport, CT

Tower Owner: American Tower Corporation
400 Regency Forest Dr., Cary, NC

Centek Project No.: 15003.040

CSC Exempt Mod Reference No.: EM-VER-158-140313

Dear Mr. Parks,


We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the Structural Analysis Report prepared by American Tower Corp. (ATC Number: 302511):

- Review of American Tower Corp. Structural Analysis dated 02/24/2014.
- Field observations by Centek Engineering personnel on 01/20/2015 of the completed upgrade which were installed in general compliance with the recommendations of the structural analysis report prepared by American Tower Corp on 02/24/2014.

The upgrade design prepared by American Tower Corp. demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,


Carlo F. Centore, PE
Principal - Structural

