
From: Carolyn Seeley <cseeley@empiretelecomm.com>
Sent: Monday, March 16, 2020 3:44 PM
To: CSC-DL Siting Council
Subject: RE: Council Notice of Outstanding Conditions for EM-AT&T-158-171019 (880 Post Road East, Westport) CT2147

Attached is the requested SSI. Do I need to mail a hard copy?

Thank you,
Carolyn Seeley
Site Acquisition Supervisor

16 Esquire Road | Billerica, MA 01862
Mobile: 339-234-8397
Email: cseeley@empiretelecomm.com
Website: www.EmpireTelecomm.com

Disclaimer: This E-Mail is intended only for the use of the individual or entity to which it is addressed, and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you have received this communication in error, please do not distribute it and delete the original message. Unless expressly stated in this e-mail, nothing in this message or any attachment should be construed as a digital or electronic signature.

From: Robidoux, Evan <Evan.Robidoux@ct.gov>
Sent: Thursday, February 27, 2020 12:09 PM
To: Carolyn Seeley <cseeley@empiretelecomm.com>
Cc: CSC-DL Siting Council <Siting.Council@ct.gov>; 'Mark.Roberts@QCDevelopment.net' <Mark.Roberts@QCDevelopment.net>
Subject: Council Notice of Outstanding Conditions for EM-AT&T-158-171019 (880 Post Road East, Westport)

Please see the attached correspondence.

Evan Robidoux
Clerk Typist
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Disclaimer: This email is intended only for the use of the individual or entity to which it is addressed, and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you received this communication in error, please do not distribute it and notify us immediately by email (administrator@qualtekservices.com) or via telephone (484.804.4500) and delete the original message. Unless expressly stated in this email, nothing in this message or any attachment should be construed as a digital or electronic signature.

Statement of Special Inspections

Project: *Structural Modifications to an Existing 180' Self Support Lattice Tower*
AECOM Project Numbers: 60519605/VZ5-202, 60553537/SAI-099
Dated October 2, 2017 CSP # 32 Westport

Location: *880 Boston Post Road, Westport CT*

Owner: *Connecticut State Police*

Design Professional in Responsible Charge: *Richard A. Sambor, P.E.*

This *Statement of Special Inspections* is submitted as a condition for permit issuance in accordance with the Special Inspection and Structural Testing requirements of the Building Code. It includes a schedule of Special Inspection services applicable to this project as well as the name of the Special Inspection Coordinator and the identity of other approved agencies to be retained for conducting these inspections and tests. This **Statement of Special Inspections** encompass the following disciplines:

Structural Mechanical/Electrical/Plumbing
 Architectural Other: Special Cases

The Special Inspection Coordinator shall keep records of all inspections and shall furnish inspection reports to the Building Official and the Registered Design Professional in Responsible Charge. Discovered discrepancies shall be brought to the immediate attention of the Contractor for correction. If such discrepancies are not corrected, the discrepancies shall be brought to the attention of the Building Official and the Registered Design Professional in Responsible Charge. The Special Inspection program does not relieve the Contractor of his or her responsibilities.

Interim reports shall be submitted to the Building Official and the Registered Design Professional in Responsible Charge.

A *Final Report of Special Inspections* documenting completion of all required Special Inspections, testing and correction of any discrepancies noted in the inspections shall be submitted prior to issuance of a Certificate of Use and Occupancy.

Job site safety and means and methods of construction are solely the responsibility of the Contractor.

Prepared by:

Richard A. Sambor, P.E.

(type or print name)

Richard A. Sambor

Signature

3/13/20

Date



Owner's Authorization:

Building Official's Acceptance:

Signature

Date

Signature

Date

Schedule of Inspection and Testing Agencies

This Statement of Special Inspections / Quality Assurance Plan includes the following building systems:

- | | |
|--|--|
| <input type="checkbox"/> Soils and Foundations | <input type="checkbox"/> Spray Fire Resistant Material |
| <input type="checkbox"/> Cast-in-Place Concrete | <input type="checkbox"/> Wood Construction |
| <input type="checkbox"/> Precast Concrete | <input type="checkbox"/> Exterior Insulation and Finish System |
| <input type="checkbox"/> Masonry | <input type="checkbox"/> Mechanical & Electrical Systems |
| <input checked="" type="checkbox"/> Structural Steel | <input type="checkbox"/> Architectural Systems |
| <input type="checkbox"/> Cold-Formed Steel Framing | <input checked="" type="checkbox"/> Special Cases |

Special Inspection Agencies	Firm	Address, Telephone, e-mail
1. Special Inspector Coordinator	AECOM Douglas Roberts	500 Enterprise Drive Rocky Hill, CT 06067 Tel. (860) 263-5819 doug.roberts@aecom.com
2. Inspector	AECOM Michael Dalickas, P.E.	500 Enterprise Drive Rocky Hill, CT 06067 Tel. (860) 263-5851 michael.dalickas@aecom.com
3. Inspector	AECOM Michael Egan	500 Enterprise Drive Rocky Hill, CT 06067 Tel. (860) 263-5817 michael.egan@aecom.com
4. Inspector	JDH Inspection Services Jody Baudanza	6 Progress Avenue Nashua, NH 03062 jodyb@jdhinspectors.com
5. Testing Agency		
6. Other		

Note: The inspectors and testing agencies shall be engaged by the Owner or the Owner's Agent, and not by the Contractor or Subcontractor whose work is to be inspected or tested. Any conflict of interest must be disclosed to the Building Official, prior to commencing work.

Structural Steel

Item	Agency # (Qualif.)	Scope
1. Fabricator Certification/ Quality Control Procedures <input type="checkbox"/> Fabricator Exempt	N/A	Review shop fabrication and quality control procedures.
2. Material Certification	1&2	Review certified mill test reports and identification markings on wide-flange shapes, high-strength bolts, nuts and welding electrodes
3. Open Web Steel Joists	N/A	Inspect installation, field welding and bridging of joists.
4. Bolting	1&4	Inspect installation and tightening of high-strength bolts. Verify that splines have separated from tension control bolts. Verify proper tightening sequence. Continuous inspection of bolts in slip-critical connections.
5. Welding	N/A	Visually inspect all welds. Inspect pre-heat, post-heat and surface preparation between passes. Verify size and length of fillet welds. <i>Ultrasonic testing of all full-penetration welds</i>
6. Shear Connectors	N/A	Inspect size, number, positioning and welding of shear connectors. Inspect studs for full 360 degree flash. Ring test all shear connectors with a 3 lb hammer. Bend test all questionable studs to 15 degrees.
7. Structural Details	1,2 & 4	Inspect steel frame for compliance with structural drawings, including bracing, member configuration and connection details.
8. Metal Deck	NA	Inspect welding and side-lap fastening of metal roof and floor deck.
9. Other:		

Special Cases

Item	Agency # (Qualif.)	Scope
1. Material Certification	1	Review certified mill test reports and identification markings on wide-flange shapes, high-strength bolts, nuts and welding electrodes
2. Tower Erection	N/A	Review of Tower Shop Drawings Submittals. Verify Compliance with tower Manufactures' Erection / Installation Requirements.
3. Guy Wire Tensioning	N/A	Verify that Guyed Wires are Placed and Tensioned consistent with the Structural Analysis report
4. Antenna Mounts and Platforms	1 & 4	Inspect antenna Mounts and Platform Assemblies for compliance with the Structural Drawings and Mount Analysis, including antenna mounting hardware configuration and construction details
5. Coax and Radio Cabling	1 & 4	Verify that Coax and Radio Cabling complies with the Structural analysis and placement is consistent with the Structural Analysis report of the tower and Mount Analysis report.