

December 6, 2018

Melanie A. Bachman, Esq.
Executive Director/Staff Attorney
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-163-170605 – Cellco Partnership d/b/a Verizon Wireless
349R Mountain Road, Windham (Willimantic), Connecticut**

Dear Ms. Bachman:

On June 26, 2017, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its existing telecommunications facility at 349R Mountain Road in Windham (Willimantic), Connecticut. The approved modifications involved the replacement of antennas and remote radio heads.

As a condition of its approval, Cellco was required to provide the Council with a letter stating that it had complied with the recommendations made in the structural report attached to the exempt modification filing. Attached is a Professional Engineer's evaluation letter verifying that the installation was completed according to that structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks

NEXIUS

Accelerating Network and Business Transformation

November 30, 2018

Mr. Tim Parks

Verizon Wireless
20 Alexander Drive, 2nd Floor
Wallingford, CT 06492

RE: Notice of Completion

Project: Verizon Willimantic CT
349R Mountain Street, Windham (Willimantic), CT 06226

Engineer: Jimmy Chendana
Nexius Solution Inc.
7 A Lyberty Way
Westford, MA 01886

CSC Exempt Mod Reference No.: EM-VER-163-170605

Dear Mr. Parks,

Nexius Solutions Inc. is providing this "Notice of Completion" regard to the wireless telecommunications facility installation at the above referenced project.


The following are the basis for substantiating compliance with the Construction Drawings prepared by Nexius Solutions Inc.:

- Review of FDH Velocitel's Structural Analysis (project #17QEIQ1400) dated May 10, 2017.
- Field Observations by Nexius Solutions Inc. personnel on October 17, 2018 of the completed installation which was installed in general compliance with the aforementioned structural analysis.

The structural analysis prepared by FDH Velocitel demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,
Nexius Solutions Inc.

Jimmy Chendana, P.E.
Structural Engineer
443-458-2372



NEXIUS MA Office: 7 A Lyberty Way, Westford, MA 01886