

**From:** Steve Pearson <[spearson@vfsmi.com](mailto:spearson@vfsmi.com)>

**Sent:** Friday, January 27, 2023 7:24 AM

**To:** Evan.Robidoux@ct.gov

**Cc:** Bachman, Melanie <[Melanie.Bachman@ct.gov](mailto:Melanie.Bachman@ct.gov)>; mayordevivo@windhamct.com;  
townmanager@windhamct.com; CSC-DL Siting Council <[Siting.Council@ct.gov](mailto:Siting.Council@ct.gov)>

**Subject:** FW: Council Decision Letter for EM-VFS-163-221114e (55 West Road, Windham)

Hi Evan and CT Siting Council, The attached Eversource PTO shows that the project construction is completed. We have tremendous partners. Thanks for everything. We appreciate your excellent service< Steve

Dear Steve Pearson:

The Connecticut Siting Council (Council) hereby acknowledges your notice to modify this existing energy facility, pursuant to Section 16-50j-57 of the Regulations of Connecticut State Agencies with the following conditions:

1. Any deviation from the proposed modification as specified in this notice and supporting materials with the Council shall render this acknowledgement invalid;
2. Any material changes to this modification as proposed shall require the filing of a new notice with the Council;
3. Not less than 45 days after completion of construction, the Council shall be notified in writing that construction has been completed;
4. The validity of this action shall expire one year from the date of this letter; and
5. VFS, LLC may file a request for an extension of time beyond the one year deadline provided that such request is submitted to the Council not less than 60 days prior to the expiration.

**STEVE PEARSON**

Green Energy Customer Financing Executive

248-657-4600 ext. 105

[spearson@vfsmi.com](mailto:spearson@vfsmi.com)

January 26, 2023

**Attention:** James Howarth

**Eastern Connecticut State University**  
0 High St.,  
Willimantic, CT 06226

**Regarding:** Authorization to energize the 460 kW inverter-based Fuel Cell installation with one (1) (Model 400 + Fuel Cell System ESM), for Eastern Connecticut University, located at 0 High St., Willimantic, CT 06226.

**Approval to Interconnect Date:** January 20, 2023

Dear Mr. Howarth,

This letter is an approval to energize of the above stated project to the Eversource system in accordance with the Interconnection Agreement. As stated in the Interconnection Agreement (enclosed) and the “Generator Interconnection Guidelines”, the following items must be provided the Eversource Distributed Resources Group on a regular basis:

1. Annually: Provide a certificate of insurance as described in the enclosed interconnection agreement prior to the insurance expiration date. Please send it to [InsuranceCTDG@Eversource.com](mailto:InsuranceCTDG@Eversource.com) or to the following address by that date:

Eversource Distributed Resources  
107 Selden St.,  
Berlin, CT 06037

2. You are responsible for the periodic maintenance of the relays, interrupting devices, control schemes, and batteries that involve the protection of the EDC’s system. Eversource may audit these reports, logs, and other material regarding the interconnection of the Generating Facility at its discretion.

Sincerely,

*Winston D. Brown, MBA*

Senior Analyst/Project Manager  
Distributed Energy Resources  
107 Selden Street, Berlin, CT 06037  
Tel: 860-665-3717

E-mail : [brownwd@eversource.com](mailto:brownwd@eversource.com)

CC : Carl Nowiszewski, Manager - Distributed Energy Resources  
DESA Service, LLC

INT-69196