

KENNETH C. BALDWIN

280 Trumbull Street
Hartford, CT 06103-3597
Main (860) 275-8200
Fax (860) 275-8299
kbaldwin@rc.com
Direct (860) 275-8345

Also admitted in Massachusetts

October 29, 2015

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-167-140423 – Cellco Partnership d/b/a Verizon Wireless 1116 Johnson Road (a/k/a 1027 Racebrook Road), Woodbridge, Connecticut**

Dear Ms. Bachman:

On May 15, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 1116 Johnson Road in Woodbridge, Connecticut. The modifications involved the replacement of its antennas, the installation of remote radio heads and the installation of a new fiber optic antenna cable.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that the tower modifications described in the Structural Analysis Report were completed. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the modifications were completed.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks

14255416-v1

October 28, 2015

Mr. Tim Parks

Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: **Verizon Woodbridge South**
1116 Johnson Road (a/k/a/ 1027 Racebrook Road), Woodbridge, CT

Tower Owner: **Crown Castle**
3530 Toringdon Way, Suite 300, Charlotte, NC

Engineer: **Paul J. Ford and Company**
250 East Broad Street, Suite 600, Columbus, OH

Centek Project No.: 15003.061

CSC Exempt Mod Reference No.: EM-VER-167-140423

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by Paul J. Ford and Company (PJF Project Number: 37513-2197 R1):

- Review of the Paul J. Ford and Company Structural Analysis dated 10/08/2013.
- Review of the Paul J. Ford and Company Modification Drawings S1 thru S9 dated 03/15/2013.
- Review of the Tower Engineering Professionals Modification Inspection Report dated 11/21/2013.
- Field observations by Centek Engineering personnel on 10/21/2015 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the structural analysis report prepared by Paul J. Ford and Company on 10/08/2013.

The modification design prepared by Paul J. Ford and Company demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,



Carlo F. Centore, PE
Principal - Structural

