



STATE OF CONNECTICUT  
*CONNECTICUT SITING COUNCIL*

Ten Franklin Square, New Britain, CT 06051  
Phone: (860) 827-2935 Fax: (860) 827-2950  
E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)  
Web Site: [www.ct.gov/csc](http://www.ct.gov/csc)

**VIA ELECTRONIC MAIL**

March 27, 2020

Jennifer D. Arasimowicz, Esq.  
FuelCell Energy, Inc.  
3 Great Pasture Road  
Danbury, CT 06810

RE: **PETITION NO. 1372** – Derby Fuel Cell, LLC declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a 14.0-megawatt fuel cell facility, associated equipment and related site improvements to be located at 200 Roosevelt Drive, Derby, Connecticut.

Dear Attorney Arasimowicz:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 2, 2020. To help expedite the Council's review, please file individual responses as soon as they are available. Please provide an electronic copy to this office only.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

*s/ Melanie A. Bachman*

Melanie A. Bachman  
Executive Director

MB/MP



STATE OF CONNECTICUT  
*CONNECTICUT SITING COUNCIL*

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [www.ct.gov/csc](http://www.ct.gov/csc)

**Petition No. 1372**

**Derby Fuel Cell, LLC**

**200 Roosevelt Drive**

**Derby, CT**

**D&M Plan Interrogatories – Set Two**

5. Condition 1a of the Connecticut Siting Council's (Council) July 19, 2019 declaratory ruling (Declaratory Ruling) requires that the Development and Management Plan (D&M Plan) include "A final site plan including, but not limited to, fuel cell units, related equipment, transformer locations (both dry and insulating fluid-filled) with containment measures as necessary, perimeter fence, concrete pads..." Please identify the transformer locations on the site plan and indicate if any containment measures are necessary for any insulating fluid-filled transformers, if applicable.
6. Referencing the Site Development Plan, Sheet 2 of 3 submitted on March 25, 2020, is there a fence on the north side of the compound, or is the compound only fenced on three sides? If the fence is only on three sides, please explain why.
7. Referencing the Site Development Plan, Sheet 2 of 3 submitted on March 25, 2020, the compound dimension lines indicate "Proposed Chain Link Fence w/Razor Wire," and the note at the bottom of the drawing says "8' High Chain Link Fence (TYP) with Barbed Wire." Please clarify if the fence would have barbed wire, razor wire, or a combination of both?