



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

January 24, 2020

Justin Adams
Bloom Energy Corporation
4353 North First Street
San Jose, CA 95134

RE: **PETITION NO. 1392** – Bloom Energy Corporation petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 300-kilowatt fuel cell facility and associated equipment to be located at the Town of Southington Water Treatment Plant, 999 Meriden Waterbury Turnpike, Southington, Connecticut.

Dear Mr. Adams:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than February 7, 2020. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 15 copies to this office, as well as a copy via electronic mail. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the February 7, 2020 deadline.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

MB/RM

c: Alicia Surowiec, Bloom Energy Corporation

Petition No. 1392
Bloom Energy Corporation
999 Meriden Waterbury Turnpike, Southington
Interrogatories

1. Was the project selected for the LREC/ZREC Program?
2. Has the Department of Energy and Environmental Protection provided a response to Bloom's Natural Diversity Database review request? If so, please submit a copy.
3. Referring to Site Plan C1.1, the components of the Bloom Energy servers have abbreviations on the modules but there is no corresponding key/legend. Please indicate what the abbreviations represent.
4. The Bloom Energy Server specification sheets in Exhibit 3 indicate nameplate and output values of 150 kW (net). Does the "net" indicate the actual output of the server to the customer at the point of interconnection?