



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

Web Site: portal.ct.gov/csc

VIA ELECTRONIC MAIL

September 23, 2024

Steve Broyer
Ecos Energy LLC
222 South 9th Street
Suite 1600
Minneapolis, MN 55402
Steve.Broyer@ecosrenewable.com

RE: **PETITION NO. 1395A** – Windham Solar LLC Declaratory Ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the construction, maintenance and operation of one 1.0-megawatt (MW) and one 0.99 MW solar photovoltaic electric generating facilities located at 31 Benz Street, Ansonia, Connecticut. **Partial Development and Management Plan II Interrogatories. Set 2.**

Dear Steve Broyer:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than October 1, 2024.

Please submit an original and 15 copies to the Council's office and an electronic copy to siting.council@ct.gov. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the October 1, 2024 deadline.

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

c: Service List, dated April 23, 2021

Enclosure: Revised Schedule, dated September 23, 2024



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935 Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
Web Site: portal.ct.gov/esc

REVISED DEVELOPMENT AND MANAGEMENT PLAN SCHEDULE

PETITION NO. 1395A – Windham Solar LLC Declaratory Ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the construction, maintenance and operation of one 1.0-megawatt (MW) and one 0.99 MW solar photovoltaic electric generating facilities located at 31 Benz Street, Ansonia, Connecticut.

Motion to Vacate or Reconsider the March 12, 2021 Council Decision	03/26/2021
Motion to Reconsider granted by the Council	04/22/2021
Council Interrogatories	
• Set-One Filed	05/03/2021
• Set-One responses due	05/27/2021
Deadline for Exchange of Interrogatories between Participants	05/06/2021
Responses to Participant Interrogatories due	05/27/2021
Deadline for Decision after Reconsideration	07/21/2021
Final Decision	06/21/2021
Partial Development and Management (D&M) Plan I received	06/28/2021
Deadline for Decision for Partial D&M Plan I	08/27/2021
90-day extension for Deadline for Decision for Partial D&M Plan I per Emergency Orders, as extended	11/25/2021
Decision for Partial D&M Plan I	07/30/2021
Partial D&M Plan II received	08/15/2024
Council Interrogatories	
• Set-One Issued	08/29/2024
• Set-One Responses Due	09/12/2024
• Set-One Responses Due w/ Extension	09/20/2024
• Set-Two Issued	09/23/2024
• Set-Two Responses Due	10/01/2024
Deadline for Decision for Partial D&M Plan II	10/14/2024
Deadline for Decision for Partial D&M Plan II with extension	10/30/2024

**Petition No. 1395A
Windham Solar LLC
31 Benz Street, Ansonia**

**Partial Development & Management (D&M) Plan II
Interrogatories – Set 2**

6. Referencing interrogatory response 3, provide laboratory results for the TCLP test. Refer to correspondence from Council Petition 1562 (link below) for an example of TCLP laboratory results. [pe1562_ack-condition1_070324_a.pdf \(ct.gov\)](#)
7. Referencing Partial D&M Plan II Overall Site Electrical Plan PV-3, an overhead interconnection line is shown along the site access drive, supported by 5 new utility poles. The initial approved D&M site plan showed an underground interconnection line from both System 1 and System 2 to a respective riser pole adjacent to Benz Street.
 - a) What is the reason for the change in the interconnection design?
 - b) What is the purpose of the three “New Riser Poles”?
 - c) Can the span lengths be increased to reduce the number of poles?
 - d) Can the underground line be extended to reduce the number of poles?