

**From:** [Hall, Ivonne](#)  
**To:** [Bradley J. Parsons](#)  
**Cc:** [Bryan Fitzgerald](#)  
**Subject:** Re: Verogy East Windsor Solar One  
**Date:** Wednesday, May 12, 2021 2:43:50 PM  
**Attachments:** [image001.png](#)

---

Yes, your understanding is correct.

Ivonne Grajko Hall, PE  
Supervising Civil Engineer  
Dam Safety Program  
Connecticut Department of Energy & Environmental Protection

---

**From:** Bradley J. Parsons <BParsons@allpointstech.com>  
**Sent:** Tuesday, May 11, 2021 3:43:49 PM  
**To:** DEEP DamSafety <DEEP.DamSafety@ct.gov>  
**Cc:** Hall, Ivonne <Ivonne.Hall@ct.gov>; Bryan Fitzgerald <bfitzgerald@verogy.com>  
**Subject:** Verogy East Windsor Solar One

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click any links or open any attachments unless you trust the sender and know the content is safe.

Dear Dam Safety,

The Connecticut Sitting Council has requested in their Development and Management Plan request for the subject project that we reach out to Dam Safety regarding permit requirements if any for the project.

It is our understanding that “Any dam which impounds less than three acre-feet of water (when assuming the water level at the crest of the dam) will not require a Dam Safety Construction Permit.”

For this project at the crest of the proposed basin, elevation 193.5, the storage is at that elevation is 2.27 acre-feet. Thus it is our understanding that the project would not require a Dam Safety Permit.

If you could confirm this for our record with the CSC. If you have any questions please let us know.

Brad



**BRADLEY J. PARSONS, PE**

Manager Civil Engineering

D | 860.552.2046 • M | 203.814.6866 • W |

[www.allpointstech.com](http://www.allpointstech.com)

567 Vauxhall Street Extension – Suite 311, Waterford, CT 06385