

October 6, 2020

Connecticut Siting Council Response to Interrogatories Set one

Melanie A. Bachman
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Petition No.: 1428
CSC Comment Date: 09/22/2020
Project Name: Branford 11J
Job Address: 272 East Main Street, Branford, CT
Owner: The Connecticut Light and Power Company d/b/a Eversource Energy

This letter is in response to interrogatory number one (1) from the Connecticut Siting Council for Petition No. 1428. The original comments have been included for your reference and convenience. Please see Black & Veatch (BV) responses to each comment addressed below shown in **BOLD** font type.

Interrogatory 1.

Since the facility is located within the Federal Emergency Management Agency-designated 100-year flood zone, would any protective design measures for the radio shelter and/or generator be used? If so, indicate what measures would be utilized.

BV Response:

- **Existing Radio Shelter** – According to As-Built drawings provided by Eversource Energy, the Top of Footing (TOF) elevation is ten (10) foot above mean sea level (AMSL), which is above the Base Flood Elevation (BFE) of nine (9) feet AMSL.
- **Proposed Generator** – The proposed generator’s TOF elevation has been revised to be in accordance with BFE+2’, or eleven (11) feet AMSL.



10/06/2020