

November 17, 2021

Melanie Bachman
Executive Director
Connecticut Siting Council
Ten Franklin Square
New Britain, Connecticut 06051

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project Petition for Declaratory Ruling

To Whom It May Concern,

Enclosed please find an original and 15 copies of the above noted petition and a filing fee of \$625.00

In the Petition, Dynamic Energy Solutions, LLC as agent for Stag Industrial Holdings, LLC, respectfully requests that the Connecticut Siting Council approve location and construction of the 2.112 MW (DC)/ 1.5 MW (AC) rooftop solar photovoltaic renewable energy generating facility to be located at 40 Pepe Farm Road, Milford, CT 06460

We hope that you find the request satisfactory in form and nature. If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



Project Information Narrative

40 Pepe Farms Road Roof Top Solar Project

Petition Overview

Pursuant to Section 16-50k(a) and Section 4-176(a) of the Connecticut General Statutes ("CGS") and Section 16-50j-38 et seq. of the Regulations of Connecticut State Agencies ("RCSA"), Stag Industrial Holdings acting through its agent, Dynamic Energy Solutions, LLC requests that the Connecticut Siting Council (the "Council") issue a declaratory ruling approving the construction and operation of a 2.112 MW (DC)/ 1.5 MW (AC) Solar electric generating facility (the "Facility"), located on the roof of the existing commercial building in a Light Industrial zoned district at 40 Pepe Farms Road, Milford, CT

As demonstrated from the information included in the petition the Facility will result in no air emissions, complies with DEEP's air and water quality standards, and will have no substantial adverse environmental effect. The project is having been contingently approved by the local Utility Co. (UI) and has been awarded participation in the Statewide Shared Clean Energy Facility (SCEF) Program.

The statewide SCEF Program was developed pursuant to Section 7(a)(1)(C) of Public Act 18-50, An Act Concerning Connecticut's Energy Future, codified as Section 16-244z(a)(1)(C) of the General Statutes of Connecticut. The statewide SCEF Program seeks the deployment of new or incremental Class I renewable generation projects ranging in size from 100 to 4,000 kW (AC) for a 20-year term. Eligible projects are chosen through a competitive bidding procurement process each year, for a total of 6 years. The program capacity is up to 25 MW per year.

Project Proponent & Petitioner Contact Info

Dynamic Energy, LLC
1550 Liberty Ridge Drive, #310
Wayne, PA 19087
807-809-8884

Pat Hastings
SVP, Project Engineering and Delivery
phastings@dynamicenergy.com
484.323.1155

Site Selection & Description

The existing parcel is approx. 14.5 acres located at 40 Pepe Farm Road in Milford, Connecticut in a light industrial mixed use area. The Site is described by the Milford tax assessor as parcel # 16008 is zoned LI and is currently owned by Stag Industrial Holdings, LLC and operated by the Thule Group. The existing facility is buffered along the road almost entirely with mature trees and evergreen.

The proposed facility which includes solar modules, ballasted racking system and inverters will be installed on the roof of the existing commercial building on site. The electrical generation of the system will be fed into the existing UI power grid via electrical equipment and poles located on the property. That electrical equipment consists of a transformer, switchgear, metering equipment and data monitoring system mount on a concrete pad and or vault. The location of the electrical equipment is in the grassy area near the front of the building approximately 100 feet from the street.

Service Life

The proposed facility has an expected useful life of approx. 25-30 years.

Equipment

- 2.112 kW DC
- 1.5 MW AC
- 2,675 MWh Annual Production
 - o Directly exported to Utility Grid per SCEF Program

The major components of the system include but are not limited to:

- 72 Cell Watt Solar Modules (Qty: 5280)
- Ballast Mount Racking System (DCE)
 - o System sits on deck of existing TPO roof. The racking sits on feet made out of recycled rubber. There is a slip sheet layout between the existing roof membrane and the rubber.
 - o Maximum system height to top of solar module is approx. 14-16 inches
- Inverters (Qty 30) 50kW AC String Inverters
 - o Inverters will be mounted on the roof via inverter racking similar to racking for solar modules
 - o Maximum Height if mounted inverter is approx. 24"
 - o Inverter output circuits will be run from the roof in metal conduit down the side of the building wall. Conduits then travel underground to the AC collector equipment pad.

- AC Collector equipment (all collocated on 50' x 20' concrete pad in front of building)
 - 1 Pad Mounted Switchboard (approx. 72" high x 36"L x 36"W)
 - 1 2000kVA transformer (approx. 83" high x 80" Lx 83" W)
 - 1 Pad Mounted Disconnect Switch (approx. 93" high x 64" L x 44" W)
 - 1 Pad Mounted Metering Enclosure (approx. 47" high x 72"L x 54" W)
 - United Illuminating Company owned interconnection equipment.
 - The output of the AC collector equipment will leave the concrete pad area underground and to a UI owned and installed riser pole,
 - Pole Mounted GOAB switch – Pole mounted switch for Utility and Emergency disconnection
 - 1 new junction pole & 1 new stub pole to tie into existing utility lines at the street.
 - Utility poles are approximately 40' heigh.
 - 1 new customer service transformer replacement.
 - UI is replacing the customer existing transformer given the age of the equipment.
 - The replacement will be located at the same location of the existing transformer (front of building)
 - Access to UI equipment
 - UI requires truck access to equipment which will consist of a pervious roll grass paver

- All equipment and systems have been designed and engineered to adhere to all local, state and federal code requirements. Including but not limited to:
 - National Fire Protection Association (NFPA)
 - Standard for Electrical Safety in the Workplace (NFPA 70E)
 - Fire Code (NFPA 1)
 - National Electrical Code (NEC)
 - American National Standards Institute (ANSI)
 - Institute of Electrical and Electronics Engineers (IEEE)
 - International Code Council (ICC)
 - International Building Code (IBC)
 - International Plumbing Code (IPC)
 - National Electrical Manufacturers Association (NEMA)
 - Underwriters Laboratories (UL)

Utility Approval

- United Illuminating Co has contingently approved construction and interconnection of the system. A system impact study has been complete and shows no major impact on existing electrical system.
- System Protection
 - o System Relay & Protection function are included in the customer side of the equipment via internal relay protection as well as supplemental relay protection in AC collector switchboard.
 - o Main system disconnects are located both at the pad mounted disconnect switch and Utility owned pole mounted GOAB (gang operated air break) switch.

Environmental Considerations

- Project will comply with air emissions rates, including carbon dioxide and any other greenhouse gasses, and compliance with applicable DEEP regulations
- Project will not increase or decrease existing water consumption and discharge rates
- Project is not located in any FEMA flood zones
- Project is not located in proximity of any DEEP Aquifer Protection Areas or Vernal Pool Areas
- Project DEEP ground water classification underlying the property is Class GB
 - o Class GB designated uses are industrial process water and cooling waters and baseflow for hydraulically-connected waterbodies and is presumed not suitable for human consumption without treatment
- FAA has determined the project as NO hazard to air navigation
- The project is located entirely on developed existing parcel
 - o Project is NOT located in Critical Habitat of any State or Federal listed Species
 - o Project is NOT located in Northern long-eared bat areas of concern in Connecticut
- Parcel is buffered (minus area at entrance) by mature trees and evergreens. The closest residential home is approx 565 feet away. These are buffered approx. 250' deep of mature trees and natural vegetation.

Construction Description and Sequence

- The proposed solar array is planned to consist of approximately 5,280 solar modules installed on a steel roof top ballasted racking mounting system. Equipment and material will be store onsite in existing parking lot staging area.All

materials and equipment will be stored in ground located in lockable shipping containers on parking lot staging area. The solar modules, racking and any necessary installation tools and equipment will lift to the roof via shooting boom forklift. The racking is installed first, then the solar modules and then the associated wiring to the inverters and down off the roof to the AC collector area. AC collector system will be mounted on a concrete pad. Once the concrete pad and equipment are installed the AC wiring from the inverters, switchboard transformers etc will be pulled and landed. United Illuminating Company will install Utility interconnection and new feeder will be run underground from the last Utility Pole to the AC Collector equipment. Local Building and Electrical inspections will take place and once approved the system will be tested, commissioned and approved for operation by the Utility Company.

- Construction timeline will be approximately 3-4 months
- Working hours are typically 7am-5pm
 - o Given the nature of the project no extraneous noise during construction is expected.
- Total disturbance area is expected to be less than 3,000 sq ft.
 - o This disturbance are will be limited to the grassy area in the front of the building where the pad mounted electrical equipment will be located.
 - o A General Permit for discharge of stormwater will NOT be required given the actual amount of disturbance expected onsite (less than 1 acre)
- Semi-Annual proactive maintained of the system will occur by qualified individuals.
 - o Maintenance activities consist of visual inspection, electrical testing or system typical to Solar PV system.
 - o Maintenance access will be achieved thru the existing roof hatch
 - o Landscaping and mowing will be consistent and continue with existing facility landscaping and mowing plans.

Decommissioning

Please see attached Decommissioning Plan Exhibit

Safety

Dynamic Energy follows all OSHA regulations and will provide a detailed project specific safety plan that will be followed during construction and available for inspection. A copy of the safety plan is available upon request. The solar array will be enclosed behind a locked fence to be installed during construction per NEC code.

Community Benefits

The solar array is primarily an electrical system and therefore will require licensed electricians to install a large portion of the equipment. Dynamic Energy will be working with local contractors which will provide direct and indirect economic benefit to the local community. This will provide jobs for local contractors throughout the project and provide training which can support their work on future installations with the experience gained on this project.

Operation and Maintenance Plan

Operations and maintenance shall begin once the Utility has provided approval to operate the solar system. The maintenance schedule will consist of regular site visits within the first ninety (90) days of the system operation with one (1) report and base line reading for all electrical equipment to be completed at ninety (90) days. The ninety (90) day report will be the beginning of the bi-annual maintenance service. The maintenance shall be scheduled for every six (6) months starting in April or October depending on which is closer to the date of the ninety (90) day report.

Access to the site shall be provided from the planned access road off Route 11. Locks shall be installed on all new gates. Access shall be provided to the local Fire Department with the use of a lock box located outside of the most exterior gate.

The following tasks will be conducted during inspections:

1. Repairs to the solar energy collecting and distribution equipment will be made as needed. For the inverters, this will include:
 - a. Evaluating the invertors and equipment following installation to confirm proper installation.
 - b. Confirm the inverters are secure and properly grounded.
 - c. Confirm the termination is to manufacturer specifications.
 - d. Confirm all wires are color coded correctly and remain protected from physical damage.
 - e. Confirm the equipment is free from debris, moisture, rust and damage.
 - f. Confirm the inverters seals are intact.
 - g. Confirm Arc shields are installed.
 - h. Confirm placards are installed.
 - i. Maintain service clearance to the inverters and maintain access to all filters.
 - j. Confirm the ground fault fuses are intact and check any fault codes that are displayed.
 - k. Evaluate any thermal anomalies observed.
 - l. Annually, an IV Curve Trace will be conducted and inferred scans.
2. Inspections of the solar array and connecting infrastructure will be made by the maintenance contractor during each visit.
3. Any erosion shall be repaired and stabilized.

List of Exhibits

- Exhibit A: Project Plans & Layout
- Exhibit B: Zoning Map & Card
- Exhibit C: Utility Impact Study
- Exhibit D: Street Views & Overhead Perspective
- Exhibit E: FEMA Flood Map
- Exhibit F: Aquifer Map
- Exhibit G: Water Classification Map
- Exhibit H: CT Environmental Land Restriction Map
- Exhibit I: Northern Long Eared Bat Map
- Exhibit J: Wetland Map
- Exhibit K: Critical Habitat Map
- Exhibit L: Decommissioning Plan
- Exhibit M: Structural Analysis
- Exhibit N: Equipment Spec Sheets
- Exhibit O: Production Analysis

Pat Hastings

From: Anderson, Stephen <Stephen.Anderson@ct.gov>
Sent: Thursday, November 18, 2021 4:33 PM
To: Weimar, Cameron
Cc: Pat Hastings
Subject: RE: Milford, CT Rooftop Solar Project - CT Citing Council

Hi Pat,

I did get confirmation on this, the 2 megawatt cutoff if based on AC, not DC so no letter required on this one.

Steve

From: Weimar, Cameron <Cam.Weimar@ct.gov>
Sent: Thursday, November 18, 2021 2:40 PM
To: Anderson, Stephen <Stephen.Anderson@ct.gov>
Cc: phastings@dynamicenergy.com; Morris, Crystal <Crystal.Morris@ct.gov>
Subject: FW: Milford, CT Rooftop Solar Project - CT Citing Council
Importance: High

Dear Pat,

Thank you for your request, I am forwarding it to Steve Anderson of our office, who handles our agency's solar petitions.

Hope this note finds you and your family well. Best, Cam

Cameron Weimar, Ph.D.
cam.weimar@ct.gov 860 888 0130
Farmland Preservation Program
Connecticut Dept. of Agriculture
www.ctgrown.gov

CONFIDENTIALITY NOTICE: This e-mail message, including attachments, may contain information that is confidential, legally privileged, and/or exempt from disclosure under applicable law. It is intended only for the use of the individual(s) and entity(s) named as recipients in this message. If you are not an intended recipient of this message, please notify the sender immediately and delete this message. Any unauthorized review, use, disclosure, copy, or distribution is prohibited. If you receive this message in error, please do not disclose its contents or take action in reliance on the information it contains.

Click here if you have questions about COVID-19 testing for your farm employees:

[Testing Farm Employees](#) [COVID Resources for Farmers](#) COVID questions: Email us at AGR.COVID19@ct.gov



From: Pat Hastings <phastings@dynamicenergy.com>
Sent: Thursday, November 18, 2021 1:02 PM

To: Weimar, Cameron <Cam.Weimar@ct.gov>
Cc: Morris, Crystal <Crystal.Morris@ct.gov>
Subject: Milford, CT Rooftop Solar Project - CT Citing Council
Importance: High

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click any links or open any attachments unless you trust the sender and know the content is safe.

Good Afternoon,

I am reaching out to request some help with a requirement needed to request a petition for declaratory ruling for a Rooftop Solar PV Project located at 40 Pepe Farm Road, Milford, CT.
As part of the declaratory ruling application/request to the CT Citing Council, given the size of this project (2.1 MW DC) we need to provide a letter from the CT Dept of Agriculture that this project will not have any material impact on prime farmland. I seek your assistance in providing such letter/notice.

I hope that this will be an easy task for you as this project is going to be located on a roof of an existing building on an already developed light industrial zoned project.

I have attached some more details to help with this request.

Thanks.

Pat Hastings
SVP, PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com
1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087
phastings@dynamicenergy.com



CONFIDENTIALITY: This email, including its attachments, contains information that is confidential and proprietary. Disclosure or use of such material without the written permission of Dynamic Energy is prohibited. If you received this email in error, please notify the sender by return e-mail and delete this email from your system. Thank you

Pat Hastings

From: Martin, Christopher <Christopher.Martin@ct.gov>
Sent: Friday, November 19, 2021 8:35 AM
To: Pat Hastings
Cc: DEEP Forestry
Subject: RE: Milford, CT Rooftop Solar Project - CT Citing Council

Thank you for inquiring about core forest impact determination. Connecticut General Statutes only requires the Department to issue a letter regarding core forest material affect if clearing of trees is called for within the project proposal. Since this is roof top proposal on an existing building a letter from DEEP is not required.

[Chapter 277a - Public Utility Environmental Standards Act](#)

Sec. 16-50k. Certificate of environmental compatibility and public need. Transfer. Amendment. Excepted matters. Waiver.

(iii) for a solar photovoltaic facility with a capacity of two or more megawatts, **to be located on** prime farmland **or forestland**, excluding any such facility that was selected by the Department of Energy and Environmental Protection in any solicitation issued prior to July 1, 2017, pursuant to section 16a-3f, 16a-3g or 16a-3j, the Department of Agriculture represents, in writing, to the council that such project will not materially affect the status of such land as prime farmland or the Department of Energy and Environmental Protection represents, in writing, to the council that such project will not materially affect the status of such land as core forest.

Christopher R. Martin
Director/State Forester
Division of Forestry
Bureau of Natural Resources
Connecticut Department of Energy and Environmental Protection
79 Elm Street, Hartford, CT 06106-5127
Office: 860.424-3631, Mobile: 860-463-8702 | E: christopher.martin@ct.gov



www.ct.gov/deep

*Conserving, improving and protecting our natural resources and environment;
Ensuring a clean, affordable, reliable, and sustainable energy supply.*

www.ct.gov/deep/forestry

From: Pat Hastings <phastings@dynamicenergy.com>
Sent: Thursday, November 18, 2021 1:39 PM

To: DEEP Forestry <DEEP.Forestry@ct.gov>
Cc: Martin, Christopher <Christopher.Martin@ct.gov>
Subject: Milford, CT Rooftop Solar Project - CT Citing Council
Importance: High

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click any links or open any attachments unless you trust the sender and know the content is safe.

Good Afternoon,

I am reaching out to request some help with a requirement needed to request a petition for declaratory ruling for a Rooftop Solar PV Project located at 40 Pepe Farm Road, Milford, CT.
As part of the declaratory ruling application/request to the CT Citing Council, given the size of this project (2.1 MW DC) we need to provide a letter from the CT DEEP that this project will not have any material impact on core forest. I seek you assistance in providing such letter/notice.

I hope that this will be an easy task for you as this project is going to be located on a roof of an existing building on a already developed light industrial zoned project.

I have attached some more details to help with this request.

Thanks.

Pat Hastings
SVP, PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com
1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087
phastings@dynamicenergy.com



CONFIDENTIALITY: This email, including its attachments, contains information that is confidential and proprietary. Disclosure or use of such material without the written permission of Dynamic Energy is prohibited. If you received this email in error, please notify the sender by return e-mail and delete this email from your system. Thank you

Notice List

Connecticut Department of
Administrative Services
165 Capitol Avenue, Suite 8
Hartford, CT 06106

Connecticut Department of Emergency
Services and Public Protection
1111 Country Club Road
Middletown, CT 06457

Connecticut Department of Economic
and Community Development
450 Columbus Boulevard
Hartford, CT 06103

Connecticut Public Utilities
Regulatory Authority
Ten Franklin Square
New Britain, CT 06051

Connecticut Council on Environmental
Quality
79 Elm Street
Hartford, CT 06106

Connecticut Department of Energy
and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Connecticut Department of Labor
200 Folly Brook Boulevard
Wethersfield, CT 06109

Connecticut Department of Consumer
Protection
450 Columbus Boulevard, Suite 901
Hartford, CT 06103

Connecticut DOT
2800 Berlin Turnpike P.O. Box
317546
Newington, CT 06131-7546

Connecticut Office of Policy and
Management
450 Capitol Avenue
Hartford, CT 06106

Connecticut Department of
Agriculture
450 Columbus Boulevard, Suite 701
Hartford, CT 06103

Connecticut Department of Public
Health
410 Capitol Avenue
Hartford, CT 06106

Capitol Region Council of
Governments
241 Main Street
Hartford CT 06106-5310

James J. Maroney
State Senator, District S14
Legislative Office Building
LOB Room 3300
Hartford, CT 06106-1591

Kathy Kennedy
Milford State Representative
Legislative Office Building, Room 4200
300 Capitol Avenue
Hartford 06106

City of Milford
110 River St
Milford, CT 06460

KC Funding LLC
PO Box 253
Milford, CT 06460

Louis Damato
183 Quarry Road
Milford, CT 06460

Benjamin G. Blake, Mayor
70 West River Street
Milford, CT 06460

MaryRose Palumbo, Milford Inland
Wetland Officer
70 West River Street
Milford, CT 06460

Conservation Commission
Attn: Jeremy Grant, Staff Liason
70 West River Street
Milford, CT 06460

Milford Planning and Zoning Board
Attn: Susan LaFond
70 West River Street
Milford, CT 06460

CT Attorney General William Tong
165 Capitol Ave
Hartford, CT 06106



November 17, 2021

Connecticut Department of Administrative Services
165 Capitol Avenue, Suite 8
Hartford, CT 06106

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Emergency Services and Public Protection
1111 Country Club Road
Middletown, CT 06457

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Economic and Community Development
450 Columbus Boulevard
Hartford, CT 06103

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Public Utilities Regulatory Authority
Ten Franklin Square
New Britain, CT 06051

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

Connecticut Council on Environmental Quality
79 Elm Street
Hartford, CT 06106
Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Energy and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Labor
200 Folly Brook Boulevard
Wethersfield, CT 06109

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Consumer Protection
450 Columbus Boulevard, Suite 901
Hartford, CT 06103

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Transportation
2800 Berlin Turnpike P.O. Box 317546
Newington, CT 06131-7546

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Office of Policy and Management
450 Capitol Avenue
Hartford, CT 06106

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Agriculture
450 Columbus Boulevard, Suite 701
Hartford, CT 06103

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Connecticut Department of Public Health
410 Capitol Avenue
Hartford, CT 06106

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

Capitol Region Council of Governments
Executive Director Lyle Wray
241 Main Street
Hartford CT 06106-5310

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

James J. Maroney
State Senator, District S14
Legislative Office Building
LOB Room 3300
Hartford, CT 06106-1591

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

Kathy Kennedy
Milford State Representative
Legislative Office Building, Room 4200
300 Capitol Avenue
Hartford 06106

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

City of Milford
110 River St
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

KC Funding LLC
PO Box 253
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Louis Damato
183 Quarry Road
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com



November 17, 2021

Benjamin G. Blake, Mayor
70 West River Street
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

MaryRose Palumbo, Milford Inland Wetland Officer
70 West River Street
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

Conservation Commission
Attn: Jeremy Grant, Staff Liason
70 West River Street
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

Milford Planning and Zoning Board
Attn: Susan LaFond
70 West River Street
Milford, CT 06460

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

November 17, 2021

CT Attorney General William Tong
165 Capitol Ave
Hartford, CT 06106

Re: 40 Pepe Farms Road, Milford, CT – Proposed Rooftop Solar PV Project

To Whom It May Concern,

The purpose of this letter is to provide notice of intent to file a Petition for Declaratory Ruling for a renewable energy facility with the CT Citing Council for a 2.1 MW Roof Top Solar PV Project on the existing building/roof located at 40 Pepe Farms Road, Milford, CT (Zoned LI). This notice is required to be made as part of that request. The application to the CT Citing Council will be made on or around 11/19/2021.

If you have any question or concerns, please feel free to contact me at any time.

Pat Hastings

SVP. PROJECT ENGINEERING & DELIVERY

O: 484.323.1155 | M: 484.467.4683 | dynamicenergy.com

1550 Liberty Ridge Drive, Suite 310, Wayne, PA 19087

phastings@dynamicenergy.com

7018 1130 0001 2703 3924

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06103

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Consumer Protection
450 Columbus Boulevard, Suite 901
Hartford, CT 06103

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3917

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

New Britain, CT 06131

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut DOT
2800 Berlin Turnpike P.O. Box 317546
Newington, CT 06131-7546

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3931

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Wethersfield, CT 06109

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Labor
200 Folly Brook Boulevard
Wethersfield, CT 06109

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3986

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Middletown, CT 06457

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Emergency Services and Public Protection
1111 Country Club Road
Middletown, CT 06457

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3962

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

New Britain, CT 06051

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Public Utilities Regulatory Authority
Ten Franklin Square
New Britain, CT 06051

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3900

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Office of Policy and Management
450 Capitol Avenue
Hartford, CT 06106

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3894

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06103

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Agriculture
450 Columbus Boulevard, Suite 701
Hartford, CT 06103

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3993

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Administrative Services
165 Capitol Avenue, Suite 8
Hartford, CT 06106

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3867

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Public Health
410 Capitol Avenue
Hartford, CT 06106

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3979

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06103

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Department of Economic and Community Development
450 Columbus Boulevard
Hartford, CT 06103

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3856

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Kathy Kennedy
Milford State Representative
Legislative Office Building, Room 4200
300 Capitol Avenue
Hartford 06106

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3801

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Milford, CT 06460

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

MaryRose Palumbo, Milford Inland Wetland Officer
70 West River Street
Milford, CT 06460

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3832

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Milford, CT 06460

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

KC Funding LLC
PO Box 253
Milford, CT 06460

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3788

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Milford, CT 06460

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Milford Planning and Zoning Board
Attn: Susan LaFond
70 West River Street
Milford, CT 06460

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3955

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)	\$7.05	
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

11/18/2021

Connecticut Council on Environmental Quality
79 Elm Street
Hartford, CT 06106

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

7018 1130 0001 2703 3849
448E E022 1000 DE1T 9102

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT
Domestic Mail Only

For delivery information, visit our website at www.usps.com™.

City of Milford
110 River St
Milford, CT 06460

Certified Mail Fee

\$3.75

Extra Services & Fees (check box, add fee to total cost)


<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00
<input type="checkbox"/> Return Receipt (electronic)	\$0.00
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00
<input type="checkbox"/> Adult Signature Required	\$0.00
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00

Postage

\$0.58

\$7.38

City of Milford
110 River St
Milford, CT 06460



U.S. Postal Service™
CERTIFIED MAIL® RECEIPT

Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)		
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

NOV 18 2021

James J. Marshall
State Senator, District S14
Legislative Office Building
LOB Room 3300
Hartford, CT 06106-1591

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT

Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)		
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

NOV 18 2021

CT Attorney General William Tong
165 Capitol Ave
Hartford, CT 06106

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT

Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

Milford, CT 06460

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)		
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

NOV 18 2021

Benjamin G. Blake, Mayor
70 West River Street
Milford, CT 06460

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT

Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)		
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

NOV 18 2021

Connecticut Department of Energy
and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT

Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

Hartford, CT 06106

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)		
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

NOV 18 2021

Capitol Region Council of
Governments
241 Main Street
Hartford CT 06106-5310

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

U.S. Postal Service™
CERTIFIED MAIL® RECEIPT

Domestic Mail Only

For delivery information, visit our website at www.usps.com®.

Milford, CT 06460

OFFICIAL USE

Certified Mail Fee	\$3.75	0822 27
Extra Services & Fees (check box, add fee as appropriate)		
<input type="checkbox"/> Return Receipt (hardcopy)	\$0.00	
<input type="checkbox"/> Return Receipt (electronic)	\$0.00	
<input type="checkbox"/> Certified Mail Restricted Delivery	\$0.00	
<input type="checkbox"/> Adult Signature Required	\$0.00	
<input type="checkbox"/> Adult Signature Restricted Delivery	\$0.00	
Postage	\$0.58	
Total	\$7.38	

Postmark Here

NOV 18 2021

Louis Damato
183 Quarry Road
Milford, CT 06460

PS Form 3800, April 2015 PSN 7530-02-000-9047 See Reverse for Instructions

List of Exhibits

- Exhibit A: Project Plans & Layout
- Exhibit B: Zoning Map & Card
- Exhibit C: Utility Impact Study
- Exhibit D: Street Views & Overhead Perspective
- Exhibit E: FEMA Flood Map
- Exhibit F: Aquifer Map
- Exhibit G: Water Classification Map
- Exhibit H: CT Environmental Land Restriction Map
- Exhibit I: Northern Long Eared Bat Map
- Exhibit J: Wetland Map
- Exhibit K: Critical Habitat Map
- Exhibit L: Decommissioning Plan
- Exhibit M: Structural Analysis
- Exhibit N: Equipment Spec Sheets
- Exhibit O: Production Analysis

Exhibit A

STAG INDUSTRIAL HOLDINGS

40 PEPES FARM ROAD
MILFORD, CT 06460

STAG INDUSTRIAL HOLDINGS
40 PEPES FARM ROAD
MILFORD, CT 06460

DRAWING ISSUE
☐ INTERCONNECTION
☒ PERMITTING
☐ CONSTRUCTION
☐ RECORD

REV	DATE	DESCRIPTION	BY	APP'D
1	08-16-2021	PERMIT SET ISSUED		
2	08-27-2021	LAYOUT REVISED		
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
32				
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				
60				
61				
62				
63				
64				
65				
66				
67				
68				
69				
70				
71				
72				
73				
74				
75				
76				
77				
78				
79				
80				
81				
82				
83				
84				
85				
86				
87				
88				
89				
90				
91				
92				
93				
94				
95				
96				
97				
98				
99				
100				

DRAWING NAME

COVERSHEET

DRAWING NUMBER

G001

SYSTEM DESCRIPTION

TOTAL SYSTEM SIZE: 2112 kW DC STC TOTAL
MODULE TYPE: 400W JA SOLAR
QUANTITY: 5280 MODULES
TOTAL STRINGS: 330 STRINGS
MODULES PER STRING: 16
TILT ANGLE: 10.0 DEGREES
AZIMUTH: 143.544 DEGREES

MODULE DESCRIPTION:
MAXIMUM POWER (W): 400 W
OPEN CIRCUIT VOLTAGE (Voc): 49.57 V
MAXIMUM POWER VOLTAGE (Vpm): 42.02 V
SHORT CIRCUIT CURRENT (Isc): 10.14 A
MAXIMUM POWER CURRENT (Ipm): 9.52 A
EFFICIENCY (%): 19.5 %
MAXIMUM SYSTEM VOLTAGE: 1500 VDC

INVERTER DESCRIPTION: CHINT POWER SYSTEMS
TYPE OF INVERTER: 50KW
TOTAL NUMBER OF INV: 30
MODEL NUMBER: CPS-SCA50KTL
DIMENSIONS: 1000*600*260mm
CONTINUOUS POWER: 50KW
DC PEAK POWER TRACKING RANGE: 480-850V
CEC PEAK EFFICIENCY: 98.5%

RACKING DESCRIPTION:
RACKING MANUFACTURER: DCE SOLAR
RACKING TYPE: BALLASTED


PROJECT CONTACTS

PROJECT MANAGER:
MANOLI ALLEXOPOULOS
1550 LIBERTY RIDGE DR., STE 310
WAYNE, PA 19087
PHONE: (717) 951-0518


CONSTRUCTION MANAGER:
MANOLI ALLEXOPOULOS
1550 LIBERTY RIDGE DR., STE 310
WAYNE, PA 19087
PHONE: (717) 951-0518

ELECTRICAL ENGINEER:
HENDRIK BURGER
1550 LIBERTY RIDGE DR., STE 310
WAYNE, PA 19087
PHONE: (484) 323-1154
LICENCE#: 31153

STRUCTURAL ENGINEER
JAMES A MARX, P.E.
10 HIGH MOUNTAIN ROAD
RINGWOOD, NJ 07456
ASCENT CONSULTING ENGINEERING
NORTH WINDS CENTER
LICENCE#: CT (NO. 17349)



1 AERIAL PHOTO
SCALE: N.T.S.



2 VICINITY MAP
SCALE: N.T.S.

DRAWING LIST

G001 COVER SHEET
SPECIFICATIONS:
G002 GENERAL & CONSTRUCTION NOTES
G003 CONSTRUCTION NOTES (CONTINUED)
G004 CONSTRUCTION NOTES (CONTINUED)
STRUCTURAL:
S100 BUILDING OVERVIEW
S101 EXISTING STRUCTURAL LAYOUT & DETAILS
S101.1 EXISTING STRUCTURAL LAYOUT & DETAILS (CONT.)

ELECTRICAL:
E100 PV PANEL & EQUIPMENT LAYOUT
E100.1 PV PANEL & RACKING LAYOUT
E101 INVERTER, RACKING & CONDUIT DETAILS
E102 PV PANEL & PANELBOARD SUPPORT DETAILS
E200 ONE-LINE DIAGRAM
E201 ONE-LINE LEGENDS & SETTINGS
E202 STRING LAYOUT & COMBINING ARCHITECTURE
E202.1 STRING LAYOUT & COMBINING ARCHITECTURE
E203 CALCULATION & EQUIPMENT SCHEDULE
E204 TYPICAL PV-GROUNDING DIAGRAM
E300 INVERTER DETAILS
E301 MODULE DETAILS
E400 EQUIPMENT PLACARD LOCATIONS
E401 EQUIPMENT PLACARD LOCATIONS
E402 EQUIPMENT LABELS
E500 STAGING PLAN

DESIGN CRITERIA:
WIND SPEED: 123 MPH EXP.B
GROUND SNOW LOAD: 30 PSF
ROOF SNOW LOAD: 30 PSF

APPLICABLE CODES
2018 CONNECTICUT STATE
BUILDING CODE
ELECTRICAL CODE NFPA 70, 2017 ED,

HENDRIK J. BURGER
PROFESSIONAL ENGINEER
1368 SHEEP HILL ROAD
POTTSTOWN, PA 19465

SEAL

2. PERMISSION TO OPERATE THE SYSTEM IS NOT AUTHORIZED UNTIL FINAL INSPECTIONS AND APPROVALS ARE OBTAINED FROM THE LOCAL AUTHORITY HAVING JURISDICTION AND THE LOCAL UTILITY SERVICE PROVIDER.
3. THE METHOD OF ATTACHMENT CREATES A UNIFIED STRUCTURE TO MEET DEAD LOAD, WIND LOAD, AND SEISMIC REQUIREMENTS. SOLAR MODULES WILL BE SECURED TO THE EXISTING ROOF AS SPECIFIED ON THE STRUCTURAL SHEETS. EXISTING ROOF EQUIPMENT WILL NOT BE EFFECTED BY THE PV SYSTEM.
4. ALL FABRICATION AND MANUFACTURING SHALL BE PERFORMED BY CERTIFIED INDIVIDUALS IN APPROVED ASSEMBLY AND FABRICATION SHOPS PRIOR TO COMMENCEMENT OF ANY WORK. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCIES NOTED AMONG SITE CONDITIONS, MANUFACTURER RECOMMENDATIONS, OR AUTHORITY HAVING JURISDICTION.
5. THIS PROPOSED SOLAR ELECTRIC POWER IS INTENDED TO OPERATE IN PARALLEL WITH POWER RECEIVED FROM THE UTILITY SERVICE PROVIDER.
6. IF THIS SYSTEMS IS INTENDED TO CONNECT TO THE EXISTING FACILITY POWER SYSTEM AT ONE POINT, POINT OF COMMON COUPLING (POCC). THIS CONNECTION SHALL BE IN COMPLIANCE WITH THE NEC ARTICLE 705.12 'POINT OF CONNECTION'. CONNECTIONS DIRECT TO GRID SHALL BE IN ACCORDANCE TO THE DRAWINGS AND APPLICABLE NEC AND UTILITY CODES.
7. THE CONTRACTOR SHALL COMPLY WITH ALL LOCAL, STATE AND NATIONAL CODES AND UTILITY COMPANY STANDARDS AS WELL AS THE REQUIREMENTS OF ALL PERMITS OBTAINED.
8. ALL MATERIALS SUPPLIED AND ALL WORK INSTALLED MUST COMPLY WITH OR EXCEED THE MINIMUM REQUIREMENTS SET FORTH BY THE NFPA, NEC, ANY LOCAL CODES AND UTILITY COMPANY REQUIREMENTS.
9. CAUTION SHALL BE TAKEN WHEN MOUNTING ASSOCIATED ELECTRICAL EQUIP. AND MECHANICAL EQUIPMENT SO IT DOES NOT SHADE THE ARRAY AT ANY TIME DAY OR YEAR..
10. EQUIPMENT SHALL BE INSTALLED IN A SECURE AREA.
11. MATERIALS USED OUTDOORS SHALL BE SUNLIGHT/UV RESISTANT.
12. MATERIALS SHALL BE DESIGNED TO WITHSTAND THE TEMPERATURES TO WHICH THEY ARE EXPOSED.
13. ONLY HIGH QUALITY FASTENERS SHALL BE USED (STAINLESS STEEL OR EQUIVALENT).
14. THE PV SYSTEM IS EXPECTED TO BE AS AESTHETICALLY PLEASING AS POSSIBLE AND SHOULD BE CONSTRUCTED WITH GOOD WORKMANSHIP AND CARE.
15. CONTRACTOR SHALL LIMIT HIS USE OF THE PREMISES FOR WORK, INCLUDING STORAGE TO ALLOW FOR OTHER CONTRACTORS WORK, OWNER OCCUPANCY AND PUBLIC USE. IN THE COURSE OF PERFORMING THE WORK, CONTRACTORS SHALL KEEP THE WORK AREA IN A CONDITION SUITABLE FOR THE PERFORMANCE OF THE OWNER'S DAILY FUNCTIONS. THE APPEARANCE OF THESE AREAS WILL BE SUBJECT TO APPROVAL BY OWNER. TAKE ALL PRECAUTIONS NECESSARY TO PROTECT OWNER'S FURNITURE AND EQUIPMENT IN WORK AREAS.
16. CONTRACTOR SHALL MAINTAIN A RECORD SET OF DRAWINGS SHOWING ALL CHANGES DURING THE CONSTRUCTION PROCESS. DELIVER THESE RECORD DRAWINGS TO DYNAMIC ENERGY AT COMPLETION OF PROJECT.
17. FIRESTOPPING
 - a. WHERE CONDUITS AND OTHER ELECTRICAL RACEWAYS PASS THROUGH FIRE PARTITIONS, FIRE WALLS OR FLOORS, INSTALL A UL LISTED FIRE-STOP THAT PROVIDES AN EFFECTIVE BARRIER AGAINST THE SPREAD OF FIRE, SMOKE AND GASES. FIRE-STOP MATERIALS SHALL BE PACKED TIGHT, AND COMPLETELY FILL CLEARANCES BETWEEN RACEWAYS AND OPENINGS. FIRE-STOP MATERIALS SHALL CONFORM TO THE FOLLOWING:
 - a.1. FIRESTOPPING MATERIAL SHALL MAINTAIN ITS DIMENSION AND INTEGRITY WHILE PREVENTING THE PASSAGE OF FLAME, SMOKE AND GASES UNDER CONSTRUCTIONS OF INSTALLATION AND USE WHEN EXPOSED TO THE ASTM 119 TIME-TEMPERATURE CURVE FOR A TIME PERIOD EQUIVALENT TO THE RATING OF THE ASSEMBLY PENETRATED. COTTON WASTE SHALL NOT IGNITE WHEN PLACED IN CONTACT WITH THE NON-FIRE SIDE DURING THE TEST. FIRESTOPPING MATERIAL SHALL BE NON-COMBUSTIBLE AS DEFINED BY ASTM E136 AND IN ADDITION, FOR INSULATION MATERIALS, MELT POINT SHALL BE A MINIMUM OF 1700 DEGREES FAHRENHEIT FOR 2-HOUR PROTECTION.
 - a.2. MATERIALS SHALL BE 3M FIRE BARRIER, THOMAS AND BETTS FLAME SAFE, OR NELSON ELECTRIC FIRESTOP.
18. ALL SOLAR MODULES SHALL BE LISTED 1703. ALL INVERTERS SHALL BE UL LISTED 1741 CERTIFIED. ALL ELECTRICAL COMPONENTS AND MATERIALS SHALL BE LISTED FOR ITS PURPOSE AND INSTALLED IN A WORKMANLIKE MANNER. ALL OUTDOOR EQUIPMENT SHALL MEET APPROPRIATE NEMA STANDARDS.
18. ALL MATERIALS AND EQUIPMENT FOR THE WORK SHALL BE NEW UNLESS OTHERWISE SPECIFIED. ALL MATERIAL SHALL BE SUBJECT TO APPROVAL BY A DYNAMIC ENERGY.

1. ALL WASTE MATERIALS SHALL BE COLLECTED AND DISPOSED OF INTO METAL TRASH DUMPSTERS IN THE MATERIALS STORAGE AREA.
2. DUMPSTERS SHALL BE PLACED AWAY FROM STORMWATER CONVEYANCES AND DRAINS AND MEET ALL FEDERAL, STATE, AND MUNICIPAL REGULATIONS.
3. ONLY TRASH AND CONSTRUCTION DEBRIS FROM THE SITE SHALL BE DEPOSITED IN THE DUMPSTER.
4. NO CONSTRUCTION MATERIALS SHALL BE BURIED ONSITE.
5. ALL PERSONNEL SHALL BE INSTRUCTED REGARDING THE CORRECT DISPOSAL OF TRASH AND CONSTRUCTION DEBRIS.
6. ALL HAZARDOUS WASTE MATERIALS SUCH AS OIL FILTERS, PETROLEUM PRODUCTS, PAINT, AND EQUIPMENT MAINTENANCE FLUIDS SHALL BE DISPOSED OF IN ACCORDANCE WITH FEDERAL, STATE, AND MUNICIPAL REGULATIONS.
7. WHEN ANY DIRECT OR INDIRECT DAMAGE OR INJURY IS DONE TO PUBLIC OR PRIVATE PROPERTY BY OR ON ACCOUNT OF ANY ACT, OMISSION, NEGLIGENCE, OR MISCONDUCT IN THE EXECUTION OF THE WORK OR IN CONSEQUENCE OF THE NON-EXECUTION THEREOF ON THE PART OF CONTACTOR, SUCH PROPERTY SHALL BE RESTORED AT CONTACTOR EXPENSE TO A CONDITION SIMILAR OR EQUAL TO THAT EXISTING BEFORE SUCH DAMAGE OR INJURY WAS DONE.
8. OWNERS, EMPLOYEES, OR AGENTS OF PUBLIC OR PRIVATE SERVICES LOCATED WITHIN THE PROJECT LIMITS SHALL BE ALLOWED FREE AND FULL ACCESS WITH THE TOOLS, MATERIALS, AND EQUIPMENT NECESSARY TO INSTALL, OPERATE, MAINTAIN, PLACE, REPLACE, RELOCATE, AND REMOVE SERVICE FACILITIES. NO COMPENSATION WILL BE PAID TO CONTACTOR FOR ANY INCONVENIENCE CAUSED BY WORKING WITH THESE PARTIES OR AROUND OR WITH THEIR SERVICES.
9. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL DAMAGES DONE TO SERVICES FROM THE BEGINNING OF CONSTRUCTION TO THE SATISFACTORY COMPLETION OF THE PROJECT, INCLUDING ALL DAMAGES TO WATER SUPPLIES AND SEWAGE SYSTEMS, INCLUDING BUT NOT LIMITED TO DAMAGE TO SPRINGS AND WELLS, SEPTIC TANKS, CESSPOOLS, AND UNDERGROUND PIPES, WHETHER LOCATED WITHIN OR OUTSIDE THE PROJECT RIGHT-OF-WAY OR WHETHER OR NOT SHOWN ON THE PLANS.
10. CONTRACTOR SHALL, WITHOUT CHARGE, REPLACE ANY WORK OR MATERIAL, WHICH DEVELOPS DEFECTS, EXCEPT ORDINARY WEAR AND TEAR, OR FAIL TO PERFORM SATISFACTORYLY WITHIN 1 YEAR FROM DATE OF FINAL ACCEPTANCE. THIS PERTAINS TO VENDOR PROVIDED MATERIAL AND WORKMANSHIP.

1. INSTALL EQUIPMENT, CONDUIT, AND WIRING ACCORDING TO DYNAMIC ENERGY'S APPROVED PLANS AND THE PROVIDED MANUFACTURER'S INSTALLATION MANUALS.
2. A COPY OF THE APPROVED PERMIT PLANS SHALL BE AVAILABLE AT THE SITE FOR THE INSPECTOR'S USE DURING FIELD INSPECTION AND POSTED AS DICTATED BY THE AHJ.
3. ALL MATERIALS AND EQUIPMENT FOR THE WORK SHALL BE NEW, UNLESS OTHERWISE SPECIFIED. ALL MATERIAL SHALL BE SUBJECT TO APPROVAL BY DYNAMIC ENERGY.
4. CONTRACTOR SHALL PROVIDE ALL CUTTING, PATCHING, CONDUIT SLEEVES, EXCAVATION, BACKFILL, AND CONCRETE WORK.
 - a. REVIEW WITH DYNAMIC ENERGY CONSTRUCTION MANAGER, THE LOCATION AND SIZE OF OPENINGS TO BE CUT INTO EXISTING CONSTRUCTION BEFORE STARTING OF CUTTING WORK.
 - b. ALL CUTTING, ROUGH PATCHING AND FINISH PATCHING REQUIRED SHALL BE PROVIDED BY THE CONTRACTOR.
 - c. WHERE CONDUITS PASS THROUGH MASONRY OR CONCRETE WALLS, FOUNDATIONS OR FLOORS, THE CONTRACTOR SHALL SET SUCH SLEEVES AS ARE NECESSARY FOR PASSAGE OF THE CONDUITS. SLEEVES SHALL BE SCHEDULE 40 GALVANIZED STEEL OF SUFFICIENT SIZE TO PROVIDE AIR SPACE AROUND THE CONDUIT PASSING THROUGH FOR FIREPROOFING. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE EXACT LOCATION OF SLEEVES PROVIDED UNDER HIS CONTRACT.
 - d. CORE DRILL ALL OPENINGS REQUIRED IN EXISTING CONSTRUCTION USING A DRILL STOP FOR INSTALLATION OF EQUIPMENT AND MATERIAL.
 - e. PROVIDE ALL EXCAVATION AND BACKFILL REQUIRED FOR WORK OF THIS PROJECT.
5. CONTRACTOR SHALL INSTALL ALL LABELS FOR CONDUITS CABLE TRAY, ETC. AS REQUIRED BY THE CURRENT NEC CODE.
6. CONTRACTOR INITIATED CHANGES SHALL BE SUBMITTED IN WRITING TO THE ENGINEER IN THE FORM OF A DESIGN CHANGE REQUEST FOR INFORMATION PRIOR TO MAKING ANY CHANGES. APPROVED CHANGES SHALL REQUIRE A DRAWING REVISION TO MAINTAIN CONTROL OVER THE ENGINEER APPROVED DESIGN. THE ELECTRICAL CONTRACTOR IS ADVISED THAT ALL DRAWINGS AND COMPONENT MANUALS ARE TO BE UNDERSTOOD PRIOR TO INSTALLATION. THE CONTRACTOR IS ADVISED TO HAVE ALL SWITCHES IN THE 'OFF' POSITION AND FUSES REMOVED PRIOR TO INSTALLATION OF FUSE-BEARING COMPONENTS.
7. PROVIDE ALL CONCRETE REQUIRED FOR WORK OF THIS PROJECT.
8. COMMISSIONING OF THE COMPLETED INSTALLATION SHALL BE AS SPECIFIED IN THE CONTRACT AGREEMENT.

1. ALL FASTENERS SHALL BE CORROSION RESISTANT APPROPRIATE FOR SITE CONDITIONS. CONNECTORS SHALL BE TORQUED PER DEVICE LISTING OR ENGINEERING RECOMMENDATIONS. ALL ROOFING REPAIR MUST MAINTAIN EXISTING CLASS AND TYPE OF ROOF AND ALL WORK SHALL BE IN ACCORDANCE WITH THE ROOFING MANUFACTURER'S INSTALLATION REQUIREMENTS.
2. CABLE AND CONDUIT SHALL BE PROPERLY SUPPORTED , SHALL BE KEPT AT A MINIMUM 1" ABOVE ROOF SURFACE. SHALL NOT BE RUBBING ON ABRASIVE SURFACE I.E. ENDS OF RAILS, SHALL NOT BE PINCHED BETWEEN PANELS AND RAIL.
3. APPROPRIATE PROTECTION SHALL BE USED FOR ALL ROOF PENETRATIONS. CONTRACTORS SHALL HIRE OWNER'S ROOFING CONTRACTOR TO PROVIDE AND SEAL ALL ROOF PENETRATIONS.
4. CONDUITS PASSING THROUGH ROOFS OR OTHER SURFACES EXPOSED TO WEATHER SHALL BE PROPERLY FLASHED AND MADE WATER TIGHT.
5. PV WIRING SHALL BE SUPPORTED EVERY 24" OR AS PRACTICAL AND SHALL NOT TOUCH ANY ROOF SURFACES MANUFACTURED MODULE WIRES MUST BE SUPPORTED UNDER EVERY MODULE WITH STAINLESS STEEL CLIPS OR EQUIVALENT.
6. ALL ROOFTOP CONDUITS SHALL BE SUPPORTED BY THE HARD PLASTIC ROOF CADDY'S WHICH WILL KEEP THE CONDUIT AT A MINIMUM OF 4" ABOVE THE ROOF SURFACE HARD FOAM ROOF CADDY'S SHALL NOT BE USED WITHOUT APPROVAL FROM DYNAMIC ENERGY'S ENGINEER.
7. CONDUIT RUNS ON FLAT ROOFS SHOULD BE BALLASTED WHERE THEY MAY BE SUBJECT TO HIGH WINDS OR SHIFTING DUE TO ICE OR SNOW. THE BALLAST STRUCTURE MUST ALLOW THE CONDUIT TO EXPAND AND CONTRACT. BALLAST SPACING SHALL BE ON 20'-0" INTERVALS MAXIMUM. COORDINATE LOCATIONS WITH DYNAMIC ENERGY CONSTRUCTION MANAGER.
8. CONDUIT RUNS ON SLOPED ROOFS SHOULD BE SECURED IN SIMILAR FASHION AS ABOVE WITHOUT THE USE OF BALLASTING.COORDINATE METHOD AND LOCATIONS WITH DYNAMIC ENERGY CONSTRUCTION MANAGER.
9. CONDUITS RUNS SHALL BE TRANSITIONED TO SEALTITE WHEN RUN ON A ROOFTOP BETWEEN TWO STATIONARY TERMINATION POINTS TO ALLOW FOR EXPANSION AND CONTRACTION. SEALTITE SHALL NOT BE USED IN LENGTHS GREATER THAN 6'.
10. PVC CONDUIT SHALL NOT BE USED IN ANY RUN GREATER THAN 20' ON ROOFTOPS AND MUST HAVE THE ABILITY TO EXPAND AND CONTRACT
PVC IS GENERALLY USED AS PHYSICAL PROTECTION FOR EXPOSED PV WIRES PVC MUST BE SUPPORTED AT INTERVALS TO PREVENT SAGGING ALLOWING CONTACT WITH ROOF SURFACE.

EXISTING CEILINGS:

11. CONTRACTOR WILL BE RESPONSIBLE TO REMOVE AND REPLCAE EXISTING CEILING TILE AND GRID SYSTEM AFFECTING THE INSTALLATION OF EQUIPMENT AND MATERIAL ABOVE CEILING.
12. DAMAGED TILE SHALL BE BROUGHT TO OWNER'S ATTENTION PRIOR TO REMOVAL. FAILURE TO DO SO SHALL MAKE CONTRACTOR RESPONSIBLE FOR REPLACEMENT OF DAMAGED CEILING TILE AND GRID SYSTEM AT NO COST OF OWNER.
14. CONTRACTOR SHALL BE RESPONSIBLE TO DISCONNECT, REMOVE, REPLACE AND RECONNECT EXISTING LIGHTING FIXTURES,SPEAKERS ETC., IN AFFECTED WORK AREAS UNLESS NOTED OTHERWISE.

SEAL

STAG INDUSTRIAL HOLDINGS
40 PEPES FARM ROAD
MILFORD, CT 06460

[illegible]

ELECTRICAL:

MODULES:

1. PV MODULE MANUFACTURER'S INSTRUCTIONS SHALL BE CAREFULLY FOLLOWED WHEN HANDLING OR INSTALLING THE MODULES.
2. DO NOT INSTALL DAMAGED MODULES.
3. WHERE PLUG CONNECTORS ARE USED FOR MODULE WIRING, MAKE SURE THAT CONNECTORS ARE FULLY ENGAGED PLUG CONNECTORS MUST BE OF THE SAME MAKE AND MODEL AND LISTED FOR THEIR USE CONNECTORS FROM DIFFERING MANUFACTURERS SHALL NOT BE USED TOGETHER.
4. AT NO TIME IS IT ACCEPTABLE TO WALK ON, SIT ON, REST ON, OR DROP, MODULES. ANY TIME THAT THIS IS DONE THE CONTRACTOR WILL BE RESPONSIBLE FOR REPLACEMENT COST OF THE MODULES.

INVERTERS:

5. ANTI-ISLANDING PROTECTION IS A REQUIREMENT OF UL 1741 AND IS INTENDED TO PREVENT THE OPERATION OF THE PV SYSTEM WHEN THE UTILITY GRID IS NOT OPERATIONAL.
6. THE INVERTER FOR THE PROPOSED ELECTRIC SYSTEM SHALL BE IDENTIFIED FOR USE IN SOLAR PHOTOVOLTAIC SYSTEMS. ALL EQUIPMENT SHALL BE UL APPROVED.

BALANCE OF SYSTEM:

7. ALL SOURCE CIRCUITS SHALL HAVE INDIVIDUAL SOURCE CIRCUIT PROTECTION FOR TESTING AND ISOLATION. ALL COMBINER BOXES SHALL HAVE DISCONNECTING MEANS NEAR THE COMBINER FOR ISOLATION AND TESTING.
8. ALL DISCONNECTS AND COMBINER SHALL BE SECURED FROM UNAUTHORIZED/UNQUALIFIED PERSONNEL BY LOCK OR LOCATION.
9. ALL DISCONNECTS , COMBINERS , PULL/SPLICE BOXES , AND ENCLOSURES SHALL BE LISTED FOR ITS PURPOSE.
10. STRING HOMERUNS SHALL BE PROPERLY LABELED BY NUMBERS AT THE BEGINNING AND END OF EACH CIRCUIT AND AT ALL CONNECTIONS IN HOMERUN.
11. STRING NUMBERS SHALL MATCH CONSTRUCTION DRAWING AND BE IN CORRECT LOCATION IN ARRAY.
12. PV WIRING SHALL BE SUPPORTED EVERY 24" OR AS PRACTICAL AND SHALL NOT TOUCH ANY ROOF SURFACES. MANUFACTURED MODULE WIRES MUST BE SUPPORTED UNDER EVERY MODULE WITH STAINLESS STEEL CLIPS OR EQUIVALENT.
13. ALL CONDUITS AND CABLE TRAYS SHALL BE SUPPORTED AT INTERVALS AS DEFINED IN THE NEC.
14. ONLY HEAVY DUTY UV WIRE TIES WITH EXTREME HIGH AND LOW TEMPERATURE RATINGS SHALL BE USED IN ALL APPLICATIONS.
15. COMBINERS, PULL/SPLICE BOXES, AND ENCLOSURES SHALL BE LISTED FOR ITS PURPOSE.

CONDUIT:

16. PROVIDE EXPANSION FITTINGS IN CONDUIT RUNS PER NEC.
17. MEYERS HUBS SHALL BE USED FOR ANY CONDUIT PENETRATIONS ENTERING THE TOP OF ANY EXTERIOR ENCLOSURE. NEMA 4 ENCLOSURES OR GREATER WILL REQUIRE MEYERS HUB FOR ANY PENETRATION WHENEVER PRACTICAL. CONDUIT ENTRY IN THE BOTTOM, OF ENCLOSURES IS PREFERABLE. MEYERS HUB FITTINGS SHALL BE USED WITH RGS & IMC CONDUIT ONLY TO MAINTAIN GROUNDING AND WATER SEAL.
18. EMT OR GRC CONDUITS SHALL BE USED FOR ALL EXTERIOR APPLICATIONS FOR DC FEEDERS AND AC WIRING.
19. ALL METALLIC CONDUIT SHALL BE BONDED APPROPRIATELY AT ONE END(MINIMUM) AND WHENEVER USED IN CONCENTRIC KNOCK OUTS.
20. ONLY COMPRESSION COUPLINGS AND CONNECTORS APPROVED FOR WET LOCATION SHALL BE USED FOR EMT CONDUIT (EXTERIOR ONLY).
21. BUSHINGS SHALL BE USED AT CONDUIT TERMINATION POINTS PER NEC UNLESS THE CONNECTOR HAS A BUILT IN PLASTIC THROAT.
22. EXTREME CARE MUST BE TAKEN WHEN USING COMPRESSION COUPLINGS AND CONNECTORS TO ASSURE THEY ARE SEATED FULLY AND TIGHTENED SO CONDUIT CANNOT SEPERATE.
23. ALL CONDUIT ENTRIES TO PANELS, SWITCHGEAR, WEATHERHEADS, INVERTERS OR COMBINER BOXES SHALL BE SEALED AS FOLLOWS:
 - 23.1. DUCT SEALANT SHALL BE POLYWATER FST™ FOAM SEALANT. DUCT SEALANT SHALL BE A 2-PART, 98% CLOSED-CELL URETHANE FOAM. IT SHALL REACT AND SET IN 5-10 MINUTES AT 70°F. IT SHALL BE CAPABLE OF SEALING 3/4"-10 CONDUITS WITH MULTIPLE CABLE CONFIGURATIONS. DUCT SEALANT SHALL BE REENTERABLE. IT SHALL BE CAPABLE OF WITHSTANDING TEMPERATURES FROM -40°F TO 200°F; AND BE CHEMICALLY RESISTANT TO GASOLINE, OILS, DILUTE ACIDS AND BASES. DUCT SEALANT SHALL NOT AFFECT THE PHYSICAL OR ELECTRICAL PROPERTIES OF WIRE AND CABLE.
 - 23.2. DUCT SEALANT SHALL HAVE GOOD ADHESION TO DUCT AND CABLE JACKET SURFACES WITH GOOD STRUCTURAL STRENGTH. IT SHALL HAVE 120-lb COMPRESSIVE STRENGTH (ASTM D1621). DUCT SEALANT SHALL BE CAPABLE OF HOLDING 22FT. WATERHEAD PRESSURE CONTINUOUS OR 90FT. WATERHEAD PRESSURE SHORT-TERM. IT SHALL BLOCK UP TO 5 PSI GAS OR VAPOR CONTINUOUS. IT SHALL MEET NEC CODES FOR RACEWAY SEALS, MEET UL 94 FIRE RATING HBF AND BE UL RECOGNIZED.

WIRE AND TERMINATIONS:

GENERAL

1. ALL WIRE SHALL BE NEW AND CONTRACTOR SHALL PROVIDE THE MANUFACTURED DATE OF WIRE IF REQUESTED.
2. USE ONLY WIRE TYPES SPECIFIED OR AS ALLOWED BY THE NEC.
3. THHN/THWN/THHN-2/THWN-2 SHALL BE USED FOR FEEDER AND BRANCH CIRCUIT CONDUCTORS, UNLESS NOTED. CABLE INSULATION TYPE SHALL BE RATED FOR WET LOCATIONS AND HAVE A TEMPERATURE RATING OF 90°C OR BETTER.
4. PV CABLE, #10 COPPER, STRANDED, NEW 2000 VOLT, SHALL BE USED FOR PV STRING CONDUCTORS UNLESS NOTED. ALL PV WIRES BETWEEN PV MODULES & INVERTERS SHALL BE CONTINUOUS, WITHOUT ADDITIONAL CONNECTORS IN BETWEEN. UNLESS SPECIFIED BY THE ENGINEER.
5. ENSURE WIRE IS CONSISTENT WITH PLANS.
6. ALL WIRING TORQUE MUST BE DONE TO EQUIPMENT MANUFACTURERS SPECIFICATIONS AND MARKED AT EVERY TERMINATION.
7. ALL PHASE CONDUCTORS OF AN AC CIRCUIT OR FEEDER SHALL BE RUN IN THE SAME CONDUIT WHEN USING METAL RACEWAYS TO AVOID INDUCED CURRENTS AND OVERHEATING.
8. ALL AC & DC FEEDER CABLES INCLUDING STRING WIRES SHALL BE TESTED FOR INSULATION INTEGRITY WITH A MEGA OHM METER AT 1000 VOLTS FOR 1 MINUTE INTERVALS AND THE RESULTS MUST BE DOCUMENTED AND PUT IN THE JOB BINDER.
9. UNLESS SPECIFIED ALL WIRING SHALL BE COPPER.
10. ALUMINUM WIRING MAY BE USED WHEN SPECIFIED BUT SHALL NOT BE USED IN SIZES LESS THAN 2 AWG WITHOUT WRITTEN PERMISSION FROM DYNAMIC ENERGY.
11. BUSES, FEEDERS, BRANCH CIRCUIT CONDUCTORS, AND MEDIUM-VOLTAGE CABLES SHALL BE PROPERLY PHASED AND IDENTIFIED THROUGHOUT. INDIVIDUAL CONDUCTORS SHALL BE COLOR CODED AS NOTED BELOW:

CONDUCTOR	120/208V AND MEDIUM VOLTAGE	277/480V	462/800V
PHASE A	BLACK	BROWN	RED
PHASE B	RED	ORANGE	BLUE
PHASE C	BLUE	YELLOW	YELLOW
NEUTRAL	WHITE	GRAY	GRAY
GROUND	GREEN	GREEN	GREEN
ISOLATED GROUND	GREEN / YELLOW	GREEN / YELLOW	GREEN / YELLOW
CONDUCTOR	DC		
POSITIVE (+)	RED		
NEGATIVE (-)	BLACK		
GROUNDING CONDUCTOR	WHITE		
EQUIPMENT GROUND	GREEN		

- A. BUSES AND CONNECTIONS SHALL BE IDENTIFIED LEFT TO RIGHT, TOP TO BOTTOM, OR FRONT TO REAR; SHALL READ A-B-C; AND SHALL BE COLOR-CODED PER THE TABLE ABOVE.
 - B. FEEDERS FOR ALL NEW CONSTRUCTION SHALL HAVE COLOR-CODED PHASE IDENTIFICATION AT ALL JUNCTION BOXES AND WHEREVER FEASIBLE, AND SHALL HAVE SOLID (CONTINUOUS) COLOR INSULATION FOR PHASE DESIGNATION.
12. DISSIMILAR METALS (SUCH AS STEEL AND ALUMINIUM) SHALL BE ISOLATED FROM SURFACE TO SURFACE CONTACT USING NON-CONDUCTIVE SHIMS, WASHERS, OR OTHER METHODS.
 13. ALUMINIUM SHALL NOT BE PLACED IN DIRECT CONTACT WITH CONCRETE MATERIALS.
 14. PARALLEL CONDUCTORS MAY ONLY BE USED WHEN SPECIFIED, AND MUST ADHERE TO NEC ARTICLE 310.

WIRE AND TERMINATIONS (CONTINUED):

15. WIRE TERMINATIONS

- 15.1. SHALL BE HIGH PRESSURE CRIMPS ON ALL ALUMINUM CABLE. CRIMPS MUST BE RATED FOR THE SPECIFIC APPLICATION AND WIRE TYPE UNLESS APPROVED OTHERWISE.
- 15.2. ANTI-OXIDIZING COMPOUND MUST BE USED ON ALL ALUMINUM TERMINATIONS.
- 15.3. STRANDED COPPER WIRE 10 AWG & LESS REQUIRES THE USE OF COMPRESSION TYPE TERMINATIONS UNLESS DEVICE IS RATED TO HANDLE THAT SIZE WIRE.
16. WHERE CONDUCTORS SIZE EXCEED THE RATING OF THE EQUIPMENT LUGS THE CONDUCTORS MAY TRANSITION EITHER USING ILSKO CLEAR TAPS OR POWER DISTRIBUTION BLOCKS OR BUTT SPLICES TO CONDUCTORS THAT WILL NOT EXCEED THE RATING OF THE EQUIPMENT LUGS. THE TRANSITION SHALL BE WITHIN 10' - 0" OF LUGS. THE SIZE OF TRANSITIONED CONDUCTORS SHALL BE SIZED TO MEET THE RATING OF THE OVERCURRENT PROTECTION DEVICES.

TRENCHING:

3. ALL TRENCHING SHALL BE DONE IN ACCORDANCE WITH PLANS AS SPECIFIED.
2. ALL TRENCHING SHALL MEET OR EXCEED NEC ARTICLE 300 MINIMUM COVER REQUIREMENTS.
 - A. DEPTH FROM GROUND LEVEL TO TOP OF CLEAN FILL (SCREENINGS OR EQUIVALENT) 24" BELOW FINISHED GRADE, MINIMUM.
 - B. SHALL HAVE A MINIMUM OF 4" OF SCREENINGS OR EQUIVALENT UNDER CONDUIT AND A MINIMUM OF 4" ABOVE. DIRECT BURIED WIRE, WHEN ALLOWED, WILL REQUIRE 6" OF SCREENINGS ABOVE AND 6" BELOW.
 - C. METALLIC TRACER TAPE SHALL BE USED WHICH STATES THE FOLLOWING: "CAUTION: BURIED ELECTRIC LINE BELOW", TAPE SHALL BE LOCATED APPROX. 12" BELOW GRADE.
3. TRENCHES MAY HAVE TO BE LEFT OPEN OVERNIGHT FOR INSPECTION PURPOSES. IF THIS IS THE CASE, PRECAUTIONS MUST BE TAKEN TO ASSURE THAT A PERSON OR OBJECT CAN NOT FALL INTO THE TRENCH. IT IS THE CONTRACTOR'S RESPONSIBILITY TO SECURE THE TRENCH IN SUCH A MANNER TO PREVENT THIS FROM HAPPENING. CONTRACTOR SHOULD BE FAMILIAR WITH OSHA STANDARDS AND EMPLOY THE SAME.
4. TRENCHES WHICH MAY HAVE TO BE LEFT OPEN FOR AN EXTENDED PERIOD OF TIME SHALL FOLLOW # 3 ABOVE AND THE SIDEWALLS SHALL BE SECURED TO PREVENT COLLAPSE. TRENCH TOP SHALL BE COVERED TO PREVENT WATER, SNOW, AND DEBRIS FROM ENTERING AS WELL.
5. PICTURES SHALL BE TAKEN OF ALL PHASES OF THE TRENCHING AND PUT IN JOB BINDER.
6. APPROPRIATE INSPECTIONS SHALL BE MADE BY AHJ BEFORE CLOSING TRENCH.
7. RECORD DRAWINGS SHOWING THE EXACT LOCATION OF TRENCHES SHALL BE DRAWN UP BY CONTRACTOR AND PUT IN JOB BINDER. (ON "MASTER PLAN")
8. FINISH GRADING MUST BE EQUIVALENT TO THE ORIGINAL CONDITION OF THE GROUND PRIOR TO TRENCHING OR SPECIFICATION GIVEN. TRENCH SHALL BE COMPACTED (TAMPED) AT 8" DEPTH INTERVALS, TO ASSURE THAT THE TRENCH DOES NOT ALTER THE GROUND LEVEL INTEGRITY.
9. DO NOT DIG WITHOUT THE PROPER AUTHORIZATION PAPERWORK IN ORDER. CONTRACTOR SHALL OBTAIN THE SERVICES OF AN INDEPENDENT TESTING COMPANY FOR LOCATING AND THE IDENTIFYING OF ALL UNDERGROUND SITE UTILITIES IN THE AREAS OF PROPOSED EXCAVATION AND SHALL BE RESPONSIBLE FOR ANY DAMAGE OF EXISTING SITE UTILITIES OR SIMILAR.

ABBREVIATIONS:

A - AMPS
A.C. (AC) - ACTUATING CURRENT
AFG - ABOVE FINISHED GRADE
AHJ - AUTHORITY HAVING JURISDICTION
AWG - AMERICAN WIRE GAUGE
BFG - BELOW FINISHED GRADE
C - CONDUIT
Co. - COMPANY
D.C. (DC) - DIRECT CURRENT
DISC. - DISCONNECT
EC - ELECTRICAL CONTRACTOR
EMT - ELECTRICAL METALLIC TUBING
EX. - EXTERIOR
F - FURNISHED BY
GRD - GROUND
HV - HIGH VOLTAGE
I - INSTALLED BY
kW - KILOWATTS
kWh - KILOWATTS PER HOUR
LFMC - LIQUIDTIGHT FLEXIBLE METAL CONDUIT
LV - LOW VOLTAGE
MAX. - MAXIMUM
MIN. - MINIMUM
MV - MEDIUM VOLTAGE
NEC - NATIONAL ELECTRIC CODE
NFPA - NATIONAL FIRE PROTECTION ASSOCIATION
OH - OVERHEAD LINE
PH - PHASE
PV - PHOTOVOLTAIC
PVC - POLYVINYLCHLORIDE
RGS - RIGID GALVANIZED STEEL
SPD - SURGE PROTECTION DEVICE
TYP. - TYPICAL
UL - UNDERWRITERS LABORATORIES
UV - ULTRA VIOLET
V - VOLTS
W - WATTS
Wi - WIRED BY



STAG INDUSTRIAL HOLDINGS
40 PEPE FARM ROAD
MILFORD, CT 06460

Dynamic Energy™

1550 LIBERTY RIDGE DRIVE
SUITE 310
MAYNE, PA 15067
PHONE: 877-809-8884
FAX: 610-276-5403
WWW.DYNAMICENERGYUSA.COM

DRAWING ISSUE	
<input type="checkbox"/>	INTERCONNECTION
<input checked="" type="checkbox"/>	PERMITTING
<input type="checkbox"/>	CONSTRUCTION
<input type="checkbox"/>	RECORD

[illegible]

DRAWING NAME

CONSTRUCTION NOTES
(CONTINUED)

DRAWING NUMBER

GROUNDING AND BONDING:

1. ALL MATERIALS REQUIRED FOR A COMPLETE GROUNDING INSTALLATION SHALL BE FURNISHED. GROUNDING COMPONENTS SHALL INCLUDE GROUND RODS, GROUND CONDUCTOR, GROUND BUS, ABOVE AND BELOW GRADE GROUNDING CONNECTIONS, GROUNDING LUGS, AND ANY OTHER HARDWARE REQUIRED FOR A COMPLETE GROUNDING SYSTEM.
2. ALL GROUNDING SHALL BE COMPLIANT WITH NEC AND AS REQUIRED BY IEEE, NEC, NESC AND APPLICABLE LOCAL CODES.
3. SUITABLE GROUNDING FACILITIES SHALL BE FURNISHED ON ELECTRICAL EQUIPMENT NOT SO EQUIPPED. THE GROUNDING FACILITIES SHALL CONSIST OF COMPRESSION TYPE TERMINAL CONNECTORS BOLTED TO THE EQUIPMENT FRAME OR ENCLOSURE.
4. THE CONDUIT SYSTEM IS NOT CONSIDERED TO BE A GROUNDING CONDUCTOR. NO EQUIPMENT GROUNDING CONDUCTOR SHALL BE SMALLER IN SIZE THAN 12 AWG, UNLESS IT IS A PART OF AN ACCEPTABLE CABLE ASSEMBLY.
5. GROUNDING SHALL COMPLY WITH THE NEC AND THE EQUIPMENT MANUFACTURER'S APPROVED TESTED PROCEDURE.
6. ALL ASSOCIATED EQUIPMENT, RACKS, FENCING COMBINERS, INVERTERS AND SIMILAR COMPONENTS SHALL BE ELECTRICALLY BONDED WITH APPROPRIATELY RATED WIRE, LUGS, CRIMPS & CONNECTORS.
7. ALL GROUNDING TERMINATIONS SHALL BE TIGHTENED TO APPROPRIATE TORQUE.
8. EACH ARRAY / ROW OF MODULES SHALL BE BONDED TO EACH OTHER AND THE ASSOCIATED EQUIPMENT GROUND. GROUNDING CONDUCTORS SHALL BE COPPER, SIZED PER NEC AND SHOWN ON THE PLANS.
9. GROUND RODS SHALL BE DRIVEN IN AT EACH COMBINER BOX (GROUND MOUNT ONLY) AND INVERTER. (USE SIZE SPECIFIED)
10. ALL WIRING SHALL BE SECURED UNDER ARRAY SO THERE IS NO HANGING OR DRIPPING WIRES. ARRAY GROUNDING WIRES SHOULD BE INSULATED #6 AWG SOLID COPPER WIRE WITH A SUNLIGHT RESISTANT 90 DEGREE RATING (USE-2 OR EQUIVALENT).
11. CAREFUL MODULE LAYOUT SHOULD BE EMPLOYED FOR MOST EFFECTIVE MEANS OF WIRING AND NEAT WORKMANSHIP.
12. PV MODULES SHALL BE PROPERLY GROUNDED. MODULES SHALL BE GROUNDED WITH APPROPRIATE LUGS OR EQUIPMENT GROUNDING WASHERS (WEBBS) ON EACH MODULE AND MOUNTING RAILS TO OBTAIN CONTINUITY.
13. PROVIDE BONDING STRAPS AT ALL EXPANSION FITTINGS ON CABLE TRAYS AND ON RUNS OF CONDUIT THAT REQUIRE AN EXPANSION FITTING.
14. GROUND RODS SHALL BE COPPER CLAD, COLD DRAWN CARBON STEEL, MANUFACTURED IN ACCORDANCE WITH UL 467. THE COPPER CLADDING SHALL BE ELECTROLYTICALLY BONDED TO THE STEEL ROD OR BONDED BY A MOLTEN WELDING PROCESS. INDIVIDUAL GROUND RODS SHALL BE 3/4 INCH DIAMETER AND 10 FEET LONG. STAINLESS STEEL GROUND RODS SHALL BE INSTALLED WHERE SOILS CONDITIONS ARE CONSIDERED TO BE CORROSIVE OR CATHODIC PROTECTION INVOKED FOR PRESERVATION OF MATERIALS. GROUND RODS SHALL BE TYPE ERITECH AS MANUFACTURED BY ERICO, OR EQUIVALENT APPROVED BY THE ENGINEER
15. EXOTHERMAL CONNECTIONS SHALL BE A STANDARD DUTY COPPER MOLTEN WELD CONFORMING TO THE REQUIREMENTS OF IEEE 80. MOLDS AND POWDER CARTRIDGES USED FOR MAKING EXOTHERMAL CONNECTIONS SHALL BE FURNISHED BY THE SAME MANUFACTURER. EXOTHERMAL CONNECTIONS SHALL BE SIMILAR TO TYPE CADWELD AS MANUFACTURED BY ERICO, OR AN EQUIVALENT APPROVED BY SYSTEM OWNER.
16. GROUND LUGS SHALL BE SINGLE HOLE OR TWO HOLE, COMPLIANT WITH NEC BASED ON THE APPLICATION, AND COMPLIANT WITH THE COMMISSIONING CRITERIA FOR DISSIMILAR METALS. COPPER BARS CONFORMING TO THE REQUIREMENTS OF IEEE 837 AND UL 467. GROUND LUGS USED WITH THE EXOTHERMAL WELD PROCESS SHALL BE SIMILAR TO TYPE LA AS MANUFACTURED BY ERICO, OR AN SYSTEM OWNER ACCEPTABLE EQUAL. GROUND LUGS USED WITH THE COMPRESSION PROCESS SHALL BE SIMILAR TO TYPE YGHA AS MANUFACTURED BY BURNDY ELECTRICAL, OR AN SYSTEM OWNER ACCEPTABLE EQUAL.
17. GROUNDING (MEDIUM VOLTAGE AC COLLECTION SYSTEM): A MINIMUM OF 2/0 AWG BARE OR COATED COPPER GROUNDING CONDUCTOR, IN NON-CORROSIVE SOILS, SHALL BE INSTALLED IN THE SAME TRENCH, CONDUIT, OR RACEWAY AS THE AC COLLECTOR SYSTEM CABLES. IN CORROSIVE SOILS, AN APPROPRIATE GROUND (E.G., INSULATED CABLE OR TINNED COPPER GROUNDING CONDUCTOR) SHALL BE USED IN PLACE OF THE BARE COPPER GROUNDING CONDUCTOR.

18. GROUND SYSTEM RESISTANCE MEASUREMENTS:
 - 18.1. ALL GROUND RESISTANCE MEASUREMENTS SHALL BE MADE WITH THE FALL OF POTENTIAL OR SLOPE METHODS AS DEFINED IN IEEE 81.
 - 18.2. AFTER CONNECTION OF GROUND RODS TO THE GROUND SYSTEM, CONTRACTOR SHALL OBTAIN A GROUND RESISTANCE MEASUREMENT FROM A SELECTED LOCATION ON THE GROUND GRID, USING METHODS APPROVED BY THE SYSTEM OWNER. THIS DATA SHALL BE OBTAINED, IDENTIFIED AND RECORDED.
 - 18.3. THE GROUND RESISTANCE MEASUREMENT DATA MAY INDICATE THAT ADDITIONAL GROUND RODS ARE REQUIRED. CONTRACTOR SHALL FURNISH, INSTALL, AND CONNECT ADDITIONAL GROUND RODS AS NECESSARY.
19. GROUNDING COMMISSIONING: SYSTEM GROUNDING CONTRACTOR SHALL ENSURE THAT ALL COMPONENTS ARE PROPERLY GROUNDING ACCORDING TO DESIGN AND SPECIFICATIONS. GROUNDING CONNECTIONS SHALL BE INSPECTED BY AN AHJ OR OTHER INDEPENDENT QUALITY CONTROL INSPECTOR TO VERIFY PROPER INSTALLATION OF ALL COMPRESSION CLAMPS, CAD WELDS, AND MECHANICAL CONNECTIONS. THE DC AND AC SYSTEM GROUNDINGS SHALL CONFORM TO ALL APPLICABLE CODES AND STANDARDS. VISUAL INSPECTIONS OF THE GROUNDING SYSTEMS SHALL BE DOCUMENTED IN A REPORT THAT INCLUDES, BUT IS NOT LIMITED TO, THE FOLLOWING VERIFICATIONS:
 - 19.1. RACKING POSTS GROUNDED PER SPECIFICATIONS AND CONNECTED TO SYSTEM GRID.
 - 19.2. ALL CONNECTIONS VISUALLY VERIFIED.
 - 19.2.1. MECHANICAL ATTACHMENT: ANTI-OXIDATION COATINGS APPLIED, AS REQUIRED.
 - 19.2.2. LUGS FULLY SEATED.
 - 19.2.3. WHIP INSTALLED PER MANUFACTURER'S REQUIREMENTS.
 - 19.2.4. CONNECTIONS TO GROUNDING GRID INSPECTED: CAD WELDS, COMPRESSION CLAMPS.
 - 19.3. GROUNDING RODS
 - 19.3.1. RODS SET TO DEPTH PER AHJ.
 - 19.3.2. CLAMP FULLY ENGAGED.
 - 19.3.3. WHIP/CABLE FULLY ENGAGED.

HENDRIK J. BURGER
PROFESSIONAL ENGINEER
1368 SHEEP HILL ROAD
POTTSTOWN, PA 19465

SEAL



Dynamic Energy™

PHONE: 877-809-8884
FAX: 610-276-5403
WWW.DYNAMICENERGYUSA.COM

STAG INDUSTRIAL HOLDINGS
40 PEPE FARM ROAD
MILFORD, CT 06460

DRAWING ISSUE	
<input type="checkbox"/>	INTERCONNECTION
<input checked="" type="checkbox"/>	PERMITTING
<input type="checkbox"/>	CONSTRUCTION
<input type="checkbox"/>	RECORD



[illegible]

DRAWING NAME

CONSTRUCTION NOTES
(CONTINUED)

DRAWING NUMBER


G004



1550 LIBERTY RIDGE DRIVE
SUITE 310
WAYNE, PA 19087

PHONE: 877-809-8884
FAX: 610-276-5403
WWW.DYNAMICENERGYUSA.COM

STAG INDUSTRIAL HOLDINGS
40 PEPE FARM ROAD
MILFORD, CT 06460



DRAWING ISSUE	
<input type="checkbox"/>	INTERCONNECTION
<input checked="" type="checkbox"/>	PERMITTING
<input type="checkbox"/>	CONSTRUCTION
<input type="checkbox"/>	RECORD

[illegible]

DRAWING NAME

EXISTING STRUCTURAL
LAYOUT & DETAILS

DRAWING NUMBER
S101

STRUCTURAL ENGINEERING
1815 W. DIEHL RD SUITE 100
NAPERSVILLE, IL 60563

SEAL



SEAL



DRAWING ISSUE	
<input type="checkbox"/>	INTERCONNECTION
<input checked="" type="checkbox"/>	PERMITTING
<input type="checkbox"/>	CONSTRUCTION
<input type="checkbox"/>	RECORD



[illegible]

DRAWING NAME

EXISTING STRUCTURAL
LAYOUT & DETAILS

DRAWING NUMBER

S101.1










DRAWING ISSUE	
<input type="checkbox"/>	INTERCONNECTION
<input type="checkbox"/>	PERMITTING
<input type="checkbox"/>	CONSTRUCTION
<input type="checkbox"/>	RECORD

REV #	DATE	DESCRIPTION
0	08-18-2021	PERMIT SET ISSUED
1	08-27-2021	LAYOUT REVISED

DRAWING NAME	
PV PANEL & EQUIPMENT LAYOUT	

DRAWING NUMBER	
E100	





HENDRIK J. BURGER
PROFESSIONAL ENGINEER
1368 SHEEP HILL ROAD
POTTSTOWN, PA 19465

SEAL

Diagram illustrating the components of a PV-AC panel support structure:

- DATA MONITORING BOX
- PANEL PV-AC
- STRUT SUPPORT RAIL
- PANELBOARD SUPPORT POST
- DATA CONDUIT
- AC CONDUIT (IN/OUT)
- APPROVED CONDUIT SUPPORT
- EXISTING ROOF STRUCTURE

2 SUPPORT RACKING (TYP.)
E102 (FOR PANEL BOARD & DATA MONITOR)

 **Dynamic Energy**TM

1550 LIBERTY RIDGE DRIVE
SUITE 310
WAYNE, PA 19087

PHONE: 877-509-4884
FAX: 610-276-5403
WWW.DYNAMICENERGYUSA.COM

STAG INDUSTRIAL HOLDINGS
40 PEPES FARM ROAD
MILFORD, CT 06460

DRAWING ISSUE
INTERCONNECTION
PERMITTING
CONSTRUCTION
RECORD

[illegible]

DRAWING NAME

PANELBOARD SUPPORT DETAILS

DRAWING NUMBER

E102

10/11/2021 10:30:37 AM



Datasheet

50/60kW, 1000Vdc String Inverters for North America

The 50 & 60kW (55 & 66kVA) medium power CPS three phase string inverters are designed for ground mount, large rooftop and carport applications. The units are high performance, advanced and reliable inverters designed specifically for the North American environment and grid. High efficiency at 98.8% peak and 98.5% CEC, wide operating voltages, broad temperature ranges and a NEMA Type 4X enclosure enable this inverter platform to operate at high performance across many applications. The CPS 50/60kW products ship with either the standard wire-box or the H4 style wire-box, each fully integrated and separable with touch safe fusing, monitoring, and AC and DC disconnect switches. The CPS Flex Gateway enables monitoring, controls and remote product upgrades.

Key Features

- 55 & 66kVA rating allows max rated Active Power @±0.91 PF
- Selectable Max AC Apparent Power of 50/55kVA and 60/66kVA
- NEC 2014/17 compliant & UL listed Arc-Fault circuit protection
- 0-90° Mounting orientation for lay flat roof installs
- Touch safe DC Fuse holders adds convenience and safety
- Optional Flex Gateway enables remote FW upgrades
- Integrated AC & DC disconnect switches
- 3 MPPT's with 5 inputs each for maximum flexibility
- Copper and Aluminum compatible AC connections
- NEMA Type 4X outdoor rated, tough tested enclosure
- UL1741 SA Certified to CA Rule 21
- Separable wire-box design for fast service
- Standard 10 year warranty with extensions to 20 years
- Generous 1.5 DC/AC Inverter Load Ratio



CPS SCA50KTL-DO/US-480
CPS SCA60KTL-DO/US-480



50/60kW Standard Wire-box



50/60kW H4 Wire-box



© CHINT POWER SYSTEMS AMERICA 2018/08-MKTNA

Chint Power Systems America
7060 Koll Center Parkway, Suite 310 Pleasanton, CA 94566
Tel: 855-584-7168 Mail: AmericaSales@chintpowersys.com Web: www.chintpowersys.com



Technical Data

Model Name	CPS SCA50KTL-DO/US-480	CPS SCA60KTL-DO/US-480
DC Input		
Max. PV Power	75kW (30kW per MPPT)	90kW (33kW per MPPT)
Max. DC Input Voltage		1000Vdc
Operating DC Input Voltage Range		200-950Vdc
Start-up DC Input Voltage / Power		330V / 80W
Number of MPP Trackers		3
MPPT Voltage Range @ PF>0.99 ¹	480-850Vdc	540-850Vdc
Max. PV Short-Circuit Current (Isc x 1.25)		204A (68A per MPPT)
Number of DC Inputs		15 inputs, 5 per MPPT
DC Disconnection Type		Load rated DC switch
DC Surge Protection		Type II MOV, 2800Vdc, 20kA I _{nu} (8/20μs)
AC Output		
Rated AC Output Power @ PF>0.99 to ±0.91 ²	50kW	60kW
Max. AC Apparent Power (Selectable)	50/55kVA	60/66kVA
Rated Output Voltage		480Vac
Output Voltage Range ³		422 - 528Vac
Grid Connection Type		3Φ / PE / N (Neutral optional)
Max. AC Output Current @480Vac	80.2/68.2A	72.2/79.4A
Rated Output Frequency		60Hz
Output Frequency Range ³		57 - 63Hz
Power Factor		>0.99 (±0.8 adjustable)
Current THD @ Rated Load		<3%
Max. Fault Current Contribution (1 Cycle RMS)		64.1A
Max. OCPD Rating	110A	125A
AC Disconnection Type		Load rated AC switch
AC Surge Protection		Type II MOV, 1240Vdc, 15kA I _{nu} (8/20μs)
System and Performance		
Topology		Transformerless
Max. Efficiency		98.8%
CEC Efficiency		98.5%
Stand-by / Night Consumption		<1W
Environment		
Enclosure Protection Degree		NEMA Type 4X
Cooling Method		Variable speed cooling fans
Operating Temperature Range ⁴		-22°F to +140°F / -30°C to +60°C ⁴
Non-Operating Temperature Range ⁵		No low temp minimum to +158°F / +70°C maximum ⁵
Operating Humidity		0 to 100%
Operating Altitude		13,123.4ft / 4000m (derating from 9842.5ft / 3000m)
Audible Noise		<60dBA @ 1m and 25°C
Display and Communication		
User Interface and Display		LCD+LED
Inverter Monitoring		SunSpec, Modbus RS485
Site Level Monitoring		CPS Flex Gateway (1 per 70 inverters)
Modbus Data Mapping		CPS
Remote Diagnostics / FW Upgrade Functions		Standard / (with Flex Gateway)
Mechanical		
Dimensions (HxWxD)		39.4 x 23.6 x 10.24in. (1000 x 600 x 260mm)
Weight		Inverter: 123.5lbs/56kg; Wire-box: 33lbs/15kg
Mounting / Installation Angle ⁶		0 to 90 degrees from horizontal (vertical, angled, or lay flat) ⁶
AC Termination ⁷		M8 Stud Type Terminal Block (Wire range: #6 - 3/0AWG CU/AL ⁷ , Lugs not supplied)
DC Termination		Screw Clamp Fuse Holder (Wire range: #14 - #6AWG CU), Optional H4 (Amphenol)
Fused String Inputs (5 per MPPT) ⁸		15A fuses provided (Fuse values up to 30A acceptable) ⁸
Safety		
Certifications and Standards		UL1741SA-2016, UL1699B, CSA-C22.2 NO.107.1-01, IEEE1547a-2014; FCC PART15
Selectable Grid Standard and SRD		IEEE1547a-2014, CA Rule 21
Smart-Grid Features		Voltage-RideThru, Frequency-RideThru, Soft-Start, Volt-Var, Frequency-Watt, Volt-Watt
Warranty		
Standard		10 years
Extended Terms		15 and 20 years

1) See user manual for further information regarding MPPT Voltage Range when operating at non-unity PF.
2) Active Power Derating begins; at PF±0.91 to ±0.8 when Max AC Apparent Power is set to 55 or 66kVA.
3) The "Output Voltage Range" and "Output Frequency Range" may differ according to the specific grid standard.
4) Active Power Derating begins; at 40°C when PF±0.9 and MPPT <V_{min}, at 45°C when PF±1 and MPPT <V_{min}, and at 50°C when PF±1 and MPPT V ≥ 760Vdc.
5) See user manual for further requirements regarding non-operating conditions.
6) Shade Cover accessory required for installation angles of 75 degrees or less.
7) AL requires bi-metallic compression lug or bi-metallic adapter.
8) Fuses values above 20A have additional spacing requirements or require the use of the Y-comb adapter. See user manual for details.

Dynamic Energy™



PHONE: 877-809-8884
FAX: 610-276-5403
SUITE 310
WAYNE, PA 19087
WWW.DYNAMICENERGYUSA.COM

STAG INDUSTRIAL HOLDINGS
40 PEPES FARM ROAD
MILFORD, CT 06460

DRAWING ISSUE

☐ INTERCONNECTION
☒ PERMITTING
☐ CONSTRUCTION
☐ RECORD

REV #	DATE	DESCRIPTION
0	08-16-2021	PERMIT SET ISSUED
1	08-27-2021	LAYOUT REVISED

DRAWING NAME

INVERTER DETAILS

DRAWING NUMBER

E300

HENDRIK J. BURGER
PROFESSIONAL ENGINEER
1368 SHEEP HILL ROAD
POTTSTOWN, PA 19465

SEAL

Harvest the Sunshine

Mono

420W MBB Bifacial Mono PERC Half-cell Double Glass Module JAM72D10 400-420/MB Series

Introduction

Assembled with MBB bifacial PERCIUM cells and half-cell configuration, these double glass modules have the capability of converting the incident light from the rear side together with the front side into electricity, providing higher output power, lower temperature coefficient, less shading loss, as well as enhanced tolerance for mechanical loading.



Higher output power



More reliable, more stable
power generation




Less shading effect



Lower temperature coefficient

Superior Warranty

- 12-year product warranty
- 30-year linear power output warranty



■ Additional Value From 30-Year Warranty ■ JA Standard

Comprehensive Certificates

- IEC 61215, IEC 61730, UL 61215, UL 61730
- ISO 9001: 2015 Quality management systems
- ISO 14001: 2015 Environmental management systems
- OHSAS 18001: 2007 Occupational health and safety management systems
- IEC TS 62941: 2016 Terrestrial photovoltaic (PV) modules – Guidelines for increased confidence in PV module design qualification and type approval



JA SOLAR

www.jasolar.com


Specifications subject to technical changes and tests.
JA Solar reserves the right of final interpretation.



JA SOLAR

JAM72D10 400-420/MB Series

MECHANICAL DIAGRAMS



Remark: customized frame color and cable length available upon request

SPECIFICATIONS

Cell	Mono
Weight	25.0kg±3%
Dimensions	2037±2mm×1005±2mm×30±1mm
Cable Cross Section Size	4mm ² (12AWG)
No. of cells	144(6×24)
Junction Box	IP68, 3 diodes
Connector	QC 4.10-35
Cable Length (Including Connector)	Portrait:300mm(+)/400mm(-); Landscape:1200mm(+)/1200mm(-)
Packaging Configuration	34 Per Pallet
Front Glass/Back Glass	2.0mm/2.0mm

ELECTRICAL PARAMETERS AT STC

TYPE	JAM72D10 -400/MB	JAM72D10 -405/MB	JAM72D10 -410/MB	JAM72D10 -415/MB	JAM72D10 -420/MB
Rated Maximum Power(Pmax) [W]	400	405	410	415	420
Open Circuit Voltage(Voc) [V]	49.57	49.82	50.08	50.35	50.62
Maximum Power Voltage(Vmp) [V]	42.02	42.28	42.54	42.80	43.04
Short Circuit Current(Isc) [A]	10.14	10.20	10.26	10.32	10.37
Maximum Power Current(Imp) [A]	9.52	9.58	9.64	9.70	9.76
Module Efficiency [%]	19.5	19.8	20.0	20.3	20.5
Power Tolerance	0~+5W				
Temperature Coefficient of Isc(α _{Isc})	+0.044%/°C				
Temperature Coefficient of Voc(β _{Voc})	-0.272%/°C				
Temperature Coefficient of Pmax(γ _{Pmp})	-0.354%/°C				
STC	Irradiance 1000W/m ² , cell temperature 25°C, AM1.5G				

Remark: Electrical data in this catalog do not refer to a single module and they are not part of the offer.They only serve for comparison among different module types.
*Bifaciality=Pmax,rear/Rated Pmax,front

ELECTRICAL CHARACTERISTICS WITH DIFFERENT REAR SIDE POWER GAIN(REFERENCE TO 410W FRONT)

	5%	10%	15%	20%	25%
Backside Power Gain	5%	10%	15%	20%	25%
Rated Max Power(Pmax) [W]	431	451	472	492	513
Open Circuit Voltage(Voc) [V]	50.10	50.10	50.10	50.20	50.20
Max Power Voltage(Vmp) [V]	42.55	42.55	42.55	42.65	42.65
Short Circuit Current(Isc) [A]	10.76	11.28	11.79	12.30	12.81
Max Power Current(Imp) [A]	10.12	10.60	11.08	11.54	12.02


OPERATING CONDITIONS

Maximum System Voltage	1500V DC(UL)
Operating Temperature	-40°C~+85°C
Maximum Series Fuse	20A
Maximum Static Load,Front*	5400Pa(112 lb/ft ²)
Maximum Static Load,Back*	2400Pa(50 lb/ft ²)
NOCT	45±2°C
Bifaciality*	70%±5%
Fire Performance	Type 29


*For NexTracker installations static loading performance: front load measure 2400Pa, while back load measures 1800Pa.

CHARACTERISTICS


Current-Voltage Curve JAM72D10-410/MB



Power-Voltage Curve JAM72D10-410/MB



Current-Voltage Curve JAM72D10-410/MB



Premium Cells, Premium Modules

Version No. : US_EN_20200401A

Dynamic Energy™



PHONE: 877-809-8884
FAX: 610-276-5403
WWW.DYNAMICENERGYUSA.COM

1550 LIBERTY RIDGE DRIVE
SUITE 310
WAYNE, PA 19087

STAG INDUSTRIAL HOLDINGS
40 PEPES FARM ROAD
MILFORD, CT 06460

DRAWING ISSUE

☐ INTERCONNECTION
☐ PERMITTING
☐ CONSTRUCTION
☐ RECORD

DATE	DESCRIPTION
08-18-2021	
08-27-2021	

DESCRIPTION

REV.#	PERMIT SET ISSUED	LAYOUT REVISED
0		
1		

DRAWING NAME





MODULE DETAILS


DRAWING NUMBER

E301

HENDRIK J. BURGER
PROFESSIONAL ENGINEER
1368 SHEEP HILL ROAD
POTTSTOWN, PA 19465




SEAL





STAG INDUSTRIAL HOLDINGS
40 PEPS FARM ROAD
MILFORD, CT 06460

HENDRIK J. BURGER
PROFESSIONAL ENGINEER
1368 SHEEP HILL ROAD
POTTSTOWN, PA 19465



The diagram shows a front view of a cabinet with several safety features and labels:

- Top Left:** A circular label with the letter 'S' inside, indicating a safety hazard.
- Top Center:** A note stating: "NOTE: ARC FLASH LABELS PROVIDED BY DYNAMIC ENERGY BASED ON ARC FLASH STUDY RESULTS."
- Top Right:** A large red rectangular label with a black exclamation mark inside a triangle and the word "DANGER" in bold black letters.
- Middle Left:** A yellow triangular warning label with a black border and a black lightning bolt symbol.
- Middle Center:** The text "Arc Flash and Shock Risks" in black.
- Middle Right:** A yellow triangular warning label with a black border and a black lightning bolt symbol.
- Below Middle:** A horizontal line labeled "XX in- Arc Flash Protection Boundary".
- Below Line:** A horizontal line labeled "X.X cal/cm²-2- Incident Energy Flash Risk at XX in".
- Below Line:** A note stating: "Appropriate PPE Required for both Arc Flash and Shock Risks:".
- Below Note:** A list of PPE requirements:
 - Clothing: DO NOT WORK ON LIVE!
 - Foot Protection: DO NOT WORK ON LIVE!
 - DO NOT WORK ON LIVE!
 - DO NOT WORK ON LIVE!
- Bottom Left:** A horizontal line labeled "XXX VAC Shock Risk with covers/doors open".
- Bottom Center:** A horizontal line labeled "XX in- Limited Approach Boundary".
- Bottom Right:** A horizontal line labeled "XX in- Restricted Approach Boundary".
- Bottom Center:** A horizontal line labeled "XX cal/cm²-2- Minimum Arc Rating".
- Bottom Left:** A horizontal line labeled "Bus: XXXXXXXXX".
- Bottom Right:** A horizontal line labeled "XXXXXX".
- Bottom Center:** A note stating: "NOTE: ARC FLASH LABELS PROVIDED BY DYNAMIC ENERGY BASED ON ARC FLASH STUDY RESULTS."

SEAL


Exhibit B

City of Milford

Geographic Information System (GIS)




Date Printed: 11/19/2021



**MAP DISCLAIMER - NOTICE OF LIABILITY**

This map is for assessment purposes only. It is not for legal description or conveyances. All information is subject to verification by any user. The City of Milford and its mapping contractors assume no legal responsibility for the information contained herein.

Approximate Scale: 1 inch = 2000 feet



Property Information

Property Location	40 PEPES FARM RD
Owner	STAG INDUSTRIAL HOLDINGS LLC
Co-Owner	na
Mailing Address	ONE FEDERAL ST 23RD FL BOSTON MA 02210
Land Use	4010 IND WHSES MDL-96
Land Class	I
Zoning Code	LI
Census Tract	AB980

Neighborhood	J
Acreage	14.56
Utilities	All Public,Public Sewer
Lot Setting/Desc	UNKNOWN UNKNOWN
Book / Page	03723/0279
Fire District	3

Primary Construction Details


Year Built	1981
Building Desc.	IND WHSES MDL-96
Building Style	Warehouse
Building Grade	GOOD
Stories	1
Occupancy	1.00
Exterior Walls	Brick/Stn Vene
Exterior Walls 2	Aluminum Sidng
Roof Style	Flat
Roof Cover	Tar & Gravel
Interior Walls	Minim/Masonry
Interior Walls 2	Drywall/Sheet
Interior Floors 1	Concr-Finished
Interior Floors 2	Carpet

Heating Fuel	Gas
Heating Type	Hot Air-no Duc
AC Type	XF Per Sq Ft
Bedrooms	0
Full Bathrooms	0
Half Bathrooms	0
Extra Fixtures	0
Total Rooms	
Bath Style	NA
Kitchen Style	NA
Fin Bsmt Area	
Fin Bsmt Quality	
Bsmt Gar	
Fireplaces	0

Photo



Sketch



(*Industrial / Commercial Details)	
Building Use	Industrial
Building Condition	3
Sprinkler %	NA
Heat / AC	HEAT/AC SPLIT
Frame Type	STEEL
Baths / Plumbing	AVERAGE
Ceiling / Wall	CEILING ONLY
Rooms / Prtns	AVERAGE
Wall Height	30.00
First Floor Use	NA
Foundation	NA

Valuation Summary (Assessed value = 70% of Appraised Value)

Item	Appraised	Assessed
Buildings	9972570	6980800
Extras	427090	298960
Improvements		
Outbuildings	218830	153190
Land	2066720	1446700
Total	12685210	8879650

Sub Areas

Subarea Type	Gross Area (sq ft)	Living Area (sq ft)
Office, (Average)	9117	9117
First Floor	190563	190563
Total Area	199680	199680


Outbuilding and Extra Features

Type	Description
PAVING-ASPHALT	134500 S.F.
LOAD LEVELERS	18 UNITS
SPRINKLERS-WET	199680 S.F.
AIR CONDITION	9117 UNITS
FENCE-6' CHAIN	340 L.F.
LIGHTS-IN W/PL	15 UNITS

Sales History

Owner of Record	Book/ Page	Sale Date	Sale Price
STAG INDUSTRIAL HOLDINGS LLC	03723/0279	2017-03-02	13250000
CPI 40 PEPES FARM LLC	03609/0285	2014-12-03	6600000
SREF PEPE LLC	03122/0282	2006-10-20	14560000
PEPES FARM LLC	02977/0678	2005-04-20	12400000
CABOT ACQUISITION LLC	02607/0643	2002-08-12	0
CP INVESTMENT PROPERTIES IX INC	02261/0563	1998-02-11	0
CC & FRA INVESTMENT PROPERTIES	01684/0327	1988-11-07	0

Exhibit C



Distribution Generation Interconnection Impact Study

Dynamic Energy Solutions LLC - Stag Industrial Holdings

40 Pepes Farm Rd, Milford, CT 06460

June 25, 2021

Prepared For:

The United Illuminating Company
180 Marsh Hill Road, Orange, CT 06477

Submitted By:

Hussain Biyawerwala

Investigators:

TABLE OF CONTENTS

THE UNITED ILLUMINATING COMPANY

1. EXECUTIVE SUMMARY	1
2. STUDY MODELS AND ASSUMPTIONS.....	4
3. INTERCONNECTION EVALUATION.....	5
3.1 VOLTAGE CHANGE ANALYSIS	6
3.2 VOLTAGE FLUCTUATION ANALYSIS.....	10
3.3 SYSTEM IMBALANCE IMPACTS	11
3.4 POTENTIAL FOR FERRORESONANCE.....	11
3.5 UNINTENTIONAL ISLANDING.....	12



1. EXECUTIVE SUMMARY

This distribution system impact study evaluates the effect of a proposed Distributed Generation (DG) interconnection, located at 40 Pepes Farm Rd, Milford, on the operation and performance of the electric distribution system. A system model was developed to simulate the DG interconnection under various operating conditions.

The results of the simulations have shown that this proposed DG interconnection of 1500 kW of PV solar generator system would result in minor adverse impacts on the Electric Distribution Company (EDC) distribution system as described below:

Analysis	Criteria	Results	Upgrades	Notes
Voltage	$95\% < V < 105\%$	PASS		Pre-existing under voltage during minimum load condition.
Voltage Change	$\Delta V < 1\%$ at PCC	PASS		
Load Flow	No Violation	PASS		No Reverse Power through substation transformer
System Imbalance	UI Criterion	PASS		
Ferroresonance	Wye-grounded at high side	PASS after upgrade	Utility owned Vista Switch	Developer proposes a secondary SEL 651R relay & 50, 50P relay at high side.
Risk of Islanding	Inverter anti-islanding feature	PASS after upgrade	Utility owned Vista Switch	Developer proposes a secondary SEL 651R relay & 50, 50P relay at high side.
Contingency Analysis	All criteria for voltage, voltage change, load flow and system imbalance	FAIL*		Voltage change at POI > 1.0 % (1.07%)

Table #1: Results Summary

* After further review of the 'Contingency Analysis' UI has determined that there will be minor or no adverse effect to the Distribution System.

INTRODUCTION AND SYSTEM DESCRIPTION

Dynamic Energy Solutions LLC has requested the interconnection of 1500 kW of PV distributed generation named Stag Industrial Holdings at 40 Pepes Farm Rd, Milford. The project has requested approval for the interconnection of 1500 kW of PV generation through one customer proposed transformer (1) 2000 kVA 13.8kV/0.48kV, Wye Grounded/Wye Grounded interconnection transformer with an impedance of 5.75%.

The proposed DG is to be interconnected to The United Illuminating Co. (UI) distribution system through the Woodmont Substation Feeder #3660. Feeder #3660 will be the normal supply while Woodmont Substation Feeder #3650 will be the backup supply to the DG site load during peak and minimum loading conditions.

Figure #1 shows the one-line diagram of the proposed system design and the proposed connection to the interconnecting feeder for the 1500 kW PV generation. Figure #2 shows the overall developed CYMDIST system model for the proposal.

The purpose of this study is to evaluate the proposed DG interconnection and its impact on the UI distribution system. The following items have been identified as the main concerns for the DG interconnection to the UI system:

- a) Voltage Change Analysis - evaluation of the steady-state and change in distribution voltage levels at the substation bus associated with interconnection and separation of the generating facility. This will investigate the voltage change at both peak and minimum substation bus loading periods.
- b) Voltage Fluctuation Analysis - control settings on existing automatic regulation devices will be examined to determine if the proposed generation will adversely impact the regulating equipment controls or the regulating equipment's duty.
- c) System Imbalance Impacts - evaluation of potential for excessive bus imbalance associated with the generating facility when interconnected.
- d) Potential for ferroresonance - the potential for the occurrence of ferroresonance upon switching at the service entrance will be investigated.
- e) Unintentional Islanding – potential for an unintentional islanding condition in which the generator continues to supply power to a location even though electrical grid power from the local Electric Power System (EPS) is no longer present.








Figure #2: The CYMDIST Model Detail of the Stag Industrial Holdings at 40 Pepes Farm Rd, Milford, Customer's 1500 kW DG

2. STUDY MODELS AND ASSUMPTIONS

As Figure #2 shows, a system model has been developed in the CYMDIST power system simulation software. This model represents the PV generator, the interconnection transformer, and the interconnecting distribution feeder. Below is a list of assumptions made as part of the modeling and analysis:

- The proposed DG Interconnection Request received on 06/16/2020 and as depicted on the drawing by Dynamic Energy for Dynamic Energy Solutions, LLC. The Revised IA Drawings dated 10/16/2020 will be used in the study.

- The system model considered both peak and minimum load conditions on the normal and backup supply feeder, using July 2020 and April 2020 load information respectively, for the area customers and total demand of the feeders.
- All other customers' existing parallel generators and all generation on the feeders proposed prior to Dynamic Energy Solutions LLC (generation in the "queue" before Dynamic Energy Solutions LLC) are assumed to be in service.
- The proposed DG unit will be connected to the UI 13.8 kV distribution system through customer proposed one (1) 2000 kVA 13.8 kV/0.48 kV, Wye Grounded/Wye Grounded interconnection transformer with an impedance of 5.75% and X/R ratio of 2.22. The transformer is assumed to be solidly grounded. The transformer is utility-grade and has a Basic Insulation Level (BIL) of 95 kV.
- There is no emergency generation that will contribute to the site generation when the proposed DG is not interconnected.
- Loads are modeled as constant power type.
- The voltage at the source node of the feeders is operated at 1.03 per unit average (14.2 kV) during peak load periods.
- The voltage at the source node of the feeders is operated at 1.00 per unit average (13.8 kV) during minimum load periods.
- The generating facility will be connected to the UI 13.8 kV distribution system near Pole 6317, 40 Pepes Farm Rd on the feeder #3660, Woodmont Substation.

3. INTERCONNECTION EVALUATION

The system models described above have been used to complete the required analyses and simulations under different operating conditions. The sections below investigate the identified DG interconnection screens per the results of the conducted simulations. As was described in Section 2, the feeder steady-state voltage and voltage change study items that follow were performed considering these individual scenarios:

Scenario A:

1. 1500 kW PV interconnected to the normal supply Feeder #3660 during peak load conditions and all available generation on-line at that time.
2. 1500 kW PV interconnected to the backup supply Feeder #3650, feeding all the normal supply Feeder #3660 during peak load conditions and all available generation on-line at that time.



Scenario B:

1. 1500 kW PV interconnected to the normal supply Feeder #3660 during minimum load conditions and all available generation on-line at that time.
2. 1500 kW PV interconnected to the backup supply Feeder #3650, feeding all the normal supply Feeder #3660 during minimum load conditions and all available generation on-line at that time.

3.1 VOLTAGE CHANGE ANALYSIS

Voltage regulation is often a key issue when interconnecting DG to the utility system. One of the most significant limiting factors is how much the voltage changes when all DG is suddenly disconnected. These voltage changes may impact the safety, power quality, and reliability of supply to other customers which are served by the same feeder that the proposed DG will be interconnected to.

For these reasons it is recommended that for renewable generation such as photovoltaic generation, voltage changes of more than 1% will trigger closer scrutiny. Standard utility voltage regulating equipment, including substation transformer load tap changers (LTC) and pole type voltage regulators may not be able to compensate for larger changes in voltage in a timely manner.

Assuming that the generator will be operated in a constant power factor mode with a power factor of unity, this analysis simulates a sudden disconnection/loss of the 1500 kW PV generation, plus all other same type generation, and calculates the resulting voltage drop at the interconnecting DG PCC location on the feeder. The voltage changes are analyzed at the distribution feeder source, located at Woodmont Substation, at peak and minimum load periods, with maximum available generation.

Steady State Voltage – Peak Load: Figure #3 shows the voltage drop profile of Feeder #3660 under normal operating conditions before and after the proposed 1500 kW (at full output) generator interconnects with the electric system. Table #2 below shows the voltage levels (on a 120.0 Volt base) up to the POI at near Pole 6317 located within the ROW before and after the interconnection of the proposed 1500 kW PV generator. The voltage levels after the interconnection of the proposed 1500 kW PV generator are within acceptable levels.






Figure #3: The Voltage Profile of Feeder #3660 from Woodmont Substation to the Customer POI near Pole 6317 at Peak Load Periods Before (dashed line) and After (solid line) with Full 1500 kW Generation (Scenario A) (120.0 Volt Base)

Phase Designation	Before DG (V)	After DG (V)	Delta (V) @ POI
A	122.32	122.60	0.28
B	122.12	122.40	0.28
C	121.87	122.14	0.27

Table #2: The Voltage Levels Before and After on Customer POI Near Pole 6317 at Peak Load Periods Before and After with Full 1500 kW Generation (Scenario A) (120.0 Volt Base)

Steady State Voltage – Minimum Load: Figure #4 shows the voltage drop profile of Feeder #3660 under normal operating conditions before and after the proposed 1500 kW (at full output) generator interconnects with the electric system. Table #3 below shows the voltage levels (on a 120.0 Volt base) up to the POI at Pole 6317 located within the ROW before and after the interconnection of the proposed 1500 kW PV generator. The voltage levels after the interconnection of the proposed 1500 kW PV generator are within acceptable levels.




Figure #4: The Voltage Profile of Feeder #3660 from Woodmont Substation to the POI near Pole 6317 at Minimum Load Periods with Before (dashed line) and After (solid line) with Maximum Available Generation (Scenario B) (120 V Base)

Phase Designation	Before DG (V)	After DG (V)	Delta (V) @ POI
A	118.6	118.8	0.2
B	118.7	118.9	0.2
C	118.4	118.6	0.2

Table #3: The Voltage Levels Before and After on Customer POI near Pole 6317 at Minimum Load Period before and after with Full 1500 kW Generation (Scenario B) (120.0 Volt Base)

The worst-case scenario, maximum project output under minimum load conditions, reverse power flow through the Feeder #3660 is not observed.

Voltage Change – Scenario A (1500 kW DG, Peak Load): Table #4 shows the average voltage change measured at the customer's riser near Pole 6317 (POI) due to the sudden loss of the 1500 kW PV when interconnected to Feeder #3660. The voltage changes are 0.16%, 0.16% and 0.16% on Phase A, B and C, respectively. This voltage change is less than the 1% change threshold value that would be of concern.

		PEAK		
		VA	VB	VC
@ POI (100% drop)	V1	122.60	122.40	122.14
	V2	122.32	122.12	121.87
	Diff.	0.23%	0.23%	0.22%

Table #4: The Voltage Change on the Normal Feeder #3660 at Customer POI near Pole 6317 upon Sudden Loss of the 1500 kW PV Generator at Peak Load Periods (Scenario A) using Static Method of Voltage Change.

There is an insignificant voltage change at Woodmont Substation Bus #2 (Bus having the Normal Feeder #3660) for a sudden loss of the generating facility.

In the event of a contingency on Feeder #3660 at peak load periods the DG site load of the Feeder will be transferred to Woodmont Substation Feeder #3650, which is the backup to this area.

		PEAK		
		VA	VB	VC
@ POI (100% drop)	V1	116.99	116.85	115.61
	V2	115.71	115.64	114.36
	Diff.	1.07%	1.01%	1.04%

Table #5: The Voltage Change on the Backup Feeder #3650 at Customer POI Pole 6317 upon Sudden Loss of the 1500 kW PV Generator at Peak Load Periods (Scenario A) using Static Method of Voltage Change.

Table #5 shows the average voltage change measured at the customer's POI Pole 6317 due to the sudden loss of the 1500 kW PV generator when Feeder #3650 backs up Feeder #3660. The voltage changes are 1.07%, 1.01% and 1.04% on Phase A, B and C, respectively, which is more than the 1% voltage change threshold value that would be of concern. *After further review, the proposed project would have minor or no adverse effect on the Distribution System during the contingency conditions when Feeder #3650 picks up the full load from Feeder #3660. Note, it is unlikely Feeder #3650 would be required to support the entire load from feeder #3660; this load would generally be shared between several circuits if the need arises.*

Voltage Change – Scenario B (1500 kW DG, Minimum Load): Table #6 shows the average voltage change measured at the customer's POI Pole 6317 due to the sudden loss of the 1500 kW PV generator when interconnected to Feeder #3660. The voltage changes are 0.22%, 0.21% and

0.21% on Phase A, B and C, respectively. This voltage change is less than the 1% change threshold value that would be of concern.

		MINIMUM		
		VA	VB	VC
@ POI (100% drop)	V1	118.8	118.9	118.6
	V2	118.6	118.6	118.3
	Diff.	-0.17%	-0.25%	-0.25%

Table #6: The Voltage Change on the Normal Feeder #3660 at Customer POI Pole #3660 upon Sudden Loss of the 1500 kW PV Generator at Minimum Load Periods (Scenario B) using Static Method of Voltage Change.

There is an insignificant voltage change at Woodmont Substation Bus #2 (Bus having the Normal Feeder #3660) for a sudden loss of the PV generator.

3.2 VOLTAGE FLUCTUATION ANALYSIS

The distribution system will experience a change in the primary voltage as a result of the connection or sudden loss of the proposed 1500 kW PV at peak load (Scenario A) or at minimum load (Scenario B). The voltage fluctuation analysis investigated the extent that this voltage change would affect the distribution system voltage regulating equipment, including the voltage change at Woodmont Substation. The control settings of this equipment were examined to determine if the proposed generation will adversely impact the equipment's settings or its service duty.

For the normal operating case with Feeder #3660 supplying the customer, there is minimal voltage change at the Woodmont Substation Bus for the loss of the 1500 kW PV generation at peak load (Scenario A) or minimum load (Scenario B). Since the voltage change measured at the substation is minimal, it will not affect the load tap changers on the substation transformers because the voltage change is less than the 1 V bandwidth of change needed for the tap changer controls to initiate movement.

The typical maximum number of fluctuations of PV output due to variations in cloud cover based on industry available data is approximately 2.5 fluctuations per minute from maximum to minimum output. The greatest voltage change that can be expected was determined to be 0.23% on POI during peak load. Therefore, the result of the voltage fluctuation analysis is that a voltage flicker of no more than 0.23% may occur no more than three times per minute, and this would be below the industry accepted threshold of irritation.



3.3 *SYSTEM IMBALANCE IMPACTS*

The UI 13.8 kV distribution system is normally imbalanced like nearly all U.S. utility distribution systems. The available load data suggests that the main feeder (Feeder #3660) total demand is fairly balanced with imbalance of approximately 3.63 % at peak and 1.30 % at minimum load conditions. Upon the proposed project interconnection, the imbalance is increased to 4.70 % at peak and decreased to 0.95% at minimum load conditions. The proposed configuration of the 1500 kW PV generator with the existing utility 2000 kVA 13.8 kV/0.48 kV, Wye Grounded/Wye Grounded interconnection transformer need to be able to handle any zero-sequence currents absorbed from this unbalance. The DG will share the system zero sequence load current with the substation transformers. In all cases the imbalance is within the EDC's operating tolerance. The proposed generation configuration operating at unity power factor is not expected to adversely impact any existing customer load imbalance but will slightly worsen it.

3.4 *POTENTIAL FOR FERRORESONANCE*

Ferroresonance refers to a special kind of resonance that involves system capacitance and the iron-core inductance of a transformer. Typically, the system capacitance of concern is the 15kV underground (UG) service entrance cable capacitance since it is most likely to be isolated with the transformer.

Ferroresonance generally occurs during a system imbalance, usually during switching, or when there is an open-phase condition with the conductor supplying the transformer. This unbalanced condition places capacitance in series with transformer magnetizing impedance. This can result in high over-voltages that may lead to failures in transformers, cables, arresters, and customer equipment.

The transformer's primary connection is a critical parameter in the analysis of ferroresonance. Certain transformer winding connections are highly susceptible to ferroresonance and some winding connections are less susceptible to ferroresonance. Transformers that are delta connected on the primary side (13.8 kV) are more susceptible to ferroresonance than those connected grounded wye. Also, there is a greater chance of ferroresonance when the transformer is lightly loaded, which will be the case due to a DG feeding into the distribution system when the customer's load falls below that of the DG's output.

Over-voltages greater than 1.25 p.u. can damage equipment during an open-phase condition. Analysis indicates that a primary UG cable run from the switching device to the transformer that has a high capacitance in combination with a lightly loaded transformer can lead to a ferroresonance susceptible condition.

The utility owned existing one 2000 kVA 13.8 kV/0.48 kV, Wye Grounded/Wye Grounded interconnection transformers will be less susceptible to a ferroresonant condition for any length



of cable due to the grounded primary of the transformer. The developer has secondary SEL 351R relay protection, also a 50, 50G relay at high side to eliminate the concerns. However, it is required to have a Utility owned PCC recloser with SEL 651R.

3.5 UNINTENTIONAL ISLANDING

The generator must adhere to IEEE Standard 1547 that mandates a DG must detect an unintentional islanding condition and cease to energize the Electric Power System (EPS) within two seconds of the occurrence. An islanding condition results whenever the DG continues to power a location even though electrical grid power from the local EPS is no longer present. This would occur if the feeder breaker were opened for any reason other than for a fault on the feeder, or if any other manual switching device in the feeder main line to the DG is opened. It should be noted that there may be interaction with other generators on the feeder.

The issues that arise from islanding depend on the DG system configuration like transformer connections and type of generation. In the case of the Stag Industrial Holdings (40 Pepes Farm Rd, Milford) PV project, the anti-islanding protection schemes in the inverters are expected to halt export of power when the potential for an islanding condition is detected.

Exhibit D






Traveling North on Pepe Farm Road



Traveling North on Pepe Farm Road



Traveling South on Pepe Farm Road□




Traveling South on Pepe Farm Road



Traveling South on Pepe Farm Road

Exhibit E



Cross-Sections

Base Flood Elevations

Levees

Coastal Transects

Transect Baselines

General Structures

River Mile Markers

Exhibit F



Connecticut Aquifer Protection Areas

Connecticut Department of Energy and Environmental Protection





Exhibit G

Exhibit H



Connecticut Environmental Land Use Restrictions

Connecticut Department of Energy and Enviro



About


An Environmental Land Use Restriction (ELUR) is an easement granted to the Commissioner of DEEP by the property owner that is recorded on the municipal land records. The purpose of an ELUR is to minimize the risk of human exposure to pollutants and hazards to the environment by preventing specific uses or activities at a location of a property. An ELUR is a tool to achieve remedial goals for a property to be exposed to exposure risk associated with its use.

For more information, please see the [Environmental Land Use Restrictions](#) page or contact the ELUR Coordinator at deep.eur@ct.gov

This map was last updated on January 6, 2021

Exhibit I

Northern long-eared bat areas of concern in Connecticut
to assist with Federal Endangered Species Act Compliance



March 6, 2019

For information on federal requirements visit <http://www.fws.gov/midwest/endangered/mammals/nlebb/>

Exhibit J



U.S. Fish and Wildlife Service

National Wetlands Inventory

40 Pepe Farm Road



November 20, 2021

Wetlands

Estuarine and Marine Deepwater

Estuarine and Marine Wetland

Freshwater Emergent Wetland

Freshwater Forested/Shrub Wetland

Freshwater Pond

Lake

Other

Riverine

This map is for general reference only. The US Fish and Wildlife Service is not responsible for the accuracy or currentness of the base data shown on this map. All wetlands related data should be used in accordance with the layer metadata found on the Wetlands Mapper web site.

Exhibit K

June 2021



This map is intended for use as a preliminary screening tool for conducting a Natural Diversity Data Base Review Request. To use the map, locate the project boundaries and any additional affected areas. If the project is within a hatched area there may be a potential conflict with a listed species. For more information, complete a Request for Natural Diversity Data Base State Listed Species Review form (DEP-APP-007), and submit it to the NDDDB along with the required maps and information. More detailed instructions are provided with the request form on our website.

www.ct.gov/deep/nddbrequest

Use the CTECO Interactive Map Viewers at <http://cteco.uconn.edu> to more precisely search for and locate a site and to view aerial imagery with NDDB Areas.

QUESTIONS: Department of Energy and
Environmental Protection (DEEP)
79 Elm St, Hartford, CT 06106
email: deep.nddbrequest@ct.gov
Phone: (860) 424-3011




Exhibit L

Dynamic Energy Solutions, LLC
Stag Pepe Farm
Decommissioning Plan



Provided by:
Dynamic Energy Solutions, LLC
484.318.8800 / www.dynamicenergyusa.com
Confidential & Proprietary - For Intended Recipients Only

Table of Contents

Executive Summary..... 3

Introduction..... 3

Decommissioning Plan Overview..... 4

 Decommissioning After Construction

 Site Restoration

Decommissioning of the Solar Facility..... 5

 Equipment Dismantling and Removal

 Decommissioning Costs

 Financial Assurance

Executive Summary

The decommissioning plan has been prepared to account for all activities related to removal and restoration of this site during and after decommissioning. The site shall include one project with a nameplate rating of 1.5 MW AC. The decommissioning plan provides all necessary steps for the decommissioning phase of the project.

Decommissioning involves the removal of all rooftop, surface and sub-surface equipment. All structures including their foundations and all electrical equipment and material shall be removed.

The Decommissioning of the project will follow all local, state and federal guidelines for removal, recycling and disposal of all equipment. As with any construction, a company representative manager will be responsible for providing detailed plans for locations for recycling and disposal. They will also be responsible for providing site safety plans and meeting all safety expectations.

Introduction

The anticipated operational life of this PV solar facility is 25-30 years. All guidelines set forth by Local, State and Federal governing bodies of that time shall be followed for removal, recycling, disposal and safety. The decommissioning shall be complete when all structures have been removed from the site to the extent they are not otherwise in, or proposed to be placed into, productive use and the site is restored to the condition it was in prior to the erection of the PV solar facility. All decommissioning activities shall be overseen by the authority having jurisdiction and are subject to all permitting regulations and requirements.

Site Restoration

Once solar facility has been removed, it is expected that the site will be returned to as close to its original conditions as possible. Some minor grading may be required; topsoil (if removed) will be reapplied to allow for reseeding and growth.

Decommissioning of the Solar Facility

Equipment Dismantling and Removal

(Approximately 6 weeks decommissioning timeframe)

1. Obtain permit from the Town
2. Disconnect all utility grid power
3. Move all disconnects to the off position
4. Disconnect all above ground wirings, cables, and electrical connections
5. Remove all PV Modules
6. Remove Inverters, racking and associated equipment
7. Remove all electrical switchgear, transformers, and their foundations
8. Remove DAS equipment, feeders, and conduit
9. Excavate and remove Underground feeders and conduit
10. Remove all MV feeders and utility poles

Exhibit M

July 23, 2021

Attn: Mr. Pat Hastings
Dynamic Energy
1550 Liberty Ridge Drive, Suite 310
Wayne, PA 19087

(484) 318-8802

RE: STAG – Pepe Farms
Roof Framing Analysis
40 Pepes Farm Road
Milford, CT 06460

SEI Project No.: 21355.00

Dear Mr. Hastings,

Structural Enginuity Inc. (SEI) has analyzed the existing building for a new roof solar array using the 2018 Connecticut State Building Code. Based on Dynamic Energy's site observations, the roof framing is understood to consist of a metal deck on 30" deep joists spaced 6'-2" apart and spanning between 36" deep joist girders. The building uses steel columns consisting of wide flange shapes.

The exiting roof has been analyzed to support a new solar array system. The building construction can support a new solar PV array with a maximum average load of 6.0 psf. These proposed loads and the analysis of the existing members can be seen in SEI's attached calculations. This weight is typically enough to accommodate a fully ballasted racking system. Therefore, it is SEI's professional opinion that the existing roof framing is structurally adequate to support the proposed solar array system. It should be noted that the proposed loading is assuming that the proposed solar array covers the entirety of the roof and the existing framing may be able to support a higher load for an array that is limited to only a portion of the roof surface. If a higher load is necessary, SEI would need to further analyze the detailed racking layout in order to determine if the framing is acceptable.

Please contact our office, at your convenience, should you have any further questions relating to this matter.


Sincerely,



Peter Martin
Engineer III
pmartin@structuralenginuityinc.com



Allan T. Myket, P.E.
President/Founder
amyket@structuralenginuityinc.com



7/23/2021

Structural Enginuity Inc.

Attachments:

- SEI Roof Structural Framing Analysis
- Dynamic Energy Drawings

**Structural Enginuity, Inc.**

1815 W. Diehl Rd, Ste 100

Naperville, IL 60563

(630) 219-1997

www.structuralenginuityinc.com**Project Name:** STAG Industrial Holdings**Project No.:** 21355.00**Client Name:** Dynamic Energy**Date:** 7/23/2021**Project Name:** STAG INDUSTRIAL HOLDINGS

Roof Structural Analysis

40 Peper Farm Road

Milford, CT 06460

Project Client: Dynamic Energy™

1550 Liberty Ridge Drive, Suite 310

Wayne, PA 19087

(877) 809-8884

Client Contact: Pat Hastingsphastings@dynamicenergy.com**Design References:** 2018 Connecticut State Building Code

ASCE 7-16

Scope of Work:

Provide structural engineering services required in the preparation of construction contract documents for the installation of solar panels at the address listed above. The racking system and proposed array layout, provided by client, will be used in conformance with the 2018 Connecticut State Building Code to determine if the existing structure has the capacity to support the addition of the array.

Existing Structure:

The storage facility is approximately 642'-5" x 315'-4" with a flat roof. The roof is supported by 30" deep open web steel joists which run to 36" deep joist girders.



Loads

**Structural Enginuity, Inc.**

1815 W. Diehl Rd, Ste 100

Naperville, IL 60563

(630) 219-1997

www.structuralenginuityinc.com

Project Name: STAG Industrial Holdings

Project No.: 21355.00

Client Name: Dynamic Energy

Date: 7/23/2021

DEAD LOADS

Building Section: Roof 1
Building Section Description: Solar PV modules to be mounted on roof with a ballasted racking system. The roof consists of a waterproofing membrane over rigid insulation and a metal deck. The deck is supported by open web metal bar joists

Existing Dead Loads

Roof deck with foam insulation	3	psf
Metal Deck	3	psf
Steel Joists	3	psf
MEP & Misc	5	psf
	14	psf

Proposed Dead Loads

Proposed Solar Array	6	psf
----------------------	---	-----

LIVE LOADS

Building Section: Main Roof

Proposed Live Loads

Roofs - Ordinary flat pitched, and curved roofs ¹	20	psf	IBC 2018 Table 1607.1
--	----	-----	-----------------------

Note 1: Per IBC 2018 1607.13.5.1: Roof live loads need not be applied to the area covered by photovoltaic panels where the clear space between the panels and the roof surface is 24 inches or less.

**Structural Enginuity, Inc.**

1815 W. Diehl Rd, Ste 100

Naperville, IL 60563

(630) 219-1997

www.structuralenginuityinc.com

Project Name: STAG Industrial Holdings

Project No.: 21355.00

Client Name: Dynamic Energy

Date: 7/23/2021

SNOW LOADSGround snow load, p_g

30

psf

CT BC 2018 Appendix N

Exposure Factor, C_e

1

ASCE Table 7.3-1

Thermal Factor, C_t

1.2

ASCE Table 7.3-2

Importance Factor, I_s

1

ASCE Table 1.5-2

Flat roof snow load, $p_f = 0.7C_eC_tI_s p_g$

25.2

psf

ASCE Equation 7.3-1

Building Section:

Main Roof

Roof Slope

1.2

degrees

Roof Slope Factor, C_s

1

ASCE Fig 7.4-1

Minimum snow load for roofs with slopes less than 15 degrees

 $p_m = 20I_s$

20

psf

ASCE 7.3.4

Controlling snow load**25.2****psf**



Decking Check



Structural Enginuity, Inc.

1815 W. Diehl Rd, Ste 100
Naperville, IL 60563
(630) 219-1997

www.structuralenginuityinc.com

Project Name:	STAG Industrial Holdings
Project No.:	21355.00
Client Name:	Dynamic Energy
Date:	7/23/2021

DECKING:

Assume Vulcraft 1.5B 22 Gauge roof deck
3 span condition
6'-2" ft span

*Per inspection, existing metal
deck is type 1.5B deck
manufactured by Vulcraft.*

Allowable loading

87 psf

Vulcraft Deck Catalog

Roof loading

Dead Load	14	psf
Roof Live Load	20	psf
Snow Load	25.2	psf
Proposed Solar Array	6	psf

Load combinations

D	14	psf
D+Lr	34	psf
D+S+Solar	45.20	psf
D+0.75Lr	29	psf
D+0.75S	32.9	psf

CONTROLS


Controlling load combination **45.2 psf** < Allowable load = **87 psf** **OK**

Vulcraft 1.5B 22 Gauge deck OK



Framing Check

GENERAL STANDARD JOIST ANALYSIS																																																							
For Steel Joists Considered as Simple-Span Beams Subjected to Non-Standard Loads																																																							
Job Name:		Subject:																																																					
Job Number:		Originator:	Checker:																																																				
Input Data:																																																							
Joist Data:																																																							
Designation =	K-series																																																						
Span, L =	38.7100	ft.																																																					
Modulus, E =	29000000	psi																																																					
Inertia, Ix =	382.86	in. ⁴	W(LL) =	253																																																			
Original Design or Capacity Loads:																																																							
Full Uniform:																																																							
w =	336	plf																																																					
<div style="display: flex; justify-content: space-around;"> <div> <table border="1" style="background-color: yellow;"> <thead> <tr> <th></th> <th>Start</th> <th>End</th> </tr> </thead> <tbody> <tr><td>Distributed:</td><td>b (ft.)</td><td>we (plf)</td></tr> <tr><td>#1:</td><td></td><td></td></tr> <tr><td>#2:</td><td></td><td></td></tr> <tr><td>#3:</td><td></td><td></td></tr> <tr><td>#4:</td><td></td><td></td></tr> <tr><td>#5:</td><td></td><td></td></tr> <tr><td>#6:</td><td></td><td></td></tr> <tr><td>#7:</td><td></td><td></td></tr> <tr><td>#8:</td><td></td><td></td></tr> </tbody> </table> </div> <div> <table border="1" style="background-color: yellow;"> <thead> <tr> <th></th> <th>c (ft.)</th> <th>M (ft-lbs)</th> </tr> </thead> <tbody> <tr><td>Moments:</td><td></td><td></td></tr> <tr><td>#1:</td><td></td><td></td></tr> <tr><td>#2:</td><td></td><td></td></tr> <tr><td>#3:</td><td></td><td></td></tr> <tr><td>#4:</td><td></td><td></td></tr> </tbody> </table> </div> </div>						Start	End	Distributed:	b (ft.)	we (plf)	#1:			#2:			#3:			#4:			#5:			#6:			#7:			#8:				c (ft.)	M (ft-lbs)	Moments:			#1:			#2:			#3:			#4:					
	Start	End																																																					
Distributed:	b (ft.)	we (plf)																																																					
#1:																																																							
#2:																																																							
#3:																																																							
#4:																																																							
#5:																																																							
#6:																																																							
#7:																																																							
#8:																																																							
	c (ft.)	M (ft-lbs)																																																					
Moments:																																																							
#1:																																																							
#2:																																																							
#3:																																																							
#4:																																																							
<div style="display: flex; justify-content: space-around;"> <div> <table border="1" style="background-color: yellow;"> <thead> <tr> <th></th> <th>a (ft.)</th> <th>P (lbs.)</th> </tr> </thead> <tbody> <tr><td>Point Loads:</td><td></td><td></td></tr> <tr><td>#1:</td><td></td><td></td></tr> <tr><td>#2:</td><td></td><td></td></tr> <tr><td>#3:</td><td></td><td></td></tr> <tr><td>#4:</td><td></td><td></td></tr> <tr><td>#5:</td><td></td><td></td></tr> <tr><td>#6:</td><td></td><td></td></tr> <tr><td>#7:</td><td></td><td></td></tr> <tr><td>#8:</td><td></td><td></td></tr> <tr><td>#9:</td><td></td><td></td></tr> <tr><td>#10:</td><td></td><td></td></tr> <tr><td>#11:</td><td></td><td></td></tr> <tr><td>#12:</td><td></td><td></td></tr> <tr><td>#13:</td><td></td><td></td></tr> <tr><td>#14:</td><td></td><td></td></tr> <tr><td>#15:</td><td></td><td></td></tr> </tbody> </table> </div> </div>						a (ft.)	P (lbs.)	Point Loads:			#1:			#2:			#3:			#4:			#5:			#6:			#7:			#8:			#9:			#10:			#11:			#12:			#13:			#14:			#15:		
	a (ft.)	P (lbs.)																																																					
Point Loads:																																																							
#1:																																																							
#2:																																																							
#3:																																																							
#4:																																																							
#5:																																																							
#6:																																																							
#7:																																																							
#8:																																																							
#9:																																																							
#10:																																																							
#11:																																																							
#12:																																																							
#13:																																																							
#14:																																																							
#15:																																																							
New Design Loads:																																																							
Full Uniform:																																																							
w =		plf																																																					
<div style="display: flex; justify-content: space-around;"> <div> <table border="1" style="background-color: yellow;"> <thead> <tr> <th></th> <th>Start</th> <th>End</th> </tr> </thead> <tbody> <tr><td>Distributed:</td><td>b (ft.)</td><td>we (plf)</td></tr> <tr><td>#1:</td><td>0.0000</td><td>86.33333</td></tr> <tr><td>#2:</td><td>0.0000</td><td>155.4</td></tr> <tr><td>#3:</td><td>0.0000</td><td>37</td></tr> <tr><td>#4:</td><td></td><td></td></tr> <tr><td>#5:</td><td></td><td></td></tr> <tr><td>#6:</td><td></td><td></td></tr> <tr><td>#7:</td><td></td><td></td></tr> <tr><td>#8:</td><td></td><td></td></tr> </tbody> </table> </div> <div> <table border="1" style="background-color: yellow;"> <thead> <tr> <th></th> <th>c (ft.)</th> <th>M (ft-lbs)</th> </tr> </thead> <tbody> <tr><td>Moments:</td><td></td><td></td></tr> <tr><td>#1:</td><td></td><td></td></tr> <tr><td>#2:</td><td></td><td></td></tr> <tr><td>#3:</td><td></td><td></td></tr> <tr><td>#4:</td><td></td><td></td></tr> </tbody> </table> </div> </div>						Start	End	Distributed:	b (ft.)	we (plf)	#1:	0.0000	86.33333	#2:	0.0000	155.4	#3:	0.0000	37	#4:			#5:			#6:			#7:			#8:				c (ft.)	M (ft-lbs)	Moments:			#1:			#2:			#3:			#4:					
	Start	End																																																					
Distributed:	b (ft.)	we (plf)																																																					
#1:	0.0000	86.33333																																																					
#2:	0.0000	155.4																																																					
#3:	0.0000	37																																																					
#4:																																																							
#5:																																																							
#6:																																																							
#7:																																																							
#8:																																																							
	c (ft.)	M (ft-lbs)																																																					
Moments:																																																							
#1:																																																							
#2:																																																							
#3:																																																							
#4:																																																							
<div style="display: flex; justify-content: space-around;"> <div> <table border="1" style="background-color: yellow;"> <thead> <tr> <th></th> <th>a (ft.)</th> <th>P (lbs.)</th> </tr> </thead> <tbody> <tr><td>Point Loads:</td><td></td><td></td></tr> <tr><td>#1:</td><td></td><td></td></tr> <tr><td>#2:</td><td></td><td></td></tr> <tr><td>#3:</td><td></td><td></td></tr> <tr><td>#4:</td><td></td><td></td></tr> <tr><td>#5:</td><td></td><td></td></tr> <tr><td>#6:</td><td></td><td></td></tr> <tr><td>#7:</td><td></td><td></td></tr> <tr><td>#8:</td><td></td><td></td></tr> <tr><td>#9:</td><td></td><td></td></tr> <tr><td>#10:</td><td></td><td></td></tr> <tr><td>#11:</td><td></td><td></td></tr> <tr><td>#12:</td><td></td><td></td></tr> <tr><td>#13:</td><td></td><td></td></tr> <tr><td>#14:</td><td></td><td></td></tr> <tr><td>#15:</td><td></td><td></td></tr> </tbody> </table> </div> </div>						a (ft.)	P (lbs.)	Point Loads:			#1:			#2:			#3:			#4:			#5:			#6:			#7:			#8:			#9:			#10:			#11:			#12:			#13:			#14:			#15:		
	a (ft.)	P (lbs.)																																																					
Point Loads:																																																							
#1:																																																							
#2:																																																							
#3:																																																							
#4:																																																							
#5:																																																							
#6:																																																							
#7:																																																							
#8:																																																							
#9:																																																							
#10:																																																							
#11:																																																							
#12:																																																							
#13:																																																							
#14:																																																							
#15:																																																							



Results of Joist Analysis:

Original Design or Capacity Loads:

End Reactions:

RL = lbs.

RR = lbs.

Minimum Design Web Member Shear:

V_w(min) = lbs. (25% of maximum end reaction for K-series and LH-series joists per SJI Spec's.)

Maximum Moments:

+M_x(max) = ft-lbs

@ X = ft.

-M_x(max) = ft-lbs

@ X = ft.

***Maximum Deflections:**

-Δ(max) = in.

@ X = ft.

+Δ(max) = in.

@ X = ft.

Δ(ratio) =

**Note: deflections shown above include a 15% increase above the values calculated using traditional "simple-beam" flexure in order to more closely match actual test results obtained by SJI.*

New Design Loads:

End Reactions:

RL = lbs.

RR = lbs.

Maximum Moments:

+M_x(max) = ft-lbs

@ X = ft.

-M_x(max) = ft-lbs

@ X = ft.

***Maximum Deflections:**

-Δ(max) = in.

@ X = ft.

+Δ(max) = in.

@ X = ft.

Δ(ratio) =

**Note: deflections shown above include a 15% increase above the values calculated using traditional "simple-beam" flexure in order to more closely match actual test results obtained by SJI.*

Maximum Stress Ratios:


S.R. = for Shear

@ X = ft.

S.R. = for Moment

@ X = ft.

Comments:





Appendix A: DynamiC Energy Drawings

STAG INDUSTRIAL HOLDINGS

40 PEPES FARM ROAD
MILFORD, CT 06460

STAG INDUSTRIAL HOLDINGS
40 PEPES FARM ROAD
MILFORD, CT 06460

DRAWING ISSUE
☐ INTERCONNECTION
☒ PERMITTING
☐ CONSTRUCTION
☐ RECORD

DATE	DESCRIPTION
06-04-2019	
REV #	PERMIT SET ISSUED
1	

DRAWING NAME

COVERSHEET

DRAWING NUMBER

G001

SYSTEM DESCRIPTION

TOTAL SYSTEM SIZE: 2160 kW DC STC TOTAL
MODULE TYPE: 400W JINKO
QUANTITY: 5400 MODULES
TOTAL STRINGS: 156 STRINGS
MODULES PER STRING: 15
TILT ANGLE: 10.0 DEGREES
AZIMUTH: 143.544 DEGREES

MODULE DESCRIPTION:

MAXIMUM POWER (W): 400 W
OPEN CIRCUIT VOLTAGE (Voc): 49.8 V
MAXIMUM POWER VOLTAGE (Vpm): 41.7 V
SHORT CIRCUIT CURRENT (Isc): 10.36 A
MAXIMUM POWER CURRENT (Ipm): 9.60 A
EFFICIENCY (%): 19.88 %
MAXIMUM SYSTEM VOLTAGE: 1500 VDC

INVERTER DESCRIPTION: CHINT POWER SYSTEMS


TYPE OF INVERTER: 50KW
TOTAL NUMBER OF INV: 30
MODEL NUMBER: CPS-SCA50KTL
DIMENSIONS: 1000*600*260mm
CONTINUOUS POWER: 50KW
DC PEAK POWER TRACKING RANGE: 480-850V
CEC PEAK EFFICIENCY: 98.5%

RACKING DESCRIPTION:

RACKING MANUFACTURER: DCE SOLAR
RACKING TYPE: BALLASTED



1 AERIAL PHOTO
SCALE: N.T.S.



2 VICINITY MAP
SCALE: N.T.S.

DRAWING LIST

G001	COVER SHEET
SPECIFICATIONS:	
G002	GENERAL & CONSTRUCTION NOTES
G003	CONSTRUCTION NOTES (CONTINUED)
G004	CONSTRUCTION NOTES (CONTINUED)
STRUCTURAL:	
S100	BUILDING OVERVIEW
S101	EXISTING STRUCTURAL LAYOUT & DETAILS
S101.1	EXISTING STRUCTURAL LAYOUT & DETAILS (CONT.)
ELECTRICAL:	
E100	PV PANEL & EQUIPMENT LAYOUT
E100.1	PV PANEL & RACKING LAYOUT
E101	INVERTER, RACKING & CONDUIT DETAILS
E102	PV PANEL & PANELBOARD SUPPORT DETAILS
E200	ONE-LINE DIAGRAM
E201	ONE-LINE LEGENDS & SETTINGS
E202	STRING LAYOUT & COMBINING ARCHITECTURE
E202.1	STRING LAYOUT & COMBINING ARCHITECTURE
E203	CALCULATION & EQUIPMENT SCHEDULE
E204	TYPICAL PV-GROUNDING DIAGRAM
E205	MONITORING DIAGRAM & PV SUBMETER DETAILS
E206	CONDUCTOR SIZE CALCULATION TABLE
E400	EQUIPMENT PLACARD LOCATIONS
E401	EQUIPMENT PLACARD LOCATIONS
E402	EQUIPMENT LABELS
E500	STAGING PLAN

DESIGN CRITERIA:


WIND SPEED: 123 MPH EXP.B
GROUND SNOW LOAD: 30 PSF
ROOF SNOW LOAD: 30 PSF

APPLICABLE CODES


2018 CONNECTICUT STATE
BUILDING CODE
ELECTRICAL CODE NFPA 70, 2017 ED,

STRUCTURAL ENGINEITY
1815 W. DIEHL RD SUITE 100
NAPERSVILLE, IL 60563


SEAL




1 EX STEEL DETAIL
S101 (COLUMNS)




2 EX STEEL DETAIL
S101 (BEAMS)




3 EX STEEL DETAIL
S101 (BEAMS)




4 EX STEEL DETAIL
S101 (SECTION)



5 EX STEEL DETAIL
S101 (PURLINS)



6 EX STEEL DETAIL
S101 (SECTION)



DRAWING ISSUE	
<input type="checkbox"/>	INTERCONNECTION
<input checked="" type="checkbox"/>	PERMITTING
<input type="checkbox"/>	CONSTRUCTION
<input type="checkbox"/>	RECORD

REV #	DATE	DESCRIPTION
1	05-04-2019	PERMIT SET ISSUED

DRAWING NAME

EXISTING STRUCTURAL LAYOUT & DETAILS

DRAWING NUMBER


S101

STRUCTURAL ENGINEER
1815 W. DIEHL RD SUITE 100
NAPERVILLE, IL 60563

SEAL



SEAL



DRAWING ISSUE
INTERCONNECTION
PERMITTING
CONSTRUCTION
RECORD

[illegible]

DRAWING NAME
EXISTING STRUCTURAL LAYOUT & DETAILS
DRAWING NUMBER
S101.1

Exhibit N

Mono

420W MBB Bifacial Mono PERC Half-cell Double Glass Module

JAM72D10 400-420/MB Series

Introduction

Assembled with MBB bifacial PERCUM cells and half-cell configuration, these double glass modules have the capability of converting the incident light from the rear side together with the front side into electricity, providing higher output power, lower temperature coefficient, less shading loss, as well as enhanced tolerance for mechanical loading.



Higher output power



More reliable, more stable
power generation



Less shading effect




Lower temperature coefficient

Superior Warranty

- 12-year product warranty
- 30-year linear power output warranty

0.5% Annual Degradation
Over 30 years



■ Additional Value From 30-Year Warranty ■ JA Standard

Comprehensive Certificates

- IEC 61215, IEC 61730, UL 61215, UL 61730
- ISO 9001: 2015 Quality management systems
- ISO 14001: 2015 Environmental management systems
- OHSAS 18001: 2007 Occupational health and safety management systems
- IEC TS 62941: 2016 Terrestrial photovoltaic (PV) modules – Guidelines for increased confidence in PV module design qualification and type approval



ECO-TOP

ROOFTOP MOUNTING SYSTEMS



Elevating the Future for Solar



ECO-TOP

The Eco-Top rooftop system's modular design makes installation and system design fast and easy.

- » The most effective wire support system available
- » Integrated (UL approved) grounding
- » Class A fire rated (UL approved)
- » Module tilting for ease of maintenance
- » Lowest system weight
- » SEAOC compliant
- » Fast to install

Integral Wind Deflector

Integral wind deflector minimizes system loading and also functions as a ballast tray, providing a location to place ballast in the array.

Structural Components

All components are constructed from g115 galvanized steel. Additionally, entire assembly has been rated as Class A fire rated by UL for fire safety.



Fasteners

- » Serrated flange heads
- » Vibration resistance and integral grounding and bonding
- » All nuts are wax coated to eliminate galling


Molded Rubber Pad

Durable recycled rubber ballast pads provide a safe mounting surface with a high coefficient of friction. This results in reduced system loads, while protecting all equipment by minimizing vibration. In most cases the rubber pad eliminates the need for a slip sheet.

- » UV Resistant (extended lifespan)
- » Recycled Rubber (LEED credits)




ECO-TOP



Grounding and Bonding


Grounding and bonding via serrated hardware certified to UL SDT 2703 (listing available upon request). It is recommended that a ILSCO GBL-4DBT ground lug be used.

Grounding lug attaches to the N-S Beam.




Wire Clips

UV-rated flexible wire ties with easy to install push clips. Wire clips can be mounted anywhere on the rear panel beam. (UL Approved)




Integrated Wire Support

Flexible, UV protected Wire Support provided on every panel. Wires can be easily added before or after panel assembly.



PV Module Tilting

Modules can quickly and securely be tilted for ease of wiring and maintenance.



TECHNICAL SPECIFICATIONS

Tilt Angle	5° / 10°
Module Suitability	All Major Brands
Shade Spacing	6in. / 20in.
Warranty	20 Years

DCE SOLAR serves as market leader in industrial grade solar mounting hardware and consulting. DCE Solar leverages world-class engineering, fabrication facilities and American master craftsmen to create a full catalog of superior fixed-tilt mounting solutions for ground arrays and fixed-tilt solutions for roofs.



Elevating the Future for Solar |  Made in America

DCE Solar

19410 Jetton Road Suite 220 Cornelius, NC 28031 USA

Telephone: 704-659-7474 **Fax:** 704-875-0781

info@DCEsolar.com www.DCEsolar.com

50/60kW, 1000Vdc String Inverters for North America

The 50 & 60kW (55 & 66kVA) medium power CPS three phase string inverters are designed for ground mount, large rooftop and carport applications. The units are high performance, advanced and reliable inverters designed specifically for the North American environment and grid. High efficiency at 98.8% peak and 98.5% CEC, wide operating voltages, broad temperature ranges and a NEMA Type 4X enclosure enable this inverter platform to operate at high performance across many applications. The CPS 50/60kW products ship with either the standard wire-box or the H4 style wire-box, each fully integrated and separable with touch safe fusing, monitoring, and AC and DC disconnect switches. The CPS Flex Gateway enables monitoring, controls and remote product upgrades.

Key Features

- 55 & 66kVA rating allows max rated Active Power @ ± 0.91 PF
- Selectable Max AC Apparent Power of 50/55kVA and 60/66kVA
- NEC 2014/17 compliant & UL listed Arc-Fault circuit protection
- 0-90° Mounting orientation for lay flat roof installs
- Touch safe DC Fuse holders adds convenience and safety
- Optional Flex Gateway enables remote FW upgrades
- Integrated AC & DC disconnect switches
- 3 MPPT's with 5 inputs each for maximum flexibility
- Copper and Aluminum compatible AC connections
- NEMA Type 4X outdoor rated, tough tested enclosure
- UL1741 SA Certified to CA Rule 21
- Separable wire-box design for fast service
- Standard 10 year warranty with extensions to 20 years
- Generous 1.5 DC/AC Inverter Load Ratio



CPS SCA50KTL-DO/US-480
CPS SCA60KTL-DO/US-480



50/60kW Standard Wire-box



50/60kW H4 Wire-box

Model Name	CPS SCA50KTL-DO/US-480	CPS SCA60KTL-DO/US-480
DC Input		
Max. PV Power	75kW (30kW per MPPT)	90kW (33kW per MPPT)
Max. DC Input Voltage	1000Vdc	
Operating DC Input Voltage Range	200-950Vdc	
Start-up DC Input Voltage / Power	330V / 80W	
Number of MPP Trackers	3	
MPPT Voltage Range @ PF>0.99 ¹	480-850Vdc	540-850Vdc
Max. PV Short-Circuit Current (Isc x 1.25)	204A (68A per MPPT)	
Number of DC Inputs	15 inputs, 5 per MPPT	
DC Disconnection Type	Load rated DC switch	
DC Surge Protection	Type II MOV, 2800V _C , 20kA I _{TM} (8/20μS)	
AC Output		
Rated AC Output Power @ PF>0.99 to ±0.91 ²	50kW	60kW
Max. AC Apparent Power (Selectable)	50/55kVA	60/66kVA
Rated Output Voltage	480Vac	
Output Voltage Range ³	422 - 528Vac	
Grid Connection Type	3Φ / PE / N (Neutral optional)	
Max. AC Output Current @480Vac	60.2/66.2A	72.2/79.4A
Rated Output Frequency	60Hz	
Output Frequency Range ³	57 - 63Hz	
Power Factor	>0.99 (±0.8 adjustable)	
Current THD @ Rated Load	<3%	
Max. Fault Current Contribution (1 Cycle RMS)	64.1A	
Max. OCPD Rating	110A	125A
AC Disconnection Type	Load rated AC switch	
AC Surge Protection	Type II MOV, 1240V _C , 15kA I _{TM} (8/20μS)	
System and Performance		
Topology	Transformerless	
Max. Efficiency	98.8%	
CEC Efficiency	98.5%	
Stand-by / Night Consumption	<1W	
Environment		
Enclosure Protection Degree	NEMA Type 4X	
Cooling Method	Variable speed cooling fans	
Operating Temperature Range ⁴	-22°F to +140°F / - 30°C to +60°C ⁴	
Non-Operating Temperature Range ⁵	No low temp minimum to +158°F / +70°C maximum ⁵	
Operating Humidity	0 to 100%	
Operating Altitude	13,123.4ft / 4000m (derating from 9842.5ft / 3000m)	
Audible Noise	<60dBA @ 1m and 25°C	
Display and Communication		
User Interface and Display	LCD+LED	
Inverter Monitoring	SunSpec, Modbus RS485	
Site Level Monitoring	CPS Flex Gateway (1 per 70 inverters)	
Modbus Data Mapping	CPS	
Remote Diagnostics / FW Upgrade Functions	Standard / (with Flex Gateway)	
Mechanical		
Dimensions (HxWxD)	39.4 x 23.6 x 10.24in. (1000 x 600 x 260mm)	
Weight	Inverter: 123.5lbs/56kg; Wire-box: 33lbs/15kg	
Mounting / Installation Angle ⁶	0 to 90 degrees from horizontal (vertical, angled, or lay flat) ⁶	
AC Termination ⁷	M8 Stud Type Terminal Block (Wire range: #6 - 3/0AWG CU/AL ⁷ , Lugs not supplied)	
DC Termination	Screw Clamp Fuse Holder (Wire range: #14 - #6AWG CU), Optional H4 (Amphenol)	
Fused String Inputs (5 per MPPT) ⁸	15A fuses provided (Fuse values up to 30A acceptable) ⁸	
Safety		
Certifications and Standards	UL1741SA-2016, UL1699B, CSA-C22.2 NO.107.1-01, IEEE1547a-2014; FCC PART15	
Selectable Grid Standard and SRD	IEEE1547a-2014, CA Rule 21	
Smart-Grid Features	Voltage-RideThru, Frequency-RideThru, Soft-Start, Volt-Var, Frequency-Watt, Volt-Watt	
Warranty		
Standard	10 years	
Extended Terms	15 and 20 years	

1) See user manual for further information regarding MPPT Voltage Range when operating at non-unity PF.

2) Active Power Derating begins; at PF=±0.91 to ±0.8 when Max AC Apparent Power is set to 55 or 66kVA.

3) The "Output Voltage Range" and "Output Frequency Range" may differ according to the specific grid standard.

4) Active Power Derating begins; at 40°C when PF=±0.9 and MPPT ≥V_{min}, at 45°C when PF=1 and MPPT V ≥ 700Vdc.


5) See user manual for further requirements regarding non-operating conditions.

6) Shade Cover accessory required for installation angles of 75 degrees or less.

7) AL requires bi-metallic compression lug or bi-metallic adapter.

8) Fuses values above 20A have additional spacing requirements or require the use of the Y-comb adapter. See user manual for details.

MECHANICAL DIAGRAMS



Remark: customized frame color and cable length available upon request

SPECIFICATIONS

Cell	Mono
Weight	25.0kg±3%
Dimensions	2037±2mm×1005±2mm×30±1mm
Cable Cross Section Size	4mm ² (12AWG)
No. of cells	144(6×24)
Junction Box	IP68, 3 diodes
Connector	QC 4.10-35
Cable Length (Including Connector)	Portrait:300mm(+)/400mm(-); Landscape:1200mm(+)/1200mm(-)
Packaging Configuration	34 Per Pallet
Front Glass/Back Glass	2.0mm/2.0mm

ELECTRICAL PARAMETERS AT STC

TYPE	JAM72D10 -400/MB	JAM72D10 -405/MB	JAM72D10 -410/MB	JAM72D10 -415/MB	JAM72D10 -420/MB
Rated Maximum Power(Pmax) [W]	400	405	410	415	420
Open Circuit Voltage(Voc) [V]	49.57	49.82	50.08	50.35	50.62
Maximum Power Voltage(Vmp) [V]	42.02	42.28	42.54	42.80	43.04
Short Circuit Current(Isc) [A]	10.14	10.20	10.26	10.32	10.37
Maximum Power Current(Imp) [A]	9.52	9.58	9.64	9.70	9.76
Module Efficiency [%]	19.5	19.8	20.0	20.3	20.5
Power Tolerance	0~+5W				
Temperature Coefficient of Isc(α _{Isc})	+0.044%/°C				
Temperature Coefficient of Voc(β _{Voc})	-0.272%/°C				
Temperature Coefficient of Pmax(γ _{Pmp})	-0.354%/°C				
STC	Irradiance 1000W/m ² , cell temperature 25°C, AM1.5G				

Remark: Electrical data in this catalog do not refer to a single module and they are not part of the offer. They only serve for comparison among different module types.

*Bifaciality=Pmax, rear/Rated Pmax, front

ELECTRICAL CHARACTERISTICS WITH DIFFERENT REAR SIDE POWER GAIN(REFERENCE TO 410W FRONT)

	5%	10%	15%	20%	25%
Backside Power Gain	5%	10%	15%	20%	25%
Rated Max Power(Pmax) [W]	431	451	472	492	513
Open Circuit Voltage(Voc) [V]	50.10	50.10	50.10	50.20	50.20
Max Power Voltage(Vmp) [V]	42.55	42.55	42.55	42.65	42.65
Short Circuit Current(Isc) [A]	10.76	11.28	11.79	12.30	12.81
Max Power Current(Imp) [A]	10.12	10.60	11.08	11.54	12.02


*For NexTracker installations static loading performance: front load measure 2400Pa, while back load measures 1800Pa.

OPERATING CONDITIONS


Maximum System Voltage	1500V DC(UL)
Operating Temperature	-40°C~+85°C
Maximum Series Fuse	20A
Maximum Static Load, Front*	5400Pa(112 lb/ft ²)
Maximum Static Load, Back*	2400Pa(50 lb/ft ²)
NOCT	45±2°C
Bifaciality*	70%±5%
Fire Performance	Type 29

CHARACTERISTICS


Current-Voltage Curve JAM72D10-410/MB



Power-Voltage Curve JAM72D10-410/MB



Current-Voltage Curve JAM72D10-410/MB





Three-Phase Pad-Mounted Transformers



Powering reliable solutions for you



Prolec GE offers a complete line of liquid-filled Three-Phase Pad-Mounted distribution transformers that meet applicable IEEE standards. These transformers are specifically designed for commercial and residential applications, such as hotels, hospitals, universities, among others. Our transformers are designed for outdoor installation with cabinets meeting C57.12.34 & C57.12.28.

Prolec GE Three-Phase Pad-Mounted Transformers use aluminum or copper windings and are optimized to maximize efficiency and footprint.

Standard offering

- Rating
 - Up to 3,750 kVA ONAN
- High Voltage
 - Up to 34,500 V Delta or Wye Connected
 - BIL up to 200 kV
 - Loop feed
 - Dead front
 - Bushing wells
- Low Voltage
 - Up to 1200 V Delta or Wye Connected
 - BIL up to 60 kV
- Frequency: 60 Hz
- 5-legged Core
- Temperature rise: 65°C
- Cooling class: ONAN
- Insulating fluid: Mineral oil
- Impedance: per C57.12.34
- Altitude: 3,300 FASL
- Mild steel tank & cabinet
- Powder paint system; Color: Green Munsell 7GY 3.29/1.5 or ANSI 70
- Built to all applicable IEEE C57.12.34
- Operation Step down
- Windings per Prolec GE standard

Optional features

- Rating 3,750 – 5,000 kVA
- High Voltage
 - Copper windings
 - Tap changer with 7 positions
 - Radial feed
 - Live front
 - Bushing wells + Inserts
 - Tap changer: $\pm 2, 2.5\%$
 - Integral bushing
 - Porcelain bushing
- Low Voltage
 - Copper windings
 - Epoxy, 2 pieces bushings, up to 12 holes blade
 - Epoxy, 1 piece bushings up to 12 holes blade
- Frequency: 50 Hz
- Temperature rise: 55°C, 55/65°C
- Cooling class: KNAN
- Insulating fluid: Natural ester fluid (VG-100 or FR3)
- Impedance per customer request
- Electrostatic shield
- Altitude up to 14850 FASL
- Internal switch
- Bay-O-Net expulsion fuses + current limiting fuses
- Under-oil internal arresters
- Stainless Steel 409 tank & cabinet
- Stainless Steel 304 tank & cabinet
- Infrared window
- Powder paint system & liquid finish color per customer request
- Seismic designs IBC Certified
- Operation Step-Up

Standard voltages

Standard Primary	
Voltage Ratings	Minimum BIL (kV)
Delta or Wye	
2400	45
4160	60
4800	60
7200	75
7620	75
12000	95
12470	95
13200	95
13800	95
16340	95
Grounded Wye	
4160GrdY/2400	65
12470GrdY/7200	95
13200GrdY/7620	95
13800GrdY/7970	95
22860GrdY/13200	125
23900GrdY/13800	125
24940GrdY/14400	125
34500GrdY/19920	150

Standard ratings

Standard kVA Ratings		
45	225	1000
75	300	1500
112.5	500	2000
150	750	2500

Overall typical dimensions for reference

kVA	Height	Width	Depth	Typ Weight (Lb)	Typ Gal Oil
75	66	46	65	2,550	136
112.5	66	46	65	2,750	145
150	69	46	66	2,900	145
225	69	50	69	3,500	164
300	69	53	71	3,800	171
500	74	62	70	5,950	284
750	75	72	72	6,950	275
1000	78	75	75	7,800	315
1500	83	80	83	10,600	375
2000	86	85	89	12,000	440
2500	87	88	96	14,000	490

For kVAs not listed, contact factory.

Dimensions and weights are approximate and subject to change without notice and should not be used for construction purposes.



Standards and certifications available









<http://www.t-e.com>
E-mail: sales@trelectric.com
Toll Free: 1-800-843-7994
Local: 605-534-3555
Fax: 605-534-3861


Fused Disconnect Line Up 15.5KV

Details	Stock Number	Record ID
14.4 KV Nominal - 17.0 KV Max		
110 KV Bil	Scale 1" = 36"	Draftsman: JB Salesman: Dan Bowen March 3, 2020



Incoming Cable
Section






REV.	DESCRIPTION	DATE	REVISION BY
1	FOR SUBMITTAL	07/01/2016	JRADKE


SHALLBETTER	
3110 Program Drive Opa-locka, FL 32067 www.shallbetter.com	
NOMINAL SYSTEM VOLTAGE	KV
MAXIMUM DESIGN VOLTAGE	15 KV
BASIC INSULATION LEVEL (BIL)	95 KV
CONTINUOUS CURRENT	400 AMP
MODEL NUMBER	SPXD-3151-66-SS-UC
SERIAL NUMBER	
CUSTOMER NUMBER	
DATE OF MANUFACTURE	...050521... XX/2016...

15KV, 400A, 95KV BIL PADMOUNT TRANSFORMER ENCLOSURE UNITED ILLUMINATING	
SIZE	D
LOC. NUMBER	
ENCLOSURE NUMBER	
SCALE	1:14
SHEET	1 OF 2


DIMENSIONS ARE PROVIDED FOR REFERENCE ONLY.
CONDUIT PENETRATIONS FOR AUX POWER ETC SHALL BE
MADE IN THE FIELD BY ETC.



REVISION		DESCRIPTION	DATE	REVISION BY
1		FOR SUBMITTAL	07/01/2016	J.BADKE




WIRING DIAGRAM



STRIP HEATER WIRING DIAGRAM

BOTH TERMINAL BLOCK IN ENCLOSURE



LV BOX LAYOUT

3110 Project Dr. Chico, VT 05701 (802) 885-1234		WELDED DIMENSIONS ARE IN PARENTHESES AS FOLLOWS: A) ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED. B) ALL DIMENSIONS ARE TO THE CENTERLINE OF THE PART UNLESS OTHERWISE SPECIFIED. C) ALL DIMENSIONS ARE TO THE OUTSIDE UNLESS OTHERWISE SPECIFIED. D) ALL DIMENSIONS ARE TO THE INSIDE UNLESS OTHERWISE SPECIFIED. E) ALL DIMENSIONS ARE TO THE CENTERLINE OF THE PART UNLESS OTHERWISE SPECIFIED.		1KV 600A 95KV DI PADMOUNT DISMOUNT PRIMARY METERING UNITED ILLUMINATING	
DATE	07/01/2016	DESIGNER	J.BADKE	SCALE	1:1
REV.	1	DESCRIPTION	FOR SUBMITTAL	SIZE	D
PROJECT NAME		PROJECT NUMBER		SHEET NUMBER	
PROJECT ADDRESS		PROJECT CITY		PROJECT STATE	
PROJECT ZIP		PROJECT PHONE		PROJECT FAX	
PROJECT EMAIL		PROJECT WEBSITE		PROJECT URL	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	
PROJECT CONTACT		PROJECT CONTACT		PROJECT CONTACT	