



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

[www.ct.gov/csc](http://www.ct.gov/csc)

### VIA ELECTRONIC MAIL

February 17, 2022

Kristen Grillo  
Senior Permitting Specialist  
Bloom Energy Corporation  
4535 North First Street  
San Jose, CA 95134  
[kristen.grillo@bloomenergy.com](mailto:kristen.grillo@bloomenergy.com)

RE: **PETITION NO. 1482** - Bloom Energy Corporation petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 700-kilowatt fuel cell facility and associated equipment to be located at Tully Health Center, 32 Strawberry Hill Court, Stamford, Connecticut.

Dear Ms. Grillo:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than March 4, 2022. Please submit an original and 15 copies to the Council's office and an electronic copy to [siting.council@ct.gov](mailto:siting.council@ct.gov). In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

**Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the March 4, 2022, deadline.**

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

A handwritten signature in blue ink, appearing to read "Melanie Bachman".

Melanie Bachman  
Executive Director

MB/IN

Cc: Service List dated February 1, 2022

**Petition No. 1482**  
**Bloom Energy Corporation**  
**Stamford Hospital/Tully Health Center**  
**32 Strawberry Hill Court**  
**Stamford, Connecticut**  
**Interrogatories**  
**February 17, 2022**

1. What is the estimated cost of the proposed project?
2. Referring to p. 10 of the Petition, has the City and/or abutters provided comments to Bloom since the Petition filing? If yes, summarize the comments.
3. In addition to the proposed bollards, what other security measures are proposed for the facility (e.g. fencing, locks, etc.)?
4. Referring to Petition Exhibit 4, identify the location of the fuel cell facility on the photos.
5. Does Bloom intend to install the foam dampening material at the doors and exhaust of the fuel cell units as referenced in Appendix A of the Noise Analysis?
6. Referring to Petition Exhibit 6 on p. 12, will Bloom provide a copy of the Fuel Cell Emergency Response Plan and conduct fuel cell operation/emergency training with City of Stamford emergency responders prior to the commencement of facility operation?
7. Provide typical construction workdays and hours.
8. Referring to Petition p. 4 paragraph 2, identify the media to be used for pipe cleaning procedures at the proposed facility in accordance with Public Act 11-101, An Act Adopting Certain Safety Recommendations of the Thomas Commission and Connecticut General Statutes § 16-50ii.