



# STATE OF CONNECTICUT

## CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

### VIA ELECTRONIC MAIL

May 12, 2022

Paul R. Michaud, Esq.  
Principal/Managing Attorney  
Michaud Law Group LLC  
101 Centerpoint Drive, Suite 230  
Middletown, CT 06457  
[pmichaud@michaud.law](mailto:pmichaud@michaud.law)

RE: **PETITION NO. 1492** – CT NSB ProjectCo LLC petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a 1.99-megawatt AC solar photovoltaic electric generating facility located at 486 Fitch Hill Road, Montville (Uncasville), Connecticut, and associated electrical interconnection.

Dear Attorney Michaud:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than June 2, 2022. Please submit an original and 15 copies to the Council's office and an electronic copy to [siting.council@ct.gov](mailto:siting.council@ct.gov). In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

**Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the June 2, 2022 deadline.**

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

A handwritten signature in black ink, appearing to read "Melanie A. Bachman".

Melanie A. Bachman  
Executive Director

C: Service List

MB/RM

**Petition No. 1492**

**CT NSB ProjectCo LLC  
Montville, Connecticut**

**Interrogatories – Set 2**

55. What is the additional cost to install a pad mounted interconnection? Would CT NSB ProjectCo be willing to install a pad-mounted interconnection to reduce the number of utility poles?
56. What is the estimated annual capacity factor of the proposed Project? (how much energy is actually produced compared with its maximum output rating?)
57. Referencing Interrogatory Response 54, submit the TCLP results for the HT SAAE modules.
58. Based on the TCLP Certificate for the Talesun modules provided in Interrogatory response 54, it appears theses panels exceed the regulatory thresholds for lead and would be considered hazardous waste upon disposal. Would the Petitioner be willing to substitute these panels for panels that are deemed non-hazardous waste under current regulatory criteria?
59. Referencing Interrogatory Response 31, the slope analysis map did not have corresponding colors in the Legend. Revise the map to include the slope information.
60. Does the solar array design include 15 feet of clear space from the edge of the solar panels to the perimeter fence? If not, in what locations is the fence closer than 15 feet?
61. On page 33 of the Petition Environmental Assessment, it states noise levels were calculated from the transformers to the nearest property line (234 feet). Provide the calculated noise level at this property line.