



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting_council@ct.gov

Web Site: portal.ct.gov/csc

VIA ELECTRONIC MAIL

April 18, 2022

Kristen Grillo
Senior Permitting Specialist
Bloom Energy Corporation
4535 North First Street
San Jose, CA 95134
kristen.grillo@bloomenergy.com

RE: **PETITION NO. 1503** - Bloom Energy Corporation petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 750-kilowatt fuel cell facility and associated equipment to be located at Milford Hospital, 300 Seaside Avenue, Milford, Connecticut.

Dear Ms. Grillo:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than May 9, 2022. Please submit an original and 15 copies to the Council's office and an electronic copy to siting_council@ct.gov. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the May 9, 2022, deadline.

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

MB/rm

cc: Service List dated April 1, 2022

Petition No. 1503
Bloom Energy Corporation
Milford Hospital - 300 Seaside Avenue, Milford
Interrogatories

1. What is the estimated cost of the proposed project?
2. Referring to Petition, pp. 10-11, has the City and/or abutters provided comments to Bloom since the Petition filing? If yes, summarize the comments.
3. Referring to Petition p. 4, identify the media to be used for pipe cleaning procedures at the proposed facility in accordance with Public Act 11-101, An Act Adopting Certain Safety Recommendations of the Thomas Commission and Connecticut General Statutes § 16-50ii.
4. Are bollards or other vehicle impact protective measures proposed along the north side of the facility adjacent to the hospital driveway? If yes, revise the site plan to include such measures. If no, what vehicle impact protection measures are proposed for this area?
5. Would the proposed fuel cell facility include foam noise dampening material at the fuel cell doors and exhaust ports? If yes, was the 5dB reduction included in the noise level calculation? If not, would Bloom be willing to install the foam dampening material? What is the extra cost for fuel cell units with the foam dampening material?
6. Referring to Petition p. 8, provide the calculation supporting the reduction in carbon emissions by more than 25%.