



**STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL**

Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935 Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
Web Site: portal.ct.gov/csc

VIA ELECTRONIC MAIL

February 28, 2023

Kenneth C. Baldwin, Esq.
Robinson & Cole LLP
280 Trumbull Street
Hartford, CT 06103-3597
kbaldwin@rc.com

RE: **PETITION NO. 1508** – Enfield Solar One, LLC and VCP, LLC d/b/a Verogy declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a 4.0-megawatt AC solar photovoltaic electric generating facility located at 110 North Street, Enfield, Connecticut, and associated electrical interconnection.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) is in receipt of your correspondence dated February 24, 2023 regarding compliance with Condition No. 4 of the Declaratory Ruling issued by the Council on July 22, 2022, and modified on August 5, 2022, for the above-referenced facility. Site Plan Sheet GD-01 includes the installation of landscape screening at the northeast corner of the facility along the fence line in accordance with Condition No. 4.

Therefore, the Council acknowledges that Condition No. 4 has been satisfied.

The February 24, 2023 correspondence also includes a request for project changes as follows:

- a. Modify the project layout from a fixed tilt racking system to a single-axis tracker racking system.
- b. Install 545 watt modules instead of 540 watt modules and reduce the number of panels from 11,050 to 10,452.
- c. Modify associated equipment to include 40 solar inverters, six AC disconnect switches/panel boards, and two 2000 kVA transformers.
- d. Relocate the facility access road by eliminating the portion that extends along the southwest edge of the site and extending the access road into the middle of the solar field, terminating at the electrical pads.
- e. Expand the project limit of disturbance to the south and east onto existing cleared fields to accommodate the tracker system and revised stormwater management features, as well as to maintain a minimum 100-foot buffer from wetland areas.

Pursuant to Condition No. 1 of the Council's July 22, 2022 Declaratory Ruling, as modified on August 5, 2022, the requested project changes are hereby approved. This approval applies only to the project changes described in the February 24, 2023 correspondence.

Please be advised that deviations from the standards established by the Council in the Declaratory Ruling are enforceable under the provisions of Connecticut General Statutes §16-50u.

Thank you for your attention and cooperation.

Sincerely,



Melanie A. Bachman
Executive Director

c: The Honorable Robert Cressotti, Mayor, Town of Enfield, (bcressotti@enfield.org)
Ellen Zoppo-Sassu, Town Manager, Town of Enfield (ezoppo@enfield.org)
Service List, dated April 26, 2022