

What Powers You

May 24th, 2022

Melanie Bachman, Esq.
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: PETITION NO. 1509 - Bloom Energy Corporation petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 300-kilowatt fuel cell facility and associated equipment to be located at Park Avenue Medical Center, 5520 Park Avenue, Trumbull, Connecticut.

Dear Ms. Bachman:

Please see the attached responses to the interrogatories provided to Bloom Energy on May 20th, 2022.

Respectfully,



Kristen Grillo
Senior Permitting Specialist | East Coast Field Office
Customer Installations Group | North America
(917) 803-4511
Kristen.Grillo@bloomenergy.com



Bloom Energy Corporation
4353 North First Street, San Jose, CA 95134
408 543 1500
www.bloomenergy.com

Petition No. 1509
Bloom Energy Corporation
Park Avenue Medical Center - 5520 Park Avenue, Trumbull

Interrogatories

1. What is the estimated cost of the proposed project?

Response: The estimated cost of the project is \$586,485.00

2. Referring to Petition, p. 11, have the Towns of Trumbull, Easton and Fairfield, the City of Bridgeport and/or abutters provided comments to Bloom since the Petition filing? If yes, summarize the comments.

Response: No comments have been provided by the City and/or the abutters notified.

3. Referring to Petition p. 4, identify the media to be used for pipe cleaning procedures at the proposed facility in accordance with Public Act 11-101, An Act Adopting Certain Safety Recommendations of the Thomas Commission and Connecticut General Statutes § 16-50ii.

Response: The media to be used for the pipe cleaning procedures at the proposed facility would be compressed air.