

10 INDUSTRIAL AVENUE, SUITE 3 MAHWAH, NJ 07430

PHONE: 201.684.0055 FAX: 201.684.0066

September 14th, 2022

Connecticut Siting Council 10 Franklin Square New Britain, CT 06051

T-Mobile Northeast LLC
Petition Request - Interrogatories Response
Petition No. 1532 - 376 Deercliff Road, Avon
Petition No. 1536 - 259 Commerce Street, East Haven

Dear Ms. Bachman,

Please see the below responses to the interrogatories sent over on August 31st, 2022 for the above referenced petitions.

- 1. The estimated cost for each project is \$20,000.
- The generators for both of these sites are outside of the fenced compounds due to the size constraints of the existing compounds. Both compounds cannot fit the generators with their required buffer zones. Locations were chosen based on existing ground land leases in place with Crown Castle and the underlying landlord.
- 3. The fuel tanks for both generators is 240 gallons.
- 4. The run time in the instance of loss of commercial power under full load is approximately 48 hours but varies based on the demand of each site during that time. Re-fueling would be required once the tank hits under 50% fuel.
- 5. The containment measure taken with these generators is a double walled fuel tank. These are internal to the unit.
- 6. The weekly testing run time will be conducted during the day to avoid any issues with adverse noise effects and any nighttime noise ordinances.
- 7. Neither the town nor any abutters have reached out to T-Mobile or Transcend Wireless regarding these two proposed projects.
- 8. This should read "installation of a backup generator at the Property." No temporary tower will be installed, this was a typo.

9. The typical time frame for installation of these generators is two to three weeks of work, from Monday to Friday 8AM-5PM. We are targeting November 7th through November 28th for these projects.

Sincerely,
Eric Breun
Eric Breun
Transcend Wireless
201-658-7728
ebreun@transcendwireless.com