

BRUCE L. MCDERMOTT
203.772.7787 DIRECT TELEPHONE
860.240.5723 DIRECT FACSIMILE
BMCDERMOTT@MURTHALAW.COM

November 2, 2022

Melanie A. Bachman, Esq.
Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: Petition No. 1540 - ReNew Developers, LLC petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a customer-side 4.0-megawatt fuel cell facility and associated equipment to be located at 234 Riverside Avenue, Bristol, Connecticut.

Dear Ms. Bachman:

Enclosed for filing with the Connecticut Siting Council ("Council") are ReNew Developers, LLC's responses to the Council's first set of interrogatories dated October 18, 2022.

An original and fifteen (15) copies of this filing will be sent to the Council by overnight mail.

Should you have any questions regarding this filing, please do not hesitate to contact me.

Very truly yours,



Bruce L. McDermott

Enclosure

Murtha Cullina LLP
265 Church Street
New Haven, CT 06510
T 203.772.7700
F 203.772.7723

Interrogatory CSC-1

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-1: Referencing pp. 6 and 7 and Exhibit C of the Petition, has the City of Bristol or abutters provided comments to ReNew since the Petition filing? If so, please summarize the comments.

A- CSC -1: No comments have been received from the City of Bristol or any abutting property owner since the Petition was filed with the Council.

Interrogatory CSC-2

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-2: Is the project, or any portion of the project, proposed to be undertaken by state departments, institutions or agencies, or to be funded in whole or in part by the state through any contract or grant?

A-CSC-2: No. Neither the project nor any portion of the project are proposed to be undertaken by state departments, institutions or agencies, or to be funded in whole or in part by the state through any contract or grant.

Interrogatory CSC-3

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-3: Was this project selected in a state or public utility-sponsored procurement?

A-CSC -3: No. The project was not selected in a state or public utility-sponsored procurement.

Interrogatory CSC-4

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-4: Would the existing abandoned building to the west of the proposed facility be demolished and removed for construction of the fuel cell facility and data center?

A-CSC-4: The existing abandoned building to the west of the proposed facility will be demolished and removed.

Interrogatory CSC-5

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-5: Referencing page 3 of the Petition:

- a. What is the status of the interconnection study?
- b. Is the project interconnection required to be reviewed by ISO-NE?
- c. Where is the point of electrical interconnection for the proposed facility?

A-CSC-5:

- a. The interconnection application was amended on October 5, 2022.
- b. The project interconnection does not need to be reviewed by ISO-NE.
- c. The electrical interconnection point is at Pole #4795S on the west side of East Street.

Interrogatory CSC-6

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-6: Provide site plans showing the location, distance and direction of the facility interconnection point and any associated new/existing utility poles.

A-CSC-6: See Exhibit CSC 6-1.

Interrogatory CSC-7

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-7: What security measures and/or other measures, such as bollards, would be employed to protect the fuel cell units/components from vandalism, impact or intrusion?

A-CSC-7: The Facility will be enclosed by an eight (8)-foot tall fence. The fence will be aesthetically designed as part of the overall fuel cell/data center complex. Both access gates will be padlocked.

Interrogatory CSC-8

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-8: Could the proposed soil stockpile area be relocated further from the Pequabuck River?

A-CSC-8: The proposed soil stockpile area has been moved to the northeastern corner of the Site. See Exhibit CSC 8-1.

Interrogatory CSC-9

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-9: Would landscaping be installed? If so, provide details and drawings showing the landscaping locations and design.

A-CSC-9: A landscaping plan will be done with the data center building plans that will include the fuel cell facility.

Interrogatory CSC-10

November 2, 2022

ReNew Developers, LLC

Witness: Peter Carli

Petition No. 1540

Page 1 of 1

Q-CSC-10: Provide complete contact information (including phone numbers) for the spill response contractor, and local, state and federal agencies referenced in the Petroleum Materials Storage and Spill Prevention section of the Resource Protection Plan behind Tab E of the Petition.

A-CSC-10: A spill response contractor will be selected after all project approvals are obtained, prior to commencement of construction. The spill response contractor is responsible for determining spill incident local, state and federal agency reporting information (e.g., local fire department, CTDEEP Emergency Response Unit, EPA) and providing it prior to the pre-construction meeting. ReNew would provide such information to the Council at that time.