



56 Prospect Street  
P.O. Box 270  
Hartford, CT 06103

**Kathleen M. Shanley**  
Manager – Transmission Siting  
Tel: (860) 728-4527

June 12, 2024

Melanie Bachman, Executive Director  
Connecticut Siting Council  
Ten Franklin Square  
New Britain, CT 06051

Re: Petition 1549 – 1714 Line Rebuild Project  
Petition 1567 – 1637/1720 Lines Rebuild Project  
Weston Substation – Noise Emissions

Dear Ms. Bachman:

This letter is in response to your correspondence dated, June 4, 2024, regarding Mr. Larry Roberts' concerns over noise emissions at the Weston Substation located at 85 Weston Road in Weston.

Since 2014, the only equipment that has been added to the Weston Substation are voltage regulators for an upgraded circuit. These regulators are low noise and do not contribute to the overall sound from the Substation. No new transformers have been added to the Substation and Eversource is not aware of any operational changes that would increase noise levels from the facility.

Eversource is in the process of seeking proposals to take noise measurements at the Weston Substation property lines to confirm that noise levels comply with applicable regulatory requirements. Once these measurements are completed, Eversource will forward the results to the Connecticut Siting Council and to Mr. Roberts.

Sincerely,

A handwritten signature in blue ink, appearing to read "Kathleen M. Shanley".

Kathleen M. Shanley

Cc: Larry Roberts, 19 Old Weston Road, Weston, CT 06883 (gfd247@gmail.com)