



STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051  
Phone: (860) 827-2935 Fax: (860) 827-2950  
E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)  
Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

VIA ELECTRONIC MAIL

November 14, 2023

Bruce McDermott, Esq.  
Murtha Cullina LLP  
One Century Tower  
265 Church Street, 9<sup>th</sup> floor  
New Haven, CT 06510-1220  
[bmcdermott@murthalaw.com](mailto:bmcdermott@murthalaw.com)

RE: **PETITION NO. 1587** – Endurant Energy petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a 4.9-megawatt AC battery energy storage facility located at 350 Knotter Drive, Cheshire, Connecticut, and associated electrical interconnection. **Council Interrogatories to Petitioner - Set 2.**

Dear Attorney McDermott:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than December 5, 2023. Please submit an original and 15 copies to the Council's office and an electronic copy to [siting.council@ct.gov](mailto:siting.council@ct.gov). In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

**Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the December 5, 2023 deadline.**

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman  
Executive Director

MAB/RM

c: Service List dated August 11, 2023

**Petition No. 1587  
Endurant Energy  
350 Knotter Drive, Cheshire, Connecticut**

**Interrogatories- Set 2  
November 14, 2023**

**Project Development**

53. Referring to interrogatory response 4, it states the contract is extendable. Would Endurant seek to extend the 10-year contract? If yes, would battery replenishment/replacement be considered at that time?

**Proposed Site**

54. Who is the owner of the host parcel?
55. What is the approximate size of the limit of disturbance required to construct the facility?
56. Referring to Petition p. 18, it states “Fencing slats will be used to screen the Project equipment”. Fencing slats are not shown on the Site Plans provided with Interrogatory response 48. Are screening slats proposed? If yes, provide detail.
57. Decommissioning Plan p. 2 refers to a palisade perimeter fence. Why was the fence design changed to chain link?

**Interconnection**

58. Is the facility interconnection required to be reviewed by ISO-NE?
59. Would Endurant participate in the ISO-NE Forward Capacity Market?
60. Would Endurant participate in any other ISO-NE markets (ex. ancillary services)?

**Public Safety**

61. Referring to interrogatory response 22, will the facility be designed in accordance with the 2022 Connecticut State Fire Code Chapter 52- Energy Storage Systems?
62. What is the distance of the nearest municipal fire hydrant to the facility? What alternative water sources are available? How would water be brought to the site?