

BRUCE L. McDERMOTT  
203.772.7787 DIRECT TELEPHONE  
860.240.5723 DIRECT FACSIMILE  
bmcdermott@murthalaw.com

August 17, 2023

Melanie A. Bachman, Esq.  
Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: Petition of Endurant Energy for a Declaratory Ruling, Pursuant to Connecticut General Statutes §4-176 and §16-50k, for the Proposed Construction, Maintenance and Operation of a 7.0-megawatt Battery Energy Storage System to be Located at 22 Deerfield Road, Windsor, Connecticut, and Associated Electrical Interconnection

Dear Ms. Bachman:

Pursuant to Connecticut General Statutes Sections 4-176 and 16-50k(a), Endurant Energy hereby submits to the Connecticut Siting Council a Petition for a Declaratory Ruling that no Certificate of Environmental Compatibility and Public Need is necessary for the construction, operation and maintenance of a 7.0-megawatt Battery Energy Storage System including associated equipment and an electrical interconnection located at 22 Deerfield Road, Windsor, Connecticut.

Enclosed is a check in the amount of \$625 for the required filing fee.

Should you have any questions regarding this filing, please do not hesitate to contact me.

Very truly yours,



Bruce L. McDermott

Enclosures

**Murtha Cullina LLP**  
265 Church Street  
New Haven, CT 06510  
T 203.772.7700  
F 203.772.7723

STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

Petition of Endurant Energy for a Declaratory Ruling, Pursuant to : Petition No. \_\_\_\_  
Connecticut General Statutes §4-176 and §16-50k, for the :  
Proposed Construction, Maintenance and Operation of a 7.0- :  
megawatt Battery Energy Storage System to be Located at 22 :  
Deerfield Road, Windsor, Connecticut, and Associated Electrical :  
Interconnection : August 17, 2023

Petition for Declaratory Ruling of Endurant Energy

## TABLE OF CONTENTS

I.	Introduction .....	1
A.	Endurant.....	1
II.	Consistency With State Energy Policy.....	2
A.	Energy Storage Solutions Program .....	2
B.	Conservation and Load Management Plan.....	3
C.	Connecticut Siting Council “White Paper on the Security of Siting Energy Facilities” .....	3
III.	Project Purpose.....	4
IV.	Project Benefits.....	5
V.	Project Description.....	7
A.	Site .....	7
B.	Project Equipment .....	11
C.	Interconnection.....	11
D.	Municipal/Local Input and Community Outreach .....	12
E.	Public Notice and Community Outreach .....	13
F.	Project Cost.....	13
VI.	No Substantial Adverse Environmental Effect .....	13
A.	Air Quality .....	13
B.	Water Quality Impacts .....	14
1.	Wetlands and Watercourses .....	14
2.	Aquifer Protection Areas .....	14
3.	FEMA Flood Zones .....	15
4.	Stormwater .....	15
C.	Waste .....	15
D.	Hazardous Materials .....	16
E.	Wildlife and Habitat .....	16
F.	Prime Farmland and Core Forest Resources.....	17
G.	Noise Analysis .....	18
H.	Visual Impact / Scenic Values.....	18
I.	Cultural Resources / Historical Values .....	18
VII.	PROJECT CONSTRUCTION, OPERATION, MAINTENANCE AND DECOMMISSIONING.....	19
A.	Permits Required.....	19
B.	Construction.....	19
C.	Traffic/Public Transportation .....	20
D.	FAA Determinations .....	21
E.	Operations.....	21
F.	Maintenance Plan .....	23
G.	Decommissioning Plan .....	23
H.	Safety .....	24
1.	Site Security & Safety.....	24

2. Electric and Magnetic Fields (“EMF”) .....	24
3. Fire Safety .....	25
4. Fire Response.....	26
5. Off-Gas Composition .....	27
6. Emergency Planning .....	28
VIII. Conclusion .....	28

## List of Figures, Tables and Appendices

### List of Figures

Figure 1 Site Location Map.....	8
Figure 2 Site Plan and Elevation View Map.....	9
Figure 3 Equipment Overlay Map .....	10

### List of Tables

Table 1 Hazardous Material Inventory.....	16
Table 2 National Register of Historic Places .....	19
Table 3 Aviation Facilities – 5 Mile Radius .....	21

### Appendices

A Technical Data Sheets and Renderings	
B Local Outreach Log	
C Facility Maps	
– Zoning	
– Wetland Soils	
– Aquifer Protection	
– Groundwater Classification	
– Water Supply	
– FEMA Floodplain	
– Soil Survey	
– Prime Farmland Soils	
D Public Notice	
E Safety Data Sheets for Hazardous Materials	
F Natural Diversity Database Report and NDDDB Map, USFWS Report	
G Sound Assessment	
H National Register of Historic Places Map	
I FAA Notice Criteria Tool Reports	
J Emergency Response Plan	

## I. INTRODUCTION

Pursuant to Section 16-50k and Section 4-176(a) of the Connecticut General Statutes ("CGS") and Section 16-50j-38 et seq. of the Regulations of Connecticut State Agencies ("RCSA"), Endurant Energy ("Endurant") requests that the Connecticut Siting Council ("Council") issue a Declaratory Ruling that a Certificate of Environmental Compatibility and Public Need ("Certificate") is not required for Endurant's proposed location, construction, operation and maintenance of a 7.0-megawatt ("MW") Battery Energy Storage System ("BESS"), a 13.8kV electrical interconnection, and associated equipment (together, the "Project") at 22 Deerfield Road, Windsor, Connecticut (the "Property").

As discussed more fully in this Petition for Declaratory Ruling (the "Petition"), the construction, operation and maintenance of the Project satisfy the statutory elements of CGS § 16-50k and will not have a substantial adverse environmental effect. Accordingly, this Petition should be approved by the Council.

### A. ENDURANT

Endurant designs, finances, builds, constructs, owns, operates, and maintains BESS projects. Endurant is a subsidiary of LS Power, which has developed, constructed, managed and acquired more than 46,000MW of competitive power generation and over 680 miles of transmission infrastructure, for which it has raised \$50 billion in debt and equity financing. This experience includes some of the largest BESS projects in the United States.

Endurant has developed distributed energy and battery storage systems for nearly twenty years. Among its chief achievements are designing and building the first MW-scale, distribution-connected BESS projects in the nation's most technically complex distribution system, New York City. Endurant did so in collaboration with the State of New York and Consolidated Edison ("Con Edison") under a pilot program, the REV Demonstration Program, which is similar to the Connecticut Energy Storage Solutions Program ("ESSP"). These first-of-their-kind projects resulted in several industry-setting milestones, including the first projects to secure "Letters of No Objection" from the New York City Fire Department, permits and allowances from the NYC Department of Buildings, and interconnection approval from Con Edison.

Endurant has executed similar projects in the State of Connecticut. These include five separate fuel cell projects for Bloom Energy and a fuel cell-based microgrid for the City of Hartford.<sup>1</sup>

All correspondence and/or communications regarding this Petition should be addressed to:

Brian Mehler  
Senior Vice President  
Energy Storage  
Endurant Energy  
320 West 37th, 15th Floor  
New York, NY 10018  
(917) 608-9490  
[bmehler@Endurant.com](mailto:bmehler@Endurant.com)

A copy of all such correspondence or communications should also be sent to Endurant's attorney:

Bruce L. McDermott  
Murtha Cullina LLP  
265 Church Street  
New Haven, CT 06510  
(203) 772-7787  
[bmcdermott@murthalaw.com](mailto:bmcdermott@murthalaw.com)

## II. CONSISTENCY WITH STATE ENERGY POLICY

### A. ENERGY STORAGE SOLUTIONS PROGRAM

In June 2021, the Connecticut General Assembly passed *Public Act No. 21-53, An Act Concerning Energy Storage*. The Act directs the CT Public Utilities Regulatory Authority ("PURA" or the "Authority"), in coordination with the Department of Energy and Environmental Protection ("CT DEEP") and the CT Green Bank ("CTGB"), to initiate a proceeding to develop and implement programs and associated funding mechanisms incentivizing electric energy storage resources. When undertaking this proceeding, the Authority was instructed to design and administer a new incentive program that accelerates the adoption of electric energy storage technologies such as battery systems. One of the principal goals of the legislation is to unlock the benefits that energy storage technologies deliver to ratepayers.

---

<sup>1</sup> Endurant's Petition for a Declaratory Ruling for a 4.9-megawatt BESS, a 13.8kV electrical interconnection, and associated equipment in Meriden, Connecticut is pending before the Council (Petition 1585). Additionally, on August 11, 2023, Endurant filed a Petition for a Declaratory Ruling for a 4.9-megawatt BESS at 350 Knotter Drive, Cheshire, Connecticut (Petition 1587).

Consequently, in connection with Public Act 21-53, *An Act Concerning Energy Storage*, PURA issued a final decision in Docket No. 17-12-03RE03, *PURA Investigation into Distribution System Planning of the Electric Distribution Companies – Electric Storage*, establishing a statewide energy storage program, known as the “Energy Storage Solutions Program” or “ESSP”. In the Final Decision in Docket No. 17-12-03RE03, PURA explicitly created electric storage deployment targets for commercial and industrial (C&I) energy users and established an incentive structure to promote non-residential customer participation in the ESSP.

The Project at the center of this Petition is one of the C&I projects that was selected and approved by the Authority.

#### **B. CONSERVATION AND LOAD MANAGEMENT PLAN**

Pursuant to Connecticut General Statutes § 16-245(m) and § 16-32(f), the State of Connecticut’s electric and gas distribution utilities published the “2022-2024 Conservation & Load Management Plan: Connecticut’s Energy Efficiency and Demand Management Plan” on May 1, 2022.

The Plan explicitly identifies energy storage projects, such as the project central to this Petition, to be a cornerstone of the Plan: “the Companies will promote the co-delivery of energy efficiency and demand management programs that support decarbonization and carbon neutrality, including ...battery storage.”<sup>2</sup> The Plan continues, “[t]hese active demand response strategies will significantly reduce peak demand and greenhouse gas emissions, helping to mitigate the impact that the state’s building sector has on the environment and climate change. The Companies plan to encourage customers to engage with a more modern grid, improving energy affordability and resilience.”<sup>3</sup>

The Plan specifically references battery storage throughout the document as being a priority for the state to reach its energy goals for reducing ratepayer costs, hardening the grid’s resiliency, and improving the state’s environmental footprint.

#### **C. CONNECTICUT SITING COUNCIL “WHITE PAPER ON THE SECURITY OF SITING ENERGY FACILITIES”**

In response to Public Act 07-242, “An Act Concerning Electricity and Energy Efficiency”, the Council issued its White Paper on the Security of Siting Energy Facilities to establish the Council’s scope of review of energy security for electric transmission and distribution assets on October 8,

---

<sup>2</sup> 2022-2024 Conservation and Load Management Plan: Connecticut’s Energy Efficiency and Demand Management Plan (“2022-2024 C&LM Plan”) at 15-16; see also, 2023 Plan Update to Connecticut’s 2022-2024 Conservation & Load Management Plan, at 14.

<sup>3</sup> 2022-2024 C&LM Plan at 16-17.

2009. Specifically, the White Paper considers the planning, preparedness, response, and recovery capabilities of transmission and distribution assets, including generation assets.

The “clean energy revolution” is often characterized as a transformation from a fossil-fuel based system to a renewable system. While this is correct, system planners, grid operators, and development practitioners see another more fundamental transformation of the energy network: a shift from a centralized system to a de-centralized system. Just as networked computing and telecommunications have undergone this transformation since the 1970’s, the electric grid is following a similar path, trading the “hub-and-spoke” star networks of Westinghouse’s day for a “mesh network” defined by flexibility, interconnectedness, and resiliency.

The result of this transformation is clear: distributed systems (mesh networks) are inherently more resilient and secure by eliminating single points of failure. Battery energy storage systems are critical components of this security in their ability to maintain the integrity of the grid’s 60hz sinusoidal wave form frequency and deliver excess electric capacity in the event of a grid outage. They give grid planners flexibility when upgrading distribution systems, allow businesses (such as the site host, Taylor & Fenn) to be prepared for outage events, offer dynamic millisecond response capability to a variety of systemic needs, and, most importantly, provide first responders time and options during emergency events.

In short, the proposed Project is part of Connecticut’s evolution towards a more secure and resilient energy system.

### **III. PROJECT PURPOSE**

The Project’s purpose is to meet the goals of the ESSP. It will do so by offering benefits to Taylor & Fenn and the surrounding community through lower electricity costs, enhanced grid resiliency, and “the long-term environmental benefits of electric storage by reducing emissions associated with fossil-based peaking generation.” (ESSP Program Manual, January 20, 2023).

The BESS will connect to the distribution grid behind the customer’s electric utility meter, which will allow the facility to run on battery power during peak demand times, alleviating grid congestion. That is, the BESS will be used for demand response and demand management to lower the site host’s electric bills. Additionally, the BESS’ operation will allow the host site to “load-shift,” that is, charge at night to utilize cheaper off-peak power and then consume that cheaper power during the daytime peak hours.

As required by the ESSP guidelines, the BESS will operate in parallel with the grid, and can



also export power into the utility distribution system, injecting valuable “peaking power” into the grid during peak demand times when excess supply is most needed to balance the network. As energy markets mature, the BESS will also be able to provide ancillary services to the grid, increasing its value to all ratepayers throughout its 10-year life.

#### **IV. PROJECT BENEFITS**

The Project is an enabling technology for the grid’s transition to a renewable energy future. The BESS will charge from the grid at night when electricity prices are lower. The BESS will return that electricity to the grid when electricity prices are high, the sun is not shining, the wind is not blowing, or peak electric demand necessitates a reliance on carbon-intensive fossil fuel generation sources (coal or natural gas based “peaker plants”).

At a micro-level, this “peak-management-focused” operational approach will take stress off of the neighborhood’s local distribution grid when it is most vulnerable to pricing spikes that increase costs, balance the system when it is most vulnerable to instabilities to help reduce the frequency of outages, and relieve stress on the local network’s infrastructure. This “grid stress reduction” can elongate the lifespan of the grid’s hardware and allow the utility to defer or delay expensive system upgrades. Put simply, the Project will be an elemental part of a larger strategy to reduce costs, disturbances, and improve the reliability of energy for the community’s businesses and residents.

The Project will be one of the first critical assets to participate in the ESSP and, as part of that program’s target for a large, distributed portfolio, the Project will deliver the following benefits recognized by the Authority in Docket No. 17-12-03RE03:

- (1) **Economic Benefits:** The Project will allow the host site, Taylor & Fenn, to realize lower net energy costs through the battery’s demand management, capacity charge management, time-of-use energy shifting, and revenue share operations.

As described above, the Project will be an integral part of the ESSP’s economic goals of lowering the grid’s peak demand, lowering ratepayer costs by relieving peak grid capacity and transmission charges, adding capacity during times that it is needed, thereby, allowing electric utilities to avoid or delay expensive distribution infrastructure upgrade costs, increasing business operation “uptimes” through avoided outages and grid instability induced facility disruptions, enabling the integration of cheaper renewable energy resources like solar PV, and avoiding the healthcare and economic productivity costs associated with higher polluting power generation resources.

(2) **Resiliency Benefits:** For the host site, the Project will provide fast-acting backup power during utility grid outages for up to several hours, allowing Taylor & Fenn to maintain operations during shorter outages and avoiding grid-transients and harmonic distortions that may cause the facility’s industrial production equipment to trip. It also provides time for the facility to transition to traditional backup power resources (e.g., emergency generators) more effectively and without the combustion of additional fuel. On the utility scale, the Project will, in the long-term, assist in maintaining the stability and efficient operation of the electric grid by providing peaking capacity and balancing services including reserve capacity, frequency regulation, voltage support, and harmonic distortion power curing. Stress relief also means improved system reliability. BESS’ modern power electronics systems allow grid balancing and stabilization services within milliseconds, preserving the safe, efficient operation of the grid. Over time, as a larger portion of the grid’s energy is composed of intermittent renewable resources (such as solar and wind), distributed energy storage systems can help “smooth” the surge and lull of voltage, frequency and harmonic distortions that are inherent with the rapid integration of renewable energy systems.

(3) **Environmental Benefits:** Under the ESSP, BESS are used as localized peak power suppliers. As such, BESS will help avoid some of the air quality impacts of high emitting peaker plants, which are called upon as resources-of-last resort during peak demand times. Further, to achieve its renewable energy goals, Connecticut is relying on the scalable installation of energy storage to balance the grid and “smooth” the intermittent output of solar and wind generation resources. Renewable power adoption can only happen effectively with energy storage assisting the grid in accommodating these resources. Locally, the host site’s environmental footprint will improve since the BESS will charge at night when the ISO-NE’s power supply is comprised of a higher percentage of non-carbon-based resources, and then discharge that energy to serve the facility and grid during peak demand hours when the high emitting, least efficient, fossil fuel-based peaker plants are typically used.

The result is overall positive net value to the host and all ratepayers as sought in the PURA and CTGB’s ESSP.

## V. PROJECT DESCRIPTION

Designed in accordance with the ESSP's Program Manual,<sup>4</sup> and with input and guidance from The Connecticut Light and Power Company dba Eversource ("Eversource"), the Project consists of a 7.0MW/14.0MWh BESS to be installed at the Site. The Project would be designed, built, owned, operated, maintained, and financed by Endurant and participate in the State of Connecticut ESSP. CPower, Endurant's sister company, will provide asset dispatch optimization and market enrollment services. After construction, the Project will be owned by a new special purpose entity that will be created by and wholly owned by Endurant. The new special purpose entity will contract with Endurant to obtain and hold the necessary permits for construction and operation of the Project. Endurant is securing final quotes from battery suppliers that have been pre-approved by the ESSP Program Administrators to supply the battery equipment.

### A. SITE


The Project will be located at a ferrous sand foundry operated by Taylor & Fenn in Windsor, Connecticut. The company provides commercial and industrial ferrous sand casting of iron and steel components at its facility located at 22 Deerfield Road in Windsor, shown on Figure 1. Taylor & Fenn operates the foundry, pattern shop, heat treating operation, metallurgical and sand laboratories, and quality assurance processes within an approximately 180,000 square-foot manufacturing facility (the "Facility").


The footprint of the Project, including setbacks, will be approximately 6,000 square feet, located on a paved-and-grassed portion of the developed property (the "Site"). The Facility is zoned as I-Industrial, a fully developed industrial property. The property is bordered to the north by another industrial property. To the west, it is bordered by Deerfield Road, to the east by the Amtrak Railroad tracks, and to the south by I-291 and an off-ramp of I-291. The Connecticut River is 0.3 miles from the Site. The BESS containers will be installed on concrete pads within a fenced area that is eight feet tall and includes industry-standard and OEM-prescribed setbacks.

The Facility is accessed from the main Facility driveway off Deerfield Road. An additional Site access path will be developed off the main entrance driveway to provide direct Fire Department access to the Site. Figure 2 depicts a plan and elevation views of the Site. Figure 3 depicts the Project equipment overlain on an aerial view, and ground level views of the Facility and Site location from I-291 and the I-291 off-ramp.

---

<sup>4</sup> [https://energystoragect.com/wp-content/uploads/2023/06/ESS-Program-Manual\\_Updated-6.23.2023\\_CLEAN.pdf](https://energystoragect.com/wp-content/uploads/2023/06/ESS-Program-Manual_Updated-6.23.2023_CLEAN.pdf)



	Battery Energy Storage System Taylor & Fenn 22 Deerfield Road Windsor, Connecticut	Figure 1 Site Location
---	---	---------------------------




Aerial View - Battery system location indicated by yellow arrow




Ground View from I-291 - Battery system location behind building



Ground View from I-291 Off-Ramp - Battery system location behind building.

	Battery Energy Storage System Taylor & Fenn 22 Deerfield Road Windsor, Connecticut	Figure 2 Aerial View and Ground Views from I-291 & I-291 Off-Ramp
---	---	--



	<p>Battery Energy Storage System Taylor &amp; Fenn 22 Deerfield Road Windsor, Connecticut</p>	<p>Figure 3 Equipment Overlay</p>
---	---	---------------------------------------

## **B. PROJECT EQUIPMENT**

All battery systems under consideration for the Project comply with latest UL, IEEE, and National Fire Protection Association (“NFPA”) testing regimes and specifications, including UL 9540. The installation will include four fully containerized, UL certified and NFPA 855 compliant lithium-ion battery modules, external inverters, transformers, and switchgear.

Currently, the Project is expected to use Canadian Solar Inc. (“CSI”) Energy Storage SolBank 0.5P lithium iron phosphate chemistry-based battery modules with liquid cooling, humidity control, and an active balancing Battery Management System (or similar). The battery modules will export DC electricity to an EPC power converter, which are UL 1741 listed and UL 1547 compliant for interconnecting and islanding capability, which will convert the electricity to AC, and step the voltage up to 13.8kV before connecting to the utility distribution network’s 13.8kV feeder.

The sample specification sheet in Appendix A provides the technical details on the proposed battery modules for the battery system and presents system renderings. The final battery system’s make and model may change to accommodate Eversource feedback and supply chain constraints, but the core technology presented in this Petition will be the same.

The Project term is for 10 years, with the ability to extend thereafter. The battery capacity will degrade naturally without augmentation or capacity maintenance unless market and economic conditions change to make that option desirable. In year 10, the battery cells may be replenished with newer cells to increase the system’s capacity, but this will depend on the health of the battery system at that time and cost of capacity maintenance. The BESS’ internal monitoring systems will allow Endurant to monitor and diagnose the health of each cell individually over time.

## **C. INTERCONNECTION**

The Project is in the final stages of the interconnection process with Eversource. Endurant filed an interconnection request on November 7, 2022, with Eversource and has been assigned project number INT-63093. A project Feasibility Study Agreement was executed on December 23, 2022, and an Impact Study Agreement was executed on March 29, 2023, with results expected shortly. The Interconnection Agreement is pending with project completion anticipated for Q1 or Q2 2025. The utility has preliminarily determined that the Project will not likely need an ISO-NE study to be completed. A final determination is expected by August 31, 2023.

The Project will electrically interconnect to the utility's 23kV distribution feeder behind the building via an underground conduit. Upon a grid fault or outage, the system will disconnect from the grid to provide resilient power to the host Facility ("island mode"). When power services have resumed, the Facility will reconnect to the grid to maintain normal, "blue sky" operations.

#### **D. MUNICIPAL/LOCAL INPUT AND COMMUNITY OUTREACH**

Endurant, in partnership with its subcontractor, Berkshire Environmental Consultants, has worked with the Town of Windsor to provide information about the Project and to discuss permitting, safety and other feedback. Endurant met with the Town of Windsor Staff Development Team to present a Project overview and get feedback from the members of the Team, which included representatives from the Planning Department, the Building Department, the Fire Marshal's office, the Engineering Department, and Police Departments.

Endurant also reached out to the Planning Department staff to discuss permitting procedures, applications and fees, zoning requirements, setbacks, equipment screening, wetlands, and floodplain locations, building, electrical and mechanical permit requirements and fire plan review. The Windsor Zoning Map with the Project identified is shown in Appendix C.

Endurant held a meeting with the Windsor Fire Marshal and Fire Inspector to provide more detailed information about the Project and to discuss the fire safety systems of the BESS, the detection and fire alarm systems, incident response, fire department requirements and equipment needs. The Windsor Fire Marshal communicated the Department's procedural preferences and needs to Endurant and will continue to relay information about the project to the Fire Department, as well as help coordinate resources, information and training with the Windsor Volunteer Fire Department.

The Fire Marshal input was used in the development of emergency plans and identification of fire safety equipment for the Project. Project access was discussed and a new access road off the facility driveway will be created to provide more direct access to the Site. Endurant will continue to seek Fire Department input through the design-build stage, including ensuring clear disconnection signage, providing secure fenced area access, emergency disconnection equipment and planning for water access. Endurant will continue to work with the Fire Marshal during the Fire Plan Review process and when finalizing the Emergency Response Plan. Once the system is installed, Endurant will work with the Fire Marshal and Windsor Volunteer Fire Department to develop and provide training resources.



A letter describing the Project was sent to the Windsor Town Manager on August 16, 2023. Detailed logs of the contacts with local authorities about the Project are presented in Appendix B.

#### **E. PUBLIC NOTICE AND COMMUNITY OUTREACH**

Endurant has provided notice of this Petition via certificate of mailing to all persons and appropriate municipal officials and governmental agencies to whom notice is required to be given pursuant to RCSA § 16-50j-40(a).<sup>5</sup> Notices have been given to property owners within 250 feet of the Property boundary and are identified in Appendix D, in addition to a map indicating the abutter properties and a sample copy of the notice letters.

#### **F. PROJECT COST**

Total Project capital costs will be approximately \$8 million. Costs will be recouped through payments made from the State of Connecticut ESSP, administered by the CTGB, to the Project. Energy will be purchased at retail energy market rates according to the customer's utility tariff. Before the Project is finalized, a commodity supply agreement with a supply provider may be established.

### **VI. NO SUBSTANTIAL ADVERSE ENVIRONMENTAL EFFECT**

The Project will have no substantial adverse environmental effect. Battery systems do not store or contain fuel, e.g., hydrocarbon fuels, which can cause environmental impacts. Further, the BESS will not generate regulated air emissions, will not have an adverse impact on water resources or stormwater runoff, and will not impact endangered species.

#### **A. AIR QUALITY**

Battery storage systems do not produce any air emissions of criteria air pollutants and/or hazardous air pollutants regulated by the Clean Air Act and Chapter 446c – Air Pollution Control of the Connecticut General Statutes because the system does not combust fuel or use any volatile organic compounds or other chemical pollutants that would be released to the

---

<sup>5</sup> RCSA § 16-50j-40(a) in part provides: "Prior to submitting a petition for a declaratory ruling to the Council, the petitioner shall, where applicable, provide notice to each person other than the petitioner appearing of record as an owner of property which abuts the proposed primary or alternative sites of the proposed facility, each person appearing of record as an owner of the property or properties on which the primary or alternative proposed facility is to be located, and the appropriate municipal officials and government agencies...The term "appropriate municipal officials and government agencies" means, in the case of a facility required to be approved by declaratory ruling, the same officials and agencies to be noticed in the application for a certificate under Section 16-50l of the Connecticut General Statutes...".

atmosphere during normal operation. As such, an air permit is not required for the construction or operation of the battery system.

The liquid coolant system, used for cooling battery cells, uses a glycol-based coolant. The air-cooling system, used for cooling electrical components, uses HFC-134a refrigerant. Both cooling systems are closed loop with no emissions released during routine operations. R134a is a non-ozone-depleting hydrofluorocarbon (“HFC”). It was one of the first refrigerants developed to replace Chlorofluorocarbons which are ozone-depleting substances and has a lower environmental impact potential than other refrigerants. The Project is required to use licensed HVAC contractors trained to minimize or eliminate risks during maintenance activities.

During construction, short-term fugitive particulates and emissions from diesel exhaust may result from soil handling and construction vehicles. Fugitive particulate emissions from soil handling will be limited since soil disturbance is expected to be minimal with no significant storage piles. Additionally, construction vehicles will be expected to comply with CT DEEP idling requirements and operate only as needed. Therefore, any emissions resulting from their operation will also be minimal. If necessary to control fugitive dust, water spray will be used during construction.

## **B. WATER QUALITY IMPACTS**

### *1. Wetlands and Watercourses*

The Site is not located in a mapped wetland delineated area, as determined by the wetland soil map provided by the Town of Windsor GIS and the Connecticut Geodata Portal Soil Survey Geographic Database Inland Wetland Soils map. Based on the distance from the site to mapped wetland locations, and the fact that the Project will be installed at a location that has been previously developed, no impact on wetland soils is anticipated.

Seasonal depressional wetlands, also known as vernal pools, are not present on the Site. There are no watercourses at the Project location. The Windsor GIS wetland overlay map and the CT Geodata Portal Inland Wetland Soils Map, both identifying the Project location, are presented in Appendix C. Based on the foregoing, the Project is not expected to negatively impact any wetlands or watercourses.

### *2. Aquifer Protection Areas*

There are no aquifer protection areas at the Site. The CT DEEP Water Quality Classification Map, which delineates aquifer protection areas relative to the Site, is shown in Appendix C. The

Groundwater Class at the location of the Site is Class GB, as shown in the map in Appendix C. Class GB designated uses are industrial process water and cooling waters. Baseflow for hydraulically connected waterbodies and use is presumed not suitable for human consumption without treatment. There are no Drinking Water Watersheds or Private Well Parcels at the Site, as shown in the Water Supply Map in Appendix C.

The Project has no normal operating processes that will impact groundwater or surface water. During a fire emergency, firewater may be generated as a part of response activities, however the overall approach of response is not water deluge of the batteries, but to allow self-extinguishing, and to use water to control impacts on adjacent structures to prevent spread. Firewater generated would be comparable to water generated during routine fire response of manufacturing buildings and electrical equipment. Fire response and firewater management are further discussed in the Safety section of this Petition.

### *3. FEMA Flood Zones*

A review of the Federal Emergency Management Agency's ("FEMA") National Flood Insurance Program flood mapping data shows that that the Project location is not within the 100-year Flood Zone. This determination was confirmed by the Windsor Town Planner. The FEMA flood hazard area is shown in Appendix C.

### *4. Stormwater*

The area of Site disturbance for the Project is less than one acre and will not require a CT DEEP General Permit for Discharge of Stormwater and Dewatering Wastewaters for Construction Activities. The battery system is contained within a weather resistant enclosure, and as such, there is no stormwater contact with the battery system components. No routine industrial stormwater permitting is triggered by the Project.

## **C. WASTE**

During the Site clearing and construction phases, construction debris and other solid waste will be generated and managed by Endurant and its construction contractor. No hazardous waste is expected to be generated during the construction phase, unless there are small equipment leaks from vehicles. Any vehicle fluid leak will be managed in accordance with the applicable CT DEEP requirements.

During normal operations, the only waste products that will be generated by the Project will be the result of maintenance activities, such as coolant and refrigerant change out or

maintenance product usage. The servicing of the HVAC system will be contracted to a registered HVAC servicing company. Maintenance activities are expected to occur semi-annually. Refrigerant change outs would typically be recycled. The R134a change out would be closed piped to a recovery tank. Any waste oils or lubricants will be collected and managed in accordance with CT DEEP regulations. Occasional vehicle or truck traffic on the Site for maintenance activities could result in vehicle fluid leakage which will be managed in accordance with the applicable CT DEEP requirements.

**D. HAZARDOUS MATERIALS**

An inventory of hazardous materials expected to be onsite during construction and during normal operations, is presented in Table 1 below. The exact products to be used will be determined during construction and installation. Representative Safety Data Sheets for comparable products are contained in Appendix E for reference. There will be no fuel or hazardous material storage at the Project Site, beyond the quantities contained in the equipment.

Equipment containing hazardous materials will be routinely inspected as part of the maintenance inspection program developed and conducted by the OEM contractor.

<b>TABLE 1: HAZARDOUS MATERIAL INVENTORY</b>		
<b>NORMAL OPERATIONS</b>		
<i>Product</i>	<i>Use</i>	<i>Approx. Quantity On-Site</i>
<b>Air cooling system refrigerant – HFC - 134a</b>	HVAC cooling of battery electrical equipment	35.3 lbs. per BESS container
<b>Liquid cooling system – glycol-based coolant</b>	Cooling of battery cells	84.8 gal per BESS container
<b>Transformer Oil</b>	Electrical Insulating oil	Approx 500 gal per transformer
<b>Lithium-Ion Electrolyte</b>	Storage of electrical energy	48 gal per BESS container
<b>SITE PREPARATION AND CONSTRUCTION</b>		
<i>Product</i>	<i>Use</i>	<i>Quantity On-Site</i>
<b>Construction Vehicle Fluids</b>	Fuel, oil, hydraulic and other oils used in site vehicles, and heavy equipment used during installation.	Variable

**E. WILDLIFE AND HABITAT**

The CT DEEP Natural Diversity Database (“NDDB”) maps general locations of Connecticut

Endangered, Threatened, and Special Concern species as well as rare natural communities. The NDDDB Area Map, presented in Appendix F, indicates that the Project location is not in a mapped NDDDB area. The NDDDB Preliminary Review screening tool indicated that a threatened species, Peregrine Falcon (*Falco peregrinis*), has been documented within or in close proximity to the Project area. No critical habitat was found at the Project Site. A CT DEEP NDDDB filing was made for a Project review consultation and when a response from CT DEEP is obtained, it will be provided to the Council.

The Project Site is not in or adjacent to any of the State's Protected Wildlife Management Areas.

The Endangered Species Act, 16 U.S.C. § 1531 et seq. protects federally threatened and endangered wildlife. Listed species and their critical habitats are managed by the Ecological Services Program of the U.S. Fish and Wildlife Service ("USFWS") and the fisheries division of the National Oceanic and Atmospheric Administration. The USFWS Information for Planning and Conservation ("IPaC") tool was used to identify potentially affected listed species and their habitat. The Northern Long-eared Bat (*Myotis septentrionalis*, endangered species) and the Monarch Butterfly (*Danaus plexippus*, candidate species) were identified. The IPaC report indicates that there is no Critical Habitat within the vicinity of the Project area for either species. The report is provided in Appendix F.

#### **F. PRIME FARMLAND AND CORE FOREST RESOURCES**

The Soil Survey of the State of Connecticut map (2008) indicates that soils at the Site are unit #307 - Urban Land. The General Soil Map of Connecticut (1978) indicates it is map unit #27, Elmwood-Buxton-Scantic: Brownish and reddish, nearly level to gently sloping, deep, moderately well drained and poorly drained soils with a silty or clayey substratum; on terraces.

None of the soils at the Site are mapped as prime farmland or farmland soils of statewide importance, nor are there any forested areas on Site, therefore, there is no Core Forest. As such, Project construction will not impact Prime Farmland or Core Forest resources. These maps are provided in Appendix C.

Taylor & Fenn has an Environmental Land Use Restriction ("ELUR") related to soil contamination and remediation at the Deerfield Road property. The ELUR was recorded in the Windsor municipal land records in 2005. It restricts residential activities on the entirety of the site and restricts soil disturbance in specific areas. The BESS Site is not located in the areas of soil disturbance restriction identified by the ELUR and does not represent residential activity,

therefore the ELUR does not restrict the construction of this Project.

#### **G. NOISE ANALYSIS**

Cavanaugh Tocci Associates has evaluated the environmental sound impact associated with the proposed BESS. This evaluation's objectives were to define the acoustic design goals based on applicable noise regulations and to estimate and evaluate the acoustic impact of the proposed Project in the surrounding community.

Based on Cavanaugh Tocci's review of the Project description and the BESS and inverter noise study reports, sound produced by the proposed BESS Project will comply with the most stringent requirements of the state and local noise regulations. Furthermore, the firm concluded that the sound emitted by the Project will not produce a noticeable impact on the acoustic environment and will not have an unreasonable adverse effect on any surrounding properties. The complete Facility Sound Assessment is in Appendix G.

#### **H. VISUAL IMPACT / SCENIC VALUES**

The Project will be situated on a 14-acre, existing manufacturing facility location, which is in an industrial setting. The Project will be enclosed in a securely fenced area at the Facility's northern end. Fencing slats will be used to screen the Project equipment. Due to the location of the Project, it will be screened by the host facility buildings, and will not be visible from Deerfield Road, I-291, the I-291 off ramp or properties to the south of I-291. The Windsor Town Planner did not suggest any additional screening in reviewing the Project. As the access road plans are developed, trees and other natural screening will be retained as possible, while still ensuring adequate access to the site.

Since this Project is being added to an existing industrially developed property, in an industrial area and out of view from public roads, it will not create a substantial change in the visual and aesthetic characteristics of the Project area. Further, the Project equipment is consistent in design and aesthetic with the current uses at the facility.

#### **I. CULTURAL RESOURCES / HISTORICAL VALUES**

The Project will not have any adverse effects on the state's historic or archaeological resources.

A search in the National Register of Historic Places ("NRHP") map indicated that there are several NRHP listed properties within a half mile of the Project. These properties are presented below in Table 2, and mapped in the figure presented in Appendix H.

**Table 2 – National Register of Historic Places**

<b>NRHP Property</b>	<b>Distance from Site</b>
Elijah Mills House	0.20
Oliver Mills House	0.21
Capt. Benjamin Allyn II House	0.25
Timothy Dwight Mills House	0.29
Giles Barber House	0.40
Windsor Farms Historic District	0.52 (across CT River)

Based on the distances to NRHP properties, and the limits of the Project scope as well as intervening structures, and the low height of the Project, it is anticipated that there will be no impact on Historic Places. A Project Review request was made to the Connecticut State Historic Preservation Office (“SHPO”) on August 11, 2023, regarding the Project’s effect on historic, architectural or archaeological resources listed on or eligible for the NHRP. A copy of SPHO’s response will be provided to the Council upon becoming available.

**VII. PROJECT CONSTRUCTION, OPERATION, MAINTENANCE AND DECOMMISSIONING**

**A. PERMITS REQUIRED**

The Project will require local permits, including a Building Permit, which includes a Fire Plan review, a Mechanical Permit, and an Electrical Permit. Permit applications will be submitted following the Siting Council determination.

**B. CONSTRUCTION**

The on-site construction phase will commence when the Interconnection Agreement is executed, and the Siting Council’s determination has been issued. Following these key milestones, Endurant anticipates that by Q4 2023, advanced engineering design work will be completed, final permits will be secured, and equipment purchase orders will be placed. On-site activities will begin in Q1-Q2 2024. On-site construction is anticipated to take no more than six months.

The Project will require minimal construction or disruption to the existing site since it is a developed industrial property. There will be work to develop an access road from the Taylor & Fenn Driveway as part of the Project. There will be some removal and cutting back of overgrown brush that has encroached on the periphery of the Project Site. Initial site work will

include installation of a construction fence to shield most site activities, excavation, installation of below ground conduits and pouring concrete pads. Trenches to accommodate the laying of new conduit will be dug from the BESS site to the Facility's electrical room where the BESS will be connected to the distribution infrastructure. These excavation and grading phases are minimally disruptive and will be coordinated with the site host to minimize operational impacts.

The installation of the major battery equipment is also expected to have minimal environmental impact. Pre-packaged containerized modules will be shipped to the Site from the production facility and will be dropped onto the poured concrete pads and connected via the newly laid conduit to the distribution infrastructure. Once installed, the battery system will be commissioned, tested, and activated for commercial operation. Commercial operation is expected prior to the 2025 ESSP program season, scheduled to start on June 1, 2025.

### **C. TRAFFIC/PUBLIC TRANSPORTATION**

During the construction phase of the Project, there will be a short-term slight increase in the local traffic, due to the number of construction vehicles and equipment coming onto the Taylor & Fenn Property from Deerfield Road. The driveway and parking areas on the property are large enough to accommodate the staging and parking of any construction vehicles or heavy equipment needed for site work and construction activities. On-site traffic controls will be utilized to minimize any impact to typical traffic patterns and the Town of Windsor Police Department will be notified prior to delivery of the equipment. Once installation is completed, the only additional traffic will be during periodic equipment inspection and routine maintenance activity.

Connecticut Highway 291 and the I-291 westbound Exit 3 off-ramp are directly south of the Property. I-291 is approximately 410 feet from the Project and the I-291 off-ramp is approximately 370 feet from the Project. The Taylor & Fenn building is located between the Project and the highway. Endurant believes that the distance between the highway/off-ramp and the Project Site as well as the location of the Taylor & Fenn building, precludes any highway related impact to the battery system or battery incident impact to the highway system.

The Amtrak Hartford Line runs along the Taylor & Fenn eastern property boundary and it is approximately 1000-feet from the Project Site. The distance between the railroad tracks and the Project precludes any possible train impact to the battery system or battery incident impact to the railway.



**D. FAA DETERMINATIONS**

There are several aviation facilities within a 5-mile radius of the Project. These facilities and distances from the Project are identified in Table 2.

**Table 3 – Aviation Facilities – 5 Mile Radius**

Facility Code	Facility Name	Type	Location	Distance from Project (miles)
CT06	Delta One	Heliport	Hartford	1.9
CT62	Twin Manufacturing Co	Heliport	South Windsor	2.2
CT00	Electro-Methods Inc.	Heliport	South Windsor	2.8
OCT5	St. Francis Hospital	Heliport	Hartford	3.7
CT05	Kaman Aerospace Corp.	Heliport	Bloomfield	3.9
CT14	Bancroft Airport	Airport	East Windsor	4.0
CT88	Rentschler Heliport	Heliport	East Hartford	4.6
HFD	Hartford-Brainard Airport	Airport	Hartford	5.0

The FAA Obstruction Evaluation Tool was used to assess Notification Criteria for the permanent battery positioning and for the temporary use of a mobile construction crane during the Project's construction phase. Based on the Site-specific data entered for the Project, Site elevation and structure height for each scenario, the results indicated that the Notice Criteria under Part 77 were not exceeded for either scenario. These Notice Criteria Tool outputs are presented in Appendix I.

Notwithstanding this determination, Endurant will provide notice to these aviation facilities prior to the use of the construction crane. This notice will ensure that the facilities are aware of the presence of the crane and factor it into their operations.

**E. OPERATIONS**

During “blue sky conditions,” i.e., normal grid operations, the BESS will operate to provide peak demand management and demand response. From June 1 - September 30 and as per ESSP call windows, the BESS will discharge, for 2-3 hours between 3:00 p.m. - 8:00 p.m. During the June - September period, the BESS will charge at night, typically from approximately 11:00 p.m. - 6:00 a.m. The amount of time it will take for the battery to charge will depend on energy prices and the host facility's energy demand. Typically, charging will occur over several

off-peak hours. During shoulder and winter seasons, the BESS will charge at similar times, but discharge over a longer period to manage the site host's peak demand charges.

While the battery energy storage system will be owned and operated by Endurant. CPower, Endurant's sister company, will provide the dispatch optimization services for the battery, signaling the on-board management system to charge and discharge at economically and technically optimal times. "Active" or "Passive" calls will depend on when Program Administrators (the utility) calls on the asset to dispatch. CPower is one of the largest, most experienced demand response and demand management providers in the country and utilizes its "Enerwise" technology to receive signals from grid operators and relay those calls to the battery system.

During "black sky conditions," or grid outage events, the BESS will provide resiliency and power quality services, i.e., back-up power, to the Facility. During grid outages, faults or other electrical disturbances and per UL and utility interconnection rules, the BESS will be able to fully disconnect from the grid to continuously power the Facility, operating in "island mode." The system will be IEEE 1547 and UL 1741 SA compliant. Once the grid outage is over, the BESS and Facility will reconnect to the distribution network. The amount and duration of backup power will depend on the battery's state of charge when the outage occurs. Even if the battery's state of charge is low at the time of an outage, it will be sufficient to allow the Facility to continuously operate for some time, buying the staff valuable time to transfer to traditional start-up backup power resources. This is critically valuable during winter storms when backup generators may need additional startup time, and/or fuel may be inaccessible, as many Connecticut residents experienced during Winter Storm Alfred and Hurricane Sandy.

The BESS will be capable of participating in other ISO-NE markets, such as energy, forward capacity, and ancillary service markets once ISO-NE develops new participation rules for behind-the-meter resources to do so.

The BESS' inverter systems can dispatch almost instantaneously once called by the controls system. Typically, this is a matter of milliseconds. However, utility calls are sent 24-hours in advance under the ESSP program rules. While it is operating, the battery system will be remotely monitored 24/7. The Project will be equipped with Battery Management Software ("BMS") that uses supervisory control and data acquisition systems to initiate automated procedures or responses by personnel.

The Project term is 10 years, with an option to extend for additional periods. The battery system will degrade naturally without augmentation or capacity maintenance unless market and economic conditions change to make that option desirable. In year 10, the battery cells may be replenished with newer cells to increase the system's capacity, but this will depend on the health of the battery system at that time and cost of capacity maintenance. The BESS' internal monitoring systems will allow Endurant to monitor and diagnose the health of each cell module individually over time.

#### **F. MAINTENANCE PLAN**

Unlike rotating machines such as combustion engines or gas turbines, battery energy storage systems require little maintenance. To honor the battery warranty, the BESS suppliers require that the battery's maintenance be conducted by the battery manufacturer and its subcontractors for the full life of the Project. The supplier's staff and subcontracting teams have been trained specifically on the modules and equipment installed on-site. Bi-annual planned maintenance events will occur, typically before and after the summer ESSP season to ensure the system will be fully available for that season-year.

Maintenance activities include a full checklist of items to ensure system integrity and availability for peak operation. These include a full testing of the BESS safety systems, backup power and cooling systems. The OEM Maintenance Plan will be provided by the manufacturer once the final decision is made on the equipment.

#### **G. DECOMMISSIONING PLAN**

At the end of the Project's Operation Phase, including any extensions, the Project equipment, including the battery containers, will be removed and the Site will be returned to its original condition before the battery system's installation (or as otherwise directed by the Facility owner). This will include removing the battery modules, switchgear, inverters, transformers, cabling, concrete pads, fencing, ethernet, and other infrastructure installed, and installing pavement and sod as needed. New shrubs, trees or other plants may be added as requested by the Facility owner.

The accelerating adoption of grid-scale battery energy storage systems has created new markets and business opportunities, including for recycling the battery systems. This includes an off-site deconstruction of the battery's components, isolation of its elements and raw materials (including lithium, copper, nickel, cobalt, etc.). The potential has created a wave of

new companies offering battery recycling and repurposing for the types of systems being proposed as part of this Project.

Newer methods of more efficient battery recycling are the subject of research, including advanced development of cathode re-lithiation processes, binder removal and recovery, and black mass purification. New thermal techniques are also being developed to identify any contaminants resulting from the recycling processes themselves.

Endurant intends to use the most advanced recycling and repurposing methodologies available at the end of the equipment's life if the materials cannot otherwise be reused.

## **H. SAFETY**

### *1. Site Security & Safety*

The battery system is surrounded by an 8-foot-high security fence, with locked access. Fire Department access to the locked gate will be provided by a Knox Box or other universal key system. Personnel will not be allowed within fenced areas during normal operation and all systems will be locked out during inspection or maintenance. No fires, flames or sources of heat are allowed within the fenced area. Contractors are trained in safe work practices around electrical equipment and specifically BESS. The Site and electrical room will be outfitted with proper signage designating hazards and confirmation of electrical disconnects for both the BESS and the host facility.

### *2. Electric and Magnetic Fields ("EMF")*

During operation, EMF from the Project will derive from: 1) the DC battery banks; 2) the DC cables connecting the battery banks to the power inverters; 3) the AC power inverters that convert the DC power to AC power; 4) and the 23-kV AC underground lines connecting Project to the existing service in the customer's electrical room. There will be no additional EMF from the existing utility interconnection.

The battery banks and DC cables on site will produce static fields (i.e., at 0 Hertz). These sources will not be expected to produce any significant disturbance to the existing levels of static magnetic field produced by natural sources within the earth (i.e., the earth's geomagnetic field) away from the Project location. The existing level of the earth's static geomagnetic field is about 8,000 times lower than the standard for exposure of the general public to static magnetic fields recommended by the International Commission on Non-ionizing Radiation Protection (ICNIRP, 2009).

The power inverters and underground AC lines on site will produce AC fields at frequencies greater than 60 Hz on site. These higher-frequency fields from the inverters, like the DC fields from the battery banks, decrease rapidly to low levels within a few tens of feet or less<sup>6</sup>. These components are located significantly far from any potentially affected receptors and thus will not be an important contributor to AC fields outside the Project boundaries. Additionally, electric fields are blocked (i.e., shielded) by most grounded conducting objects, including buildings, walls, trees, and fences.

### 3. *Fire Safety*

Safety and fire protection are designed into the Project in multiple ways.

Battery Design – Stationary battery energy storage system design continues to evolve to keep pace with the improved standards and lessons learned from performance and fire incidents. The battery system is designed for compliance with the most recent and stringent battery safety standards, including NFPA 855, UL 1642, UL 1973 and UL 9540. In addition to meeting the UL 9540 standard, the system has been tested using the UL 9540A testing methodology. These tests are not pass/fail, but rather destructive tests used for evaluating the thermal runaway impacts of a BESS design including propagation, extent of gassing, explosion, or fire. The UL 9540A SolBank Unit Level Test results found the following:

- No module to module or unit to unit thermal runaway propagation
- No flying debris or explosive discharge of gases during the test
- No electrical arcs or other electrical events during the test
- No external flaming observed.

Detection and Alarm Systems – The BESS is equipped with combustible gas detectors to detect the most prevalent flammable/explosive off-gases from lithium iron phosphate battery cells – hydrogen (H<sub>2</sub>), carbon monoxide (CO) and methane (CH<sub>4</sub>). Industry standards recommend either explosion vent panels (deflagration panels) or automatic exhaust venting to address explosion prevention. The BESS is equipped with an exhaust fan that vents flammable/explosive gases upon detection by the gas detection system. The BESS design also integrates several safety features including a temperature detector, a smoke detector, a fire alarm (audible and visual), an alarm panel and manual emergency stop buttons. For explosion protection, the BESS is

---

<sup>6</sup> Tell TA, Hooper HC, Sias GG, Mezei G, Hung P, Kavet R. Electromagnetic fields associated with commercial solar photovoltaic electric power generating facilities. J Occup Environ Hyg 12: 795-803, 2015.

equipped with combustible gas sensors, an exhaust fan and pressure balancer. The system is not equipped with an inert gas suppression system (which reduces oxygen levels in confined space) given the system is vented thus preventing effective reduction of oxygen levels.

Battery Management System - The BMS constantly monitors cell and pack level voltage, temperature, status of the various detectors (smoke, temperature, and gas) and other parameters to ensure early detection of pre-fault conditions, and immediate detection of fault events. Should any parameter exceed a permissible value, the BMS will surface appropriate alarms and take appropriate protective actions including the potential to disconnect the affected string.

#### 4. *Fire Response*

There are many factors to consider in determining the appropriate response to an incident at a battery storage facility. Endurant has worked with the Windsor Fire Marshal to discuss fire response options and strategies, and ways that Endurant can support the Windsor Volunteer Fire Department, through information, training, and other resources. Life safety and protection of adjacent properties are the response priorities. A battery fire at the Project should be monitored for propagation to other hazards and allowed to burn itself out. First responders should not enter the fenced area other than for life safety concerns. Water may be used, at the Fire Department's discretion, to control the temperature of adjacent hazards that are not fire involved. Water has not been shown to be effective in extinguishing a lithium-ion fire but can be used to limit the potential spread of fire to adjacent structures. The Project location and configuration at the Property provide a buffer from adjacent buildings. Based on the UL 9540A testing results, and the lack of unit-to-unit propagation observed, it is expected that any fire at the Project will be contained within the affected battery module.

Fire Department access to the facility will be gained through a new access point off of the Facility driveway. There is adequate space for staging and response activities, and the driveway and facility parking areas to the east can be used to provide if additional space is necessary for Incident Command activities.

During Endurant's meeting with the Fire Department, access to fire prevention water was discussed. A municipal hydrant is located on Deerfield Drive. Additional water through a private water system is provided for facility use at Taylor & Fenn and the property to the north, and it is unclear whether this system can be used- this will be explored in the coming Project phases. The suitability of the private water system will continue to be investigated with the water

system owners and the Fire Marshal. Additional discussions will also continue with the Fire Marshal as part of the Fire Plan review process.

As discussed above, water is used to cool adjacent buildings and to prevent the spread of fire. Neither water, nor any other fire suppressants (i.e., foams, etc.), have been shown to extinguish a lithium-ion fire. Accordingly, neither water deluge nor suppressant media are recommended fire responses. Any fire water generated from the response will be from cooling adjacent buildings and electrical equipment to prevent spread of fire, and as such, it does not come into contact with the batteries, which are contained in weather-proof enclosures. Fire water makeup would be consistent with that generated during routine fire response of manufacturing buildings and electrical equipment.

#### 5. *Off-Gas Composition*

Battery system modules are designed to be maintained within a safe temperature range via the thermal management system which controls the internal system temperature through heating and cooling. At normal operating temperature, there is little or no off-gassing from the batteries. In a thermal runaway or fire, elevated temperature causes off-gassing from the battery cells. Gas composition is determined by the battery’s chemistry. Off-gas from lithium iron phosphate batteries during thermal runaway or fire is generally characterized as follows:

<b>Gas Component</b>	<b>Percent (by volume)</b>
Hydrogen (H <sub>2</sub> )	48.013 %
Carbon monoxide (CO)	11.191 %
Carbon dioxide (CO <sub>2</sub> )	27.325 %
Hydrocarbons (HC)	12.999 %

The danger of these components is their ability to form an explosive mixture with air. The UL 9540A tests indicated resulting gas concentrations during thermal runaway of much less than 25% of the Lower Flammability Limit (“LFL”) which is the concentration at which it will reach a flammable point. A 25% LFL concentration is the first alarm trigger for the gas detectors installed in the units (50% is the next).

The systems incorporate active venting to reduce the buildup of flammable gases to mitigate hazards associated with the amount of off-gas produced. The density of any vented off-gasses will be lighter than air thus allowing them to rise and disperse and minimize the risk of creating a localized explosive atmosphere.

## 6. *Emergency Planning*

Endurant has developed an Emergency Response Plan (“ERP”) that documents the procedures in place to prepare for and respond to an emergency at the BESS Project. The ERP delineates emergency response responsibilities of personnel and identifies mutual aid resources available by off-site responders. It also identifies training provided to site personnel in responding to emergencies and identifies drill procedures and incident investigation procedures. The ERP has been prepared as part of Project planning. The plan will be updated to reflect additional site-specific input generated as part of the permitting process and with further consultation with the Windsor Fire Marshal and Windsor Volunteer Fire Department. A running record of changes and updates will be maintained with the plan. The ERP is provided in Appendix J.

## **VIII. CONCLUSION**

For the foregoing reasons, Endurant Energy respectfully requests that the Council issue a determination that the proposed Project as described in this Petition will not have a substantial adverse environmental effect, and therefore, that a Certificate is not required.