



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935 Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
Web Site: portal.ct.gov/csc

VIA ELECTRONIC MAIL

March 22, 2024

Paul R. Michaud, Esq.
Michaud Law Group LLC
515 Centerpoint Drive, Suite 503
Middletown, CT 06457
pmichaud@michaud.law

RE: **PETITION NO. 1601** – TRITEC Americas, LLC notice of election to waive exclusion from Connecticut Siting Council jurisdiction, pursuant to Connecticut General Statutes §16-50k(e), and petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a 0.999-megawatt AC solar photovoltaic electric generating facility located at 958 Route 163, Montville, Connecticut, and associated electrical interconnection. **Council Interrogatories to Petitioner – Set 2.**

Dear Attorney Michaud:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 5, 2024. Please submit an original and 15 copies to the Council's office and an electronic copy to siting.council@ct.gov. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the April 5, 2024 deadline.

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

c: Service List dated November 15, 2023

**Petition No. 1601
TRITEC Americas, LLC
958 Route 163, Montville, Connecticut**

**Interrogatories – Set 2
March 22, 2024**

44. Referencing Interrogatory response 29, can a transformer be installed with a secondary containment system and/or a low-level oil alarm?
45. What is the noise profile of the selected transformer?
46. Referencing Interrogatory response 31, submit a detailed sound level calculation work sheet or a sound study that accounts for cumulative noise levels from the proposed eight inverters and transformer at the nearest property line.
47. Referencing Interrogatory responses 41 & 42, what comments did the DOT have regarding the location of the access drive?