

Late-Filed Exhibit 3

Spill Response and Prevention Plan that includes protocols for transformer spills and the identification of the construction vehicle refueling area.

Spill Response and Prevention Plan

**0.99 MW AC Ground Mounted Solar Project
250 Carter Street, Manchester, CT**

Date:

May 3, 2024

Prepared By:

Horton Electrical Services, LLC
97 River Road
Canton, CT 06019

1. Introduction.

The Spill Response and Prevention Plan (“SRPP”) was developed for the construction of a 0.99 MW AC ground mounted solar array (“Project”) located at 250 Carter Street in Manchester, Connecticut (“Project Site”).

2. General Requirements.

The Project Site is proximate to sensitive environmental features, and as such Horton Electrical Services, LLC (“Contractor”) is required to take precautions related to the storage of petroleum materials and equipment refueling. The Contractor is responsible for containing and properly cleaning up any inadvertent fuel or petroleum (i.e., oil, hydraulic fluid, biodegradable transformer insulating fluid, etc.) spill.

The Contractor shall not keep any above ground fuel or oil storage onsite greater than 1,320 gallons in cumulative volume.

The Contractor is responsible for keeping and maintaining a spill containment kit at the Project Site for the duration of the construction of the Project. The spill containment kit shall consist of a sufficient supply of absorbent pads and absorbent material, as well as contain this Spill Prevention and Materials Storage Plan. In addition, a waste drum will be kept on site to contain any used absorbent pads/material for proper and timely disposal off site in accordance with applicable local, state, and federal laws.

The Contractor shall make all workers and subcontractors at the Project Site aware of this SRPP and shall include it as part of their job briefings.

3. Specific Spill Response and Prevention Procedures.

The Contractor will adhere to the following spill response and prevention procedures.

Refueling and Material Storage

- All light duty construction support vehicles will be fueled off-Site at a service station.
- Refueling of vehicles on-Site will take place in a supervised manner to avoid any overfills.
- Refueling of vehicles on-Site will take place at least 100 feet from any wetlands or water courses located on the property.
- Refueling of vehicles or machinery will take place on an impervious pad with secondary containment designed to contain petroleum fuels.
- Any refueling tanks and/or drums or other hazardous materials that must be kept on Site will be stored on an impervious surface utilizing secondary containment and be kept at least 100 feet from any wetlands or water courses located on the property.

Spill Clean Up

- Obtain the Spill Response Kit from the designated location on Site.
- Place the absorbent materials directly on the spill.

- Continue to place the absorbent materials around the spill to prevent any further release.
- Ensure that the spill is eliminated or isolated at the source.
- Determine the type and approximate amount of material that was spilled.
- Contact the appropriate Site contacts and local, state, and/or federal agencies as required. Contact a disposal company to properly dispose of any contaminated materials.
- Complete a report on the incident.

Reporting

- Complete an incident report for each spill.
- Submit a completed incident report to local, state, and federal agencies, as required.
- The Connecticut Department of Energy & Environmental Protection (DEEP), Emergency Response Unit should be contacted at: (860) 424-3338, in the event of an emergency spill.

4. Site and Emergency Contact Information

<p><u>Project Owner</u></p> <p>TRITEC Americas, LLC 888 Prospect St., Suite 200 La Jolla, CA 92037 (619) 363-3080</p>	<p><u>Local Fire Department</u></p> <p>Manchester Fire Department 75 Center St. Manchester, CT 06040 (860) 647-3266 (non-emergency) 911 (emergency)</p>
<p><u>Project Site & Construction Contact</u></p> <p>Horton Electrical Services, LLC 97 River Rd. Canton, CT 06019 (860) 965-7538</p>	<p><u>Local Police Department</u></p> <p>Manchester Police Department 239 Middle Tpke East Manchester, CT 06040 (860) 645-5500 (non-emergency) 911 (emergency)</p>
<p><u>Spill Clean Up Contractor</u></p> <p>Clean Harbors Environmental 51 Broderick Rd Bristol, CT 06010 (860) 583-8917</p>	<p><u>State Agency</u></p> <p>CT DEEP Emergency Response Unit 79 Elm St. Hartford, CT 06106 (860) 424-3338 (866) 337-7745 (toll-free)</p>