

# Doosan Fuel Cell America, Inc.

# Fuel Cell Emergency Response Guide

**York Correctional** 

201 West Main St.

East Lyme, CT 06357



**Left Blank** 



### **DISCLAIMER**

Doosan Fuel Cell America reserves the right to change or modify, without notice, the design or equipment specifications of the PureCell® system Model 400 without obligation with respect to equipment either previously sold or to be sold. This guide is provided by Doosan Fuel Cell America, and no liability will accrue to Doosan Fuel Cell America based on the information or specifications included herein. No warranties or representations are made by this guide and no warranties or representations shall apply to the equipment except as stated in Doosan Fuel Cell America's standard terms and conditions of sale applicable at the time of purchase, a copy of which will be provided upon request. The Model 400 is designed to provide safe and reliable service when operated within design specifications, according to all applicable instructions, and with the appropriate operating materials. When operating this equipment, use good judgment and follow safety precautions to avoid damage to equipment and property or injury to personnel. Be sure to understand and follow the procedures and safety precautions contained in all applicable instructions, operating materials, and those listed in this guide. All information in this document is as of February 10, 2020.

### **Policy**

The following plan has been developed to minimize the severity of damage to human health, the environment, and property in the event of an unexpected failure.

#### Scope

This Emergency Response Guide shall be integrated into the site Emergency Response Plan. Information contained in this document is customized to meet local requirements and shall be shared with local responders as necessary. This guide in no way assumes or transfers liability or ownership. Doosan Fuel Cell America should be contacted if clarification is needed.





## **Emergency Contacts and Numbers**

| Local Emergency Number  | 911   |
|---|---|
| Doosan Fuel Cell America Control Center                       | (860) 727-2847  |
| Fire Department – Non-emergency number                        | Niantic Fire Dept. (860) 739-3449   |
| Hospital – Non-emergency number                               | Lawrence and Memorial Hospital 365 Montauk Ave, New London, CT 06320 (860) 442-0711 |
| Electric Utility Name: Eversource Energy                      | (800) 286-2000  |
| Gas Utility<br>Name: Eversource Gas                           | 855-645-2427  |
| Local Oil & Chemical Spill Response Division                  | 800-645-8265  |
| CT. DEEP Oil & Chemical Spill Response Division               | 860-424-3338  |
| EPA Region 1 Emergency Response                               | (800) 424-8802 Environmental Emergency  |
| OSHA - Occupational Safety and Health Admin. Emergency Number | (800) 321-6742 National Emergency Number  |
| Poison Control Center   | (800) 222-1222 National Emergency Number  |



## **Fuel Cell Hazard Overview**







| Rear View Panel  | Primary Hazard                                   | Front View Panel   | Primary Hazard                                   |
|------------------|--|--------------------|--|
| 1 (Computer      | Electrical = 120 VAC                             | 12 (Reformer)      | Electrical = 480 VAC                             |
| Terminal)        |  |                    | Chemical = Air sensitive catalyst / combustibles |
|                  |  |                    | Thermal = 600°F Reformer                         |
|                  |  |                    | Pressure = 150 psi steam                         |
| 2 (Swing Door)   | Electrical = 480 VAC                             | 13 (Reformer)      | Electrical = 480 VAC                             |
|                  |  |                    | Chemical = Air sensitive catalyst / combustibles |
|                  |  |                    | Thermal = 600°F Reformer                         |
|                  |  |                    | Pressure = 150 psi steam                         |
| 3 (Mechanical    | Electrical = 480 VAC                             | 14 (Reformer)      | Electrical = 480 VAC                             |
| Entry)           | Chemical = Propylene Glycol                      |                    | Chemical = Air sensitive catalyst / combustibles |
|                  | Thermal = 350°F Steam                            |                    | Thermal = 600°F Reformer                         |
|                  | Pressure = 150 psi Steam                         |                    | Pressure = 150 psi steam                         |
| 4 (Mechanical    | Chemical = Propylene Glycol                      | 15 (DC Cell Stack) | Electrical = 300 VDC                             |
| Entry)           | Thermal = 350°F Steam                            |                    | Chemical = Solid phosphoric acid / combustibles  |
|                  | Pressure = 150 psi Steam                         |                    |  |
| 5 (TMS)          | Electrical = 480 VAC                             | 16 (DC Cell Stack) | Electrical = 300 VDC                             |
|                  | Chemical = Propylene Glycol / Deionized Water /  |                    | Chemical = Solid phosphoric acid / combustibles  |
|                  | Resin  |                    |  |
|                  | Thermal = 350oF Steam                            |                    |  |
|                  | Pressure = 150 psi Steam                         |                    |  |
| 6 (ILS)          | Electrical = 480 VAC                             | 17 (DC Cell Stack) | Electrical = 300 VDC                             |
|                  | Chemical = Air sensitive catalyst / combustibles |                    | Chemical = Solid phosphoric acid / combustibles  |
|                  | Thermal = 600°F Reformer                         |                    |  |
|                  | Pressure = 150 psi steam                         |                    |  |
| 7 (Fuel          | Electrical = 480 VAC                             | 18 (DC Cell Stack) | Electrical = 300 VDC                             |
| Processing Area) | Chemical = Air sensitive catalyst / combustibles |                    | Chemical = Solid phosphoric acid / combustibles  |
|                  | Thermal = 600°F Reformer                         |                    |  |
|                  | Pressure = 150 psi steam                         |                    |  |
| 8 (Fuel          | Electrical = 480 VAC                             | 19 (Grid Connect   | Electrical = 480 VAC                             |
| Processing Area) | Chemical = Air sensitive catalyst / combustibles | Disconnect)        |  |
|                  | Thermal = 600°F Reformer                         |                    |  |
|                  | Pressure = 150 psi steam                         |                    |  |
| 9 (Gas/Nitrogen  | Chemical = combustibles                          | 20 (ESM)           | Electrical = 1400 VDC / 480 VAC                  |
| Inlet)           |  |                    |  |
| 10 (Reformer)    | Electrical = 480 VAC                             | 21 (Blower 110)    | Electrical = 300 VDC                             |
|                  | Chemical = Air sensitive catalyst / combustibles |                    | Mechanical = Blower                              |
|                  | Thermal = 600°F Reformer                         |                    |  |
|                  | Pressure = 150 psi steam                         |                    |  |
| 11 (Reformer)    | Electrical = 480 VAC                             | ALL Roof Panels    | Multiple Hazards                                 |
|                  | Chemical = Air sensitive catalyst / combustibles |                    | DO NOT WALK ON ROOF!                             |
|                  | Thermal = 600°F Reformer                         |                    |  |
|                  | Pressure = 150 psi steam                         |                    |  |



## **Conditional Assessment**

| Normal Condition   | Potential Abnormal Condition                                      |          | Response  |  |
|--|---|----------|---|--|
| Fuel Cell  | Dark colored smoke exiting chimney or any other part of enclosure | 1.<br>2. | Establish safe perimeter  Contact Doosan Fuel Cell America  Control Center (860) 727-2847 |  |
| White steam exiting power plant at exhaust chimney, above panel #6 (It can be a large amount of white steam depending on ambient | Observable fire or heavy smoke at any point on fuel cell          | 1.       | Press Fuel Cell 'Stop Button' – Only if safely accessible!                                |  |
| conditions)  |   | 2.       | Dial 911 or Local Emergency<br>Response Number  |  |
|  |   | 3.       | Establish safe perimeter  |  |
|  |   | 4.       | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>                  |  |
| Fuel Cell  | Grinding or loud intermittent noises                              | 1.       | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>                  |  |
| Moderate humming, clicking and fan sounds  | Observable fire or heavy smoke at any point on fuel cell          | 1.       | Press Fuel Cell 'Stop Button' – Only if safely accessible!                                |  |
|  |   | 2.       | Dial 911 or Local Emergency<br>Response Number  |  |
|  |   | 3.       | Establish safe perimeter  |  |
|  |   | 4.       | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>                  |  |
| Cooling Module   | Smoke or fire coming from module                                  | 1.       | Press Fuel Cell 'Stop Button' – Only if safely accessible!                                |  |
| Fan humming  |   | 2.       | Dial 911 or Local Emergency<br>Response Number  |  |
|  |   | 3.       | Establish safe perimeter  |  |
|  |   | 4.       | Contact Doosan Fuel Cell America<br>Control Center (860) 727-2847                         |  |



|  | Grinding or loud noise coming from fans             | 1.                     | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>   |
|--|---|------------------------|--|
| Cooling Module   | Small leak dripping from joint, valve or connection | 1.                     | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>   |
| No leaking from cooling loop piping or coils           | Medium to large leak                                | 1.                     | Follow local spill response protocol or contact Clean Harbors Emergency Cleanup Response (800) 645-8265          |
|  |   | 2.                     | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>   |
| Mechanical Hi/Lo Grade Piping                          | Small leak dripping from joint, valve or connection | 1.                     | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>   |
| Small amounts of condensate dripping from piping       | Medium to large leak                                | 1.                     | Follow local spill response protocol<br>or contact Clean Harbors<br>Emergency Cleanup Response<br>(800) 645-8265 |
|  |   | 2.                     | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>   |
| Disconnects/Other Equipment                            | Smoke or fire coming from equipment                 | 1.                     | Dial 911 or Local Emergency<br>Response Number   |
| No leaks or smoke                                      |   | <ol> <li>3.</li> </ol> | Establish safe perimeter  Contact Doosan Fuel Cell America  Control Center (860) 727-2847                        |
| Compressed Gas Manifold (N2/H2)                        | Leaks – may be able to hear hissing sound.          | 1.                     | If Indoors – Evacuate Immediately! Dial 911 or Local Emergency Response Number                                   |
| No leaks, May hear intermittent gas flow during purges |   | 2.                     | Establish safe perimeter   |
|  |   | 3.                     | Contact Doosan Fuel Cell America<br>Control Center <b>(860) 727-2847</b>   |



## Fuel Cell Related Safety Data Sheets (SDS)

| 1 | Propylene Glycol – DowFrost®                               |
|---|--|
| 2 | Phosphoric Acid – Solid                                    |
| 3 | Reformer/ILS Catalysts                                     |
| 4 | Anion/Cation Resin   |
| 5 | Nitrogen / Hydrogen Compressed Gas Mixture (non-flammable) |

## Inspections

| Inspection Type                  | Equipment Requirements  | Frequency Required |
|----------------------------------|-------------------------|--------------------|
| General Maintenance              | Laptop, Service Vehicle | Monthly            |
| General Housekeeping             | N/A                     | Monthly            |
| Waste and Chemical Storage*      | N/A                     | Weekly             |
| Internal Combustible Gas Monitor | AT-160 Calibration Kit  | Annual             |
| Fire Prevention                  | N/A                     | Monthly            |

<sup>\*</sup>When applicable

Fuel Cell operation is monitored and controlled remotely 24 hours a day 7 days a week by the Doosan Fuel Cell America Control Center. Upset or abnormal occurrences outside of normal operating parameters are immediately identified and service technicians are dispatched within 24 hours to respond when required.

## **Emergency Procedures**

| Alarms                           | There are no audible or visual alarms on Fuel Cell. Alarm conditions are relayed immediately to the Doosan Fuel Cell America Control Center. The Doosan Fuel Cell America Control Center will then contact the appropriate site personnel on the site's emergency contact list. |
|----------------------------------|---|
| Emergency Shut Down Onsite       | Actuate Fuel Cell Stop Button   |
| Emergency Area Egress - Gas Odor | Evacuate 330 Feet in all directions   |
| Emergency Area Egress - Fire     | Evacuate 330 Feet in all directions – CV000 automatic natural gas supply shut off   |
| Emergency Egress - General       | Fuel cell is unmanned remotely monitored and controlled. No Doosan Fuel Cell America employees attending unit unless service or maintenance is required.  |



## Signage and labeling



Perimeter fencing will have signage clearly identifying that "No smoking, no ignition sources" on every side of the fence. Signage will be similar to the sign below:



### General:

### **Safety Hazard Analysis**

The PureCell® Model 400 fuel cell system has been designed to meet strict ANSI/CSA safety standards to protect against risks from electrical, mechanical, chemical, and combustion safety hazards. The following items are a few of the safety measures incorporated into the design.

## **Fire Detection and Protection:**

The power plant design incorporates a combustible gas sensor as well as thermal fuses located throughout the power module cabinet to detect fire. The detection of a potential flammable gas mixture, a fire, or the failure of this detection circuit will result in a power plant shutdown and a subsequent inert gas (nitrogen) purge of the fuel cell stack and fuel processing system. This event will also result in an alarm callout notification to Doosan Fuel Cell America service personnel. The power plant is designed with an integral emergency-stop button on the outside of the enclosure to enable immediate shutdown in the event of an emergency. There is also a gas shut-off valve and electrical disconnect switch easily accessible to emergency personnel. There are no restrictions for type of fire suppression equipment.



#### Gas Leak:

Augmenting the internal combustible gas sensor, the power plant also monitors the flow rate of natural gas. If the gas flow rate exceeds the equivalent power production of the power plant then a shutdown will result. The largest possible accumulation from a leak prior to shutdown is below combustible limits. Fuel valves inside the power plant are "fail safe" and will return to their normally closed position upon loss of power. The power plant is designed to have a physical barrier that separates the equipment handling combustible gases (fuel compartment) from electrical or potential spark-creating equipment (motor compartment). The fuel compartment is kept at a negative pressure to contain and remove any potential gas leaks, whereas the motor compartment is pressurized by a fan source to prevent combustible gases from entering.

## Hydrogen:

Hydrogen is lighter than air and thus does not pool like other fuels and will readily dissipate with proper ventilation making it less likely to ignite. Although hydrogen has low self-ignition characteristics, the fuel in the power plant is not pure hydrogen. Also, the power plant is not producing or storing hydrogen, it consumes hydrogen-rich gas equal to what it requires to produce power. The fuel cell stack is wrapped in a fire retardant blanket. There are no materials inside the unit that would sustain a flame. There is no large volume of gas or any ignition that occurs within the cell stack.

## **Phosphoric Acid:**

Phosphoric acid is integral part of the fuel cell system, acting as the electrolyte within the fuel cell stack. Phosphoric acid is a surprisingly common substance that is contained in common cola drinks. A leak of phosphoric acid is not possible because phosphoric acid is not in liquid form once applied in the equipment. There is no reservoir of liquid. Phosphoric acid is contained in the porous structure of the fuel cell stack material by capillary action, similar to how ink is absorbed into a blotter.

### Fluid Leak:

The only fluid source is water. All pressurized water vessels are designed to ASME boiler codes and inspected annually. All piping, welds, etc. meet pressurized piping standards. Water produced through the electrochemical process is "pure" water and is reclaimed and reused by the process. The other source of water is water used in the external cooling module, which is mixed with a polypropylene glycol and a rust inhibitor to prevent rust and freezing in colder climates.

#### Hazardous Waste:

The fuel cell does not produce any hazardous waste. Standard Material Safety Data Sheets (MSDS) are available upon request.



**APPENDIX 1 – SAFETY DATA SHEETS** 





Revision date: 04-07-2014

## SAFETY DATA SHEET

#### 1. Identification

Product identifier: PHOSPHORIC ACID

Other means of identification

Synonyms: Ortho-Phosphoric Acid, White Phosphoric Acid

Product No.: 0240, 6908, 2798, 2797, 5854, 2796, 5804, 2788, 0259, 5372, 0274, 0269, 0268, 0265, 0264,

0262, 0260, 0255, 0251

Recommended use and restriction on use

Recommended use: Not available. Restrictions on use: Not known.

Manufacturer/Importer/Supplier/Distributor information

Manufacturer

Company Name: Avantor Performance Materials, Inc. Address: 3477 Corporate Parkway, Suite 200

Center Valley, PA 18034

Telephone:

Customer Service: 855-282-6867

Fax: Contact Person:

Environmental Health & Safety

e-mail: info@avantormaterials.com

Emergency telephone number:

24 Hour Emergency: 908-859-2151

Chemtrec: 800-424-9300

## 2. Hazard(s) identification

#### Hazard classification

## Physical hazards

Corrosive to metals Category 1

Health hazards

Acute toxicity (Oral) Category 4
Skin corrosion/irritation Category 1
Serious eye damage/eye irritation Category 1
Specific target organ toxicity - single Category 3

exposure

Unknown toxicity

Acute toxicity, oral 0 %
Acute toxicity, dermal 0 %
Acute toxicity, inhalation, vapor 100 %
Acute toxicity, inhalation, dust or mist 100 %

Unknown toxicity

Acute hazards to the aquatic 84 %

environment

Chronic hazards to the aquatic 84 %

environment

COP

SOUR

Label elements

SDS\_US - SDSMIX000331

1/10

CELL





Revision date: 04-07-2014

#### Hazard symbol:



Signal word: Danger

Hazard statement: May be corrosive to metals.

Harmful if swallowed.

Causes severe skin burns and eye damage.

May cause respiratory irritation.

#### Precautionary statement

Prevention: Keep only in original container. Do not breathe dust/fume/mist/vapors. Do

not eat, drink or smoke when using this product. Use only outdoors or in a

well-ventilated area. Wear protective gloves/protective clothing/eye protection/face protection. Wash thoroughly after handling.

Absorb spillage to prevent material damage. IF SWALLOWED: Rinse Response:

mouth. Do NOT induce vomiting. IF ON SKIN (or hair): Remove/take off immediately all contaminated clothing. Rinse skin with water/shower. Wash contaminated clothing before reuse. IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. IF INHALED: Remove victim to fresh air and keep at rest in a position comfortable for breathing. Immediately call a POISON

CENTER or doctor/physician.

Storage: Store locked up. Store in a well-ventilated place. Keep container tightly

closed. Store in corrosive resistant container with a resistant inner liner.

Disposal: Dispose of contents/container to an appropriate treatment and disposal

facility in accordance with applicable laws and regulations, and product

characteristics at time of disposal.

Other hazards which do not result in GHS classification:

None

## 3. Composition/information on ingredients

## Mixtures

| Chemical identity | Common name and synonyms | CAS<br>number | Content in percent (%)* |
|-------------------|--------------------------|---------------|-------------------------|
| PHOSPHORIC ACID   |                          | 7664-38-2     | 80 - 90%                |

<sup>\*</sup> All concentrations are percent by weight unless ingredient is a gas. Gas concentrations are in percent by volume.

## 4. First-aid measures

General information: Get medical advice/attention if you feel unwell. Show this safety data sheet

to the doctor in attendance.

SDS\_US - SDSMIX000331 IENT OR ANY INFORMATION IN IT FOR ANY PURPOSE. INCLUDING WITHOUT LIMITATION TO DESIGN, MANUFACTURE, OR REPAIR PARTS, WITHOUT EXPRESS WRITTEN PERMISSION, NEITHER RECEIPT FROM ANY



AVANTOR'

Version: 1.0

Revision date: 04-07-2014

Ingestion: Do NOT induce vomiting. Call a physician or poison control center

immediately. If vomiting occurs, keep head low so that stomach content

doesn't get into the lungs.

Inhalation: Move to fresh air. Call a physician or poison control center immediately.

Apply artificial respiration if victim is not breathing If breathing is difficult,

give oxygen.

Skin contact: Immediately flush with plenty of water for at least 15 minutes while

removing contaminated clothing and shoes. Call a physician or poison control center immediately. Wash contaminated clothing before reuse.

Destroy or thoroughly clean contaminated shoes.

Eye contact: Immediately flush with plenty of water for at least 15 minutes. If easy to do,

remove contact lenses. Call a physician or poison control center

immediately. In case of irritation from airborne exposure, move to fresh air.

Get medical attention immediately.

Most important symptoms/effects, acute and delayed

Symptoms: Causes severe skin and eye burns. Causes digestive tract burns.

Indication of immediate medical attention and special treatment needed

Treatment: Treat symptomatically. Symptoms may be delayed.

5. Fire-fighting measures

General fire hazards: No data available

Suitable (and unsuitable) extinguishing media

Suitable extinguishing

media:

The product is non-combustible. Use fire-extinguishing media appropriate

for surrounding materials.

Unsuitable extinguishing

media:

None known.

Specific hazards arising from

the chemical:

Not combustible, but if involved in a fire decomposes to produce toxic

gases.

Special protective equipment and precautions for firefighters

Special fire fighting

procedures:

Move containers from fire area if you can do so without risk. Use water

spray to keep fire-exposed containers cool.

Special protective equipment

for fire-fighters:

Firefighters must use standard protective equipment including flame

retardant coat, helmet with face shield, gloves, rubber boots, and in enclosed spaces, SCBA. Product is highly acidic. Wear protective gear if

spilled during fire fighting.

6. Accidental release measures

Personal precautions, protective equipment and emergency procedures: See Section 8 of the MSDS for Personal Protective Equipment. Do not touch damaged containers or spilled material unless wearing appropriate protective clothing. Keep unauthorized personnel away. Keep upwind.

Ventilate closed spaces before entering them.

SDS\_US - SDSMIX000331



AVANTOR

Version: 1.0

Revision date: 04-07-2014

Methods and material for containment and cleaning

up:

Neutralize with lime or soda ash. Absorb spill with vermiculite or other inert material, then place in a container for chemical waste. Clean surface thoroughly to remove residual contamination. Dike far ahead of larger spill

for later recovery and disposal.

Notification Procedures:

Inform authorities if large amounts are involved.

Environmental precautions:

Do not contaminate water sources or sewer. Prevent further leakage or

spillage if safe to do so.

## 7. Handling and storage

Precautions for safe handling:

Do not get in eyes, on skin, on clothing. Do not taste or swallow. Wash thoroughly after handling. Do not eat, drink or smoke when using the product. Use caution when adding this material to water. Add material slowly when mixing with water. Do not add water to the material; instead, add the material to the water.

Conditions for safe storage,

including any incompatibilities:

Do not store in metal containers. Keep container tightly closed. Store in a

well-ventilated place.

### 8. Exposure controls/personal protection

#### Control parameters

Occupational exposure limits

| Chemical identity | Туре    | Exposure Limit values | Source   |
|-------------------|---------|-----------------------|--|
| PHOSPHORIC ACID   | TWA     | 1 mg/m3               | US. ACGIH Threshold Limit Values (2011)  |
|                   | STEL    | 3 mg/m3               | US. ACGIH Threshold Limit Values (2011)  |
|                   | REL     | 1 mg/m3               | US. NIOSH: Pocket Guide to Chemical<br>Hazards (2010)  |
|                   | STEL    | 3 mg/m3               | US. NIOSH: Pocket Guide to Chemical<br>Hazards (2010)  |
|                   | PEL     | 1 mg/m3               | US. OSHA Table Z-1 Limits for Air<br>Contaminants (29 CFR 1910.1000) (02 2006)                   |
|                   | TWA     | 1 mg/m3               | US. OSHA Table Z-1-A (29 CFR 1910.1000)<br>(1989)  |
|                   | STEL    | 3 mg/m3               | US. OSHA Table Z-1-A (29 CFR 1910.1000)<br>(1989)  |
|                   | TWA     | 1 mg/m3               | US. Tennessee. OELs. Occupational Exposure<br>Limits, Table Z1A (06 2008)                        |
|                   | STEL    | 3 mg/m3               | US. Tennessee. OELs. Occupational Exposure<br>Limits, Table Z1A (06 2008)                        |
|                   | ST ESL  | 10 µg/m3              | US. Texas. Effects Screening Levels (Texas<br>Commission on Environmental Quality) (12<br>2010)  |
|                   | AN ESL  | 1 µg/m3               | US. Texas. Effects Screening Levels (Texas<br>Commission on Environmental Quality) (12<br>2010)  |
|                   | TWA PEL | 1 mg/m3               | US. California Code of Regulations, Title 8,<br>Section 5155. Airborne Contaminants (08<br>2010) |
|                   | STEL    | 3 mg/m3               | US. California Code of Regulations, Title 8,<br>Section 5155. Airborne Contaminants (08<br>2010) |

Appropriate engineering controls No data available.





Revision date: 04-07-2014

## Individual protection measures, such as personal protective equipment

General information: Good general ventilation (typically 10 air changes per hour) should be used.

Ventilation rates should be matched to conditions. If applicable, use process enclosures, local exhaust ventilation, or other engineering controls to maintain airborne levels below recommended exposure limits. If exposure limits have not been established, maintain airborne levels to an acceptable level. An eye wash and safety shower must be available in the

immediate work area.

Eye/face protection: Wear safety glasses with side shields (or goggles) and a face shield.

Skin protection

Hand protection: Chemical resistant gloves

Other: Wear suitable protective clothing and gloves.

Respiratory protection: In case of inadequate ventilation use suitable respirator. Respirator type:

Chemical respirator with acid gas cartridge.

Hygiene measures: Provide eyewash station and safety shower. Observe good industrial

hygiene practices. Wash hands before breaks and immediately after handling the product. Wash contaminated clothing before reuse. Avoid

contact with eyes. Avoid contact with skin.

#### 9. Physical and chemical properties

Appearance

Physical state: Liquid
Form: Liquid
Color: Colorless
Odor: Odorless

Odor threshold: No data available.

pH: 1.5 0.1 N Aqueous solution

Melting point/freezing point:

Initial boiling point and boiling range:

Flash Point:

Evaporation rate:

Flammability (solid, gas):

21.1 °C

158 °C

Not applicable

No data available.

No data available.

Upper/lower limit on flammability or explosive limits

Flammability limit - upper (%):

Flammability limit - lower (%):

Explosive limit - upper (%):

Explosive limit - lower (%):

No data available.

Explosive limit - lower (%):

No data available.

Vapor pressure: 0.3 kPa

Vapor density: No data available. Relative density: 1.69 (20 °C)

Solubility(ies)

Solubility in water: Miscible with water.
Solubility (other): No data available.
Partition coefficient (n-octanol/water): No data available.
Auto-ignition temperature: No data available.
Decomposition temperature: No data available.
Viscosity: No data available.

SDS\_US - SDSMIX000331





Revision date: 04-07-2014

### 10. Stability and reactivity

Reactivity: No dangerous reaction known under conditions of normal use.

Chemical stability: Material is stable under normal conditions.

Possibility of hazardous

reactions:

Hazardous polymerization does not occur.

Conditions to avoid: Avoid contact with oxidizing agents. Avoid contact with strong reducing

agents. Contact with alkalis.

Incompatible materials: Strong reducing agents. Alkalies. Strong oxidizing agents. Metals.

Hazardous decomposition

products:

oxides of phosphorus

#### 11. Toxicological information

Information on likely routes of exposure

Ingestion: Harmful if swallowed.

Inhalation: Severely irritating to respiratory system.

Skin contact: Causes severe skin burns.

Eye contact: Causes serious eye damage.

Information on toxicological effects

Acute toxicity (list all possible routes of exposure)

Oral

Product: ATEmix (Rat): 1,700 mg/kg

Dermal

Product: ATEmix (): 3,044.44 mg/kg

Inhalation

Product: No data available.

Repeated dose toxicity

Product: No data available.

Skin corrosion/irritation

Product: Causes severe skin burns.

Serious eye damage/eye irritation

Product: Causes serious eye damage.

Respiratory or skin sensitization

Product: Not a skin sensitizer.

Carcinogenicity

Product: This substance has no evidence of carcinogenic properties.

IARC Monographs on the Evaluation of Carcinogenic Risks to Humans:

No carcinogenic components identified

US. National Toxicology Program (NTP) Report on Carcinogens:

No carcinogenic components identified

SDS\_US - SDSMIX000331





Revision date: 04-07-2014

#### US. OSHA Specifically Regulated Substances (29 CFR 1910.1001-1050):

No carcinogenic components identified

Germ cell mutagenicity

In vitro Product:

No mutagenic components identified

In vivo

Product: No mutagenic components identified

Reproductive toxicity

Product: No components toxic to reproduction

Specific target organ toxicity - single exposure
Product: None known

Specific target organ toxicity - repeated exposure Product: None known.

Aspiration hazard

Product: Not classified

Other effects: Not known.

#### 12. Ecological information

Ecotoxicity:

Acute hazards to the aquatic environment:

Fish

Product: No data available.

Aquatic invertebrates

Product: No data available.

Chronic hazards to the aquatic environment:

Fish

Product: No data available.

Aquatic invertebrates

Product: No data available.

Toxicity to Aquatic Plants

Product: No data available.

Persistence and degradability

Biodegradation

**Product:** Expected to be readily biodegradable.

BOD/COD ratio

Product: No data available.

Bioaccumulative potential

Bioconcentration factor (BCF)

Product: No data available on bioaccumulation.

Partition coefficient n-octanol / water (log Kow)
Product: No data available.

SDS\_US - SDSMIX000331





Revision date: 04-07-2014

Mobility in soil: The product is water soluble and may spread in water systems.

Other adverse effects: The product may affect the acidity (pH-factor) in water with risk of harmful

effects to aquatic organisms.

13. Disposal considerations

Disposal instructions: Discharge, treatment, or disposal may be subject to national, state, or local

laws.

Contaminated packaging: Since emptied containers retain product residue, follow label warnings even

after container is emptied.

14. Transport information

DOT

UN number: UN 1805

UN proper shipping name: Phosphoric acid solution

Transport hazard class(es)

 Class(es):
 8

 Label(s):
 8

 Packing group:
 III

 Marine Pollutant:
 No

IMDG

UN number: UN 1805

UN proper shipping name: PHOSPHORIC ACID SOLUTION

Transport hazard class(es)

Class(es): 8
Label(s): 8
EmS No.: F-A, S-B

Packing group: III
Marine Pollutant: No

IATA

UN number: UN 1805

Proper Shipping Name: Phosphoric acid, solution

Transport hazard class(es):

15. Regulatory information

US federal regulations

TSCA Section 12(b) Export Notification (40 CFR 707, Subpt. D)

US. OSHA Specifically Regulated Substances (29 CFR 1910.1001-1050)

None present or none present in regulated quantities.

CERCLA Hazardous Substance List (40 CFR 302.4):

PHOSPHORIC ACID Reportable quantity: 5000 lbs.

SDS\_US - SDSMIX000331





Revision date: 04-07-2014

#### Superfund amendments and reauthorization act of 1986 (SARA)

#### Hazard categories

X Acute (Immediate) X Chronic (Delayed) Fire Reactive Pressure Generating

#### SARA 302 Extremely hazardous substance

None present or none present in regulated quantities.

#### SARA 304 Emergency release notification

Chemical identity RQ

PHOSPHORIC ACID 5000 lbs.

#### SARA 311/312 Hazardous chemical

Chemical identity Threshold Planning Quantity
PHOSPHORIC ACID 500 lbs

#### SARA 313 (TRI reporting)

None present or none present in regulated quantities.

#### Clean Water Act Section 311 Hazardous Substances (40 CFR 117.3)

PHOSPHORIC ACID Reportable quantity: 5000 lbs.

#### Clean Air Act (CAA) Section 112(r) Accidental Release Prevention (40 CFR 68.130):

None present or none present in regulated quantities.

#### US state regulations

### US. California Proposition 65

No ingredient regulated by CA Prop 65 present.

#### US. New Jersey Worker and Community Right-to-Know Act

PHOSPHORIC ACID Listed

## US. Massachusetts RTK - Substance List

PHOSPHORIC ACID Listed

## US. Pennsylvania RTK - Hazardous Substances

PHOSPHORIC ACID Listed

## US. Rhode Island RTK

PHOSPHORIC ACID Listed

## Inventory Status:

Australia AICS: On or in compliance with the inventory Canada DSL Inventory List: On or in compliance with the inventory EINECS, ELINCS or NLP: On or in compliance with the inventory On or in compliance with the inventory Japan (ENCS) List: China Inv. Existing Chemical Substances: Not in compliance with the inventory. Korea Existing Chemicals Inv. (KECI): On or in compliance with the inventory Canada NDSL Inventory: Not in compliance with the inventory. Philippines PICCS: On or in compliance with the inventory US TSCA Inventory: On or in compliance with the inventory New Zealand Inventory of Chemicals: On or in compliance with the inventory

Japan Pharmacopoeia Listing:

Not in compliance with the inventory.

Not in compliance with the inventory.

Not in compliance with the inventory.

### 16.Other information, including date of preparation or last revision


SDS\_US - SDSMIX000331





Revision date: 04-07-2014

#### NFPA Hazard ID



Hazard rating: 0 - Minimal; 1 - Slight; 2 - Moderate; 3 - Serious; 4 - Severe

Issue date: 04-07-2014

Revision date: No data available.

Version #: 1.0

Further information: No data available.

Disclaimer: THE INFORMATION PRESENTED IN THIS MATERIAL SAFETY DATA SHEET (MSDS/SDS) WAS PREPARED BY TECHNICAL PERSONNEL

BASED ON DATA THAT THEY BELIEVE IN THEIR GOOD FAITH
JUDGMENT IS ACCURATE. HOWEVER, THE INFORMATION PROVIDED
HEREIN IS PROVIDED "AS IS," AND AVANTOR PERFORMANCE

MATERIALS MAKES AND GIVES NO REPRESENTATIONS OR WARRANTIES WHATSOEVER, AND EXPRESSLY DISCLAIMS ALL WARRANTIES REGARDING SUCH INFORMATION AND THE PRODUCT TO WHICH IT RELATES, WHETHER EXPRESS, IMPLIED, OR

STATUTORY, INCLUDING WITHOUT LIMITATION, WARRANTIES OF ACCURACY, COMPLETENESS, MERCHANTABILITY, NON-INFRINGEMENT, PERFORMANCE, SAFETY, SUITABILITY, STABILITY, AND FITNESS FOR A PARTICULAR PURPOSE, AND ANY WARRANTIES ARISING FROM COURSE OF DEALING, COURSE OF PERFORMANCE, OR USAGE OF TRADE. THIS MSDS/SDS IS INTENDED ONLY AS A CHILDE TO THE APPROPRIATE PRECAUTIONARY HANDLING OF THE

OR USAGE OF TRADE. THIS MSDS/SDS IS INTENDED ONLY AS A GUIDE TO THE APPROPRIATE PRECAUTIONARY HANDLING OF THE MATERIAL BY A PROPERLY TRAINED PERSON USING THIS PRODUCT, AND IS NOT INTENDED TO BE COMPREHENSIVE AS TO THE MANNER AND CONDITIONS OF USE, HANDLING, STORAGE, OR DISPOSAL OF THE PRODUCT. INDIVIDUALS RECEIVING THIS MSDS/SDS MUST ALWAYS EXERCISE THEIR OWN INDEPENDENT JUDGMENT IN DETERMINING THE APPROPRIATENESS OF SUCH ISSUES.

ACCORDINGLY, AVANTOR PERFORMANCE MATERIALS ASSUMES NO LIABILITY WHATSOEVER FOR THE USE OF OR RELIANCE UPON THIS INFORMATION. NO SUGGESTIONS FOR USE ARE INTENDED AS, AND NOTHING HEREIN SHALL BE CONSTRUED AS, A RECOMMENDATION TO INFRINGE ANY EXISTING PATENTS OR TO VIOLATE ANY FEDERAL, STATE, LOCAL, OR FOREIGN LAWS. AVANTOR PERFORMANCE MATERIALS REMINDS YOU THAT IT IS YOUR LEGAL DUTY TO MAKE ALL INFORMATION IN THIS MSDS/SDS AVAILABLE TO YOUR

EMPLOYEES.



860727766b

UTC Power Shipping

Q9:55.17 a.m. 04-30-3009

## MATERIAL SAFETY DATA SHEET

| PRODUCT NAME; Shift Max 2  | 30, Reduced Heterogeneous Catalyst, FC72372   |  |  |  |  |
|--|---|--|--|--|--|
| SECTION 1. CHEMICAL PRODUCT AND COMPANY IDENTIFICATION                                 |   |  |  |  |  |
| Doosan Fuel Cell America, Inc.<br>195 Governors Hwy,<br>South Windsor, CT 05074<br>USA | TELEPHONE: 24 HOUR EMERGENCY: 1-800-424-9300 (CHEWTREG) PRODUCT INFORMATION: 860-727-2300 |  |  |  |  |
| MSDS NO: NN58  | INITIAL RELEASE DATE: 4/23/2009 REVISION DATE:  |  |  |  |  |
| GENERIC DESCRIPTION:<br>PHYSICAL FORM;<br>GOLOR:<br>OBOR:                              | Reduced catalyst Cylindrical tablets Dark brown None                                      |  |  |  |  |
| NFPA 704 CODES: HEALTH:  | 1 FLAMMABILITY: 4 REACTIVITY: 2   |  |  |  |  |
| NOTE: NFPA = NATIONAL FIRE PRO   | PTECTION ASSOCIATION  |  |  |  |  |

| SECTION 2. CO   | MPOSITION /   | INFORMATION ON INGRED | ILENTS                              | <u> </u>                |  |  |  |
|-----------------|---|-----------------------|-------------------------------------|-------------------------|--|--|--|
|                 |   |                       | EXPOSURE LIMITS                     |                         |  |  |  |
| CAS NUMBER      | WWT/VOL.  | COMPONENTS            | OSHA                                | AGGIH                   |  |  |  |
| The following & | The following is the composition of the packed tablets: |                       |                                     |                         |  |  |  |
| 1344-28-1       | 9-12  | Aluminum oxide        | 15 mg/m3<br>5 mg/m3<br>(respirable) | 1 mg/m²<br>(respirable) |  |  |  |
| 7440-50-8       | 55-62   | Copper                | 1 mg/m3                             | 1 mg/m³ (dust)          |  |  |  |
| 1314-13-2       | 28-33   | Zinc oxide            | 15 mg/m3<br>5 mg/m3<br>(respirable) | 2 mg/m³<br>(respirable) |  |  |  |
|                 |   |                       | Ē                                   |                         |  |  |  |
|                 |   |                       |                                     |                         |  |  |  |
|                 |   |                       | <u> </u>                            |                         |  |  |  |



**UTC Power Shipping** 

09:56:44 a.m. 04-30-2009

2/7

## MATERIAL SAFETY DATA SHEET

PRODUCT NAME: Shift Max 230, Reduced Heterogeneous Catalyst, FC72372

## SECTION 3. EFFECTS OF OVEREXPOSURE

ACUTE EFFECTS:

EYE:

May cause Irritation

SKIN:

Frequent or prolonged contact may irritate the skin and cause a skin rash (dermatitis).

INHALATION:

Protonged or repeated inhalation may cause lung damage. Prolonged or excessive

inhalation may cause respiratory tract irritation.

ORAL:

Moderately toxic and may be harmful if swallowed; may damage the liver, pancreas,

kidney or nervous systems.

REPEATED EXPOSURE EFFECTS:

EYE:

Signs and symptoms of overexposure may include scratch or abrasion, damage to

cornea (necrosis).

SKIN:

Overexposure may cause skin rash, dermatitis and or itching.

INHALATION:

Overexposure may cause coughing, wheezing, shortness of breath, difficult breathing,

chest pain.

ORAL:

Ingestion may cause upset stomach and intestinal distress.

SECTION 3. EFFECTS OF OVEREXPOSURE

NOTE TO PHYSICIANS: N/D

THIS MATERIAL CONTAINS THE FOLLOWING COMPONENTS WITH THE SPECIAL HAZARDS LISTED BELOW.

**CARCINOGENS** 

N/A

**TERATOGENS** 

N/A

MUTAGENS

N/A

REPRODUCTIVE TOXINS

N/A

SENSITIZERS

N/A

COMMENTS:

None

NTP CLASSIFICATION:

N/A

IARC CLASSIFICATION:

N/A

OSHA CLASSIFICATION:

N/A



**UTC Power Shipping** 

09:57:03 a.m. 04-30-2009 3/7

## **MATERIAL SAFETY DATA SHEET**

PRODUCT NAME: Shift Max 230, Reduced Heterogeneous Catalyst, FC72372

**SECTION 4. FIRST AID MEASURES** 

EYE: Immediately flush eyes with plenty of water for at least 30 minutes. Get immediate medical

attention.

SKIN: Wash with plenty of soap and water. Get medical attention if irritation develops or persists.

INHALATION: Remove to fresh air. If breathing is difficult seek immediate medical attention.

If swallowed, do NOT induce vomiting. Give victim large quantities of water. Call a ORAL:

physician or polson control center immediately. Never give anything by mouth to an

unconscious person.

COMMENTS: Exposure to fumes of the metal oxides may cause metal fume fever including irritation of

eyes and respiratory tract and flu-like symptoms.

**SECTION 5. FIRE FIGHTING MEASURES** 

FLASH POINT (METHOD):

**AUTOIGNITION TEMPERATURE:** 

N/A

FLAMMABILITY LIMITS IN AIR: N/A

EXTINGUISHING MEDIA:

Protect exposures; cool with water fog. For small fires use Class D extinguishing

media.

UNSUITABLE EXTINGUISHING MEDIA:

FIRE FIGHTING PROCEDURES:

Wear full protective clothing and SCBA's.

UNUSUAL FIRE HAZARDS:

Packed material will spontaneously oxidize in air, producing significant heat. Keep away from combustible materials.

HAZARDOUS DECOMPOSITION PRODUCTS:

Toxic metal furnes may be emitted if thermally decomposed.

SECTION 6. ACCIDENTAL RELEASE MEASURES

CONTAINMENT / CLEAN UP:

Small spill

With shovel or scoop, place material onto clean, dry non-flammable surface to allow catalyst to oxidize. Place oxidized catalyst into container and cover loosely. Remove containers from spill

area. Protect against inhalation of dusts or furnes, Wear eye protection.

Large spill

Wet methods of cleanup are preferred. Keep airborne particulates to a minimum. Protect against inhalation of dusts or furnes, Wear eye protection. Place in appropriate containers for disposal.



**UTC Power Shipping** 

09:57:28 a.m. 04-30-2009

4/7

### MATERIAL SAFETY DATA SHEET

PRODUCT NAME: Shift Max 230, Reduced Heterogeneous Catalyst, FC72372

## SECTION 7. HANDLING AND STORAGE

HANDLING:

No special precautions for intact containers.

STORAGE:

Store in dry area. Prevent exposure to air by maintaining under an inert gas atmosphere such as nitrogen. Use additional precautions to prevent asphyxiant hazards due to inert

gas usage.

## SECTION 8. EXPOSURE CONTROLS / PERSONAL PROTECTION

#### ENGINEERING CONTROLS

LOCAL EXHAUST:

If user operations generate dust or furne, use ventilation to keep exposure to

airborne contaminates below the exposure limits.

GENERAL VENTILATION:

## PERSONAL PROTECTIVE EQUIPMENT FOR ROUTINE HANDLING

EYES: SKIN:

Wear safety glasses with side shields or goggles.

Wear protective clothing, including long sleeves and gloves to prevent skin contact.

SUITABLE GLOVES: Impermeable, such as latex, Nitrile, etc. INHALATION: Wear NIOSH approved respirator with particulate filter.

PERSONAL PROTECTIVE EQUIPMENT FOR SPILLS

EYES:

Chemical goggles

SKIN:

Chemical resistant gloves

INHALATION / SUITABLE RESPIRATOR: (Min) Use NIOSH-approved respirator with particulate filter

PRECAUTIONARY MEASURES: N/D



UTC Power Shipping

09: 57:46 a.m. 04-30-2009

5/7

#### MATERIAL SAFETY DATA SHEET

PRODUCT NAME: Shift Max 230, Reduced Heterogeneous Catalyst, FC72372

## SECTION 9. PHYSICAL AND CHEMICAL PROPERTIES

TYPICAL PHYSICAL PROPERTIES ARE GIVEN BELOW.

APPEARANCE: Cylindrical tablets

COLOR: Dark brown

ODOR: None

ODOR THRESHOLD: N/A

pH: N/A

BOILING POINT C (F): N/A MELTING POINT C (F): N/A

SOLUBILITY IN WATER: Insoluble

VISCOSITY AT\_\_\_: N/A

VISCOSITY AT\_\_\_:

RELATIVE DENSITY TO: 65-85 lb./CF (bulk)

POUR POINT C (F): N/A

FREEZING POINT C (F): N/A

VOLATILE ORGANIC COMPOUND: SPECIFIC GRAVITY: (H<sub>2</sub>O = 1) >8

VAPOR PRESSURE - mmHg: N/A

VAPOR DENSITY @ TEMP:\_\_\_\_: N/A

EVAPORATION RATE RELATIVE TO\_

**EXPLOSIVE PROPERTIES: Will not explode** OXIDIZING PROPERTIES: Not an oxidizer

## SECTION 10. STABILITY AND REACTIVITY

STABILITY (THERMAL, LIGHT, ETC.):

Generally considered stable when contained under an inert

atmosphere.

CONDITIONS TO AVOID:

Exposure to air.

INCOMPATIBILITY (MATERIALS TO AVOID):

Combustible materials.

HAZARDOUS DECOMPOSITION PRODUCTS:

Thermal decomposition may produce metal oxide fumes.

HAZARDOUS POLYMERIZATION:

Not expected to occur.



UTC Power Shipping

09:58:03 a.m. 04-30-2009

6/7

### MATERIAL SAFETY DATA SHEET

PRODUCT NAME: Shift Max 230, Reduced Heterogeneous Catalyst, FC72372

## SECTION 11. TOXICOLOGICAL DATA

Exposure to metal oxide fume may produce "metal fume fever" which is characterized by flu-like symptoms including fever, chills and general aches.

## SECTION 12. ECOLOGICAL INFORMATION

No data available.

## SECTION 13. DISPOSAL CONSIDERATIONS

Local regulations may vary, all waste must be disposed/recycled/reclaimed in accordance with federal, state and local environmental control regulations.

## SECTION 14. TRANSPORT INFORMATION

PROPER SHIPPING NAME: Self-heating solld, inorganic, N.O.S.

HAZARD TECHNICAL NAME: Reduced copper catalysts.

HAZARD CLASS: 4.2

UN NUMBER:

PACKING GROUP:

## SECTION 15. REGULATORY INFORMATION

TSCA STATUS: Component materials are in the TSCA inventory.

## EPA SARA TITLE III CHEMICAL LISTINGS:

SECTION 302 HAZARDOUS SUBSTANCES: No

SECTION 355 EXTREMELY HAZARDOUS SUBSTANCES:

S DOCUMENT OR FIPT FROM ANY JOOSAN FUEL CELL

No



**UTC Power Shipping** 

09:58:20 a.m. 04-30-2009

7 /7

## MATERIAL SAFETY DATA SHEET

PRODUCT NAME: Shift Max 230, Reduced Heterogeneous Catalyst, FC72372

## SECTION 15. REGULATORY INFORMATION, CONTINUED

SECTION 312 HAZARD CLASS:

ACUTE:

Yes

CHRONIC:

FIRE:

Yes No

PRESSURE: REACTIVE:

No

SECTION 372 TOXIC CHEMICALS: Copper.

## SECTION 16. OTHER INFORMATION

COMMENTS:

N/D = Not Determined

N/A = Not Applicable

As a unit, the materials do not pose a hazard. However, should the container be compromised and the packed catalyst become available, measures must be taken to prevent exposure to air.

PREPARED BY: D. Black, J. Preston

Revision By:

DATE:

4/23/2009

INFORMATION GIVEN HEREIN IS OFFERED IN GOOD FAITH AS ACCURATE, BUT WITHOUT GUARANTEE. CONDITIONS OF USE AND SUITABILITY OF THE PRODUCT FOR PARTICULAR USES ARE BEYOND OUR CONTROL; ALL RISKS OF USE OF THE PRODUCT ARE THEREFORE ASSUMED BY THE USER AND WE CONTROL; ALL RISKS OF USE OF THE PRODUCT ARE THEREFORE ASSUMED BY THE USER AND WE EXPRESSLY DISCLAIM ALL WARRANTIES OF EVERY KIND AND NATURE, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE IN RESPECT TO THE USE OR SUITABILITY OF THE PRODUCT. NOTHING IS INTENDED AS A RECOMMENDATION FOR USES WHICH INFRINGE VALID PATENTS OR AS EXTENDING LICENSE UNDER VALID PATENTS. APPROPRIATE WARNINGS AND SAFE UNDER VALID PATENTS. HANDLING PROCEDURES SHOULD BE PROVIDED TO HANDLERS AND USERS.