

Appendix A – Equipment Specifications, TCLP Report

100/125 kW, 1500 Vdc String Inverters for North America



CPS SCH100/125KTL-DO/US-600

The 100 and 125 kW high power CPS three-phase string inverters are designed for ground mount applications. The units are high performance, advanced and reliable inverters designed specifically for the North American environment and grid. High efficiency at 99.1% peak and 98.5% CEC, wide operating voltages, broad temperature ranges and a NEMA Type 4X enclosure enable this inverter platform to operate at high performance across many applications. The CPS 100/125 kW products ship with the Standard or Centralized Wire-box, each fully integrated and separable with AC and DC disconnect switches. The Standard Wire-box includes touch-safe fusing for up to 20 strings. The CPS FlexOM Gateway enables communication, controls and remote product upgrades.

Key Features

- NFPA 70 and NEC compliant
- Touch-safe DC Fuse holders add convenience and safety
- CPS FlexOM Gateway enables remote firmware upgrades
- Integrated AC and DC disconnect switches
- 1 MPPT with 20 fused inputs for maximum flexibility
- Copper- and Aluminum-compatible AC connections
- NEMA Type 4X outdoor rated enclosure
- Advanced Smart-Grid features (CA Rule 21 certified)
- kVA headroom yields 100 kW @ 0.9 PF and 125 kW @ 0.95 PF
- Generous 1.87 (100 kW) and 1.5 (125 kW) DC/AC inverter load ratios
- Separable wire-box design for fast service
- Standard 5-year warranty with extensions to 20 years



100/125KTL Standard Wire-box



100/125KTL Centralized Wire-box

Model Name	CPS SCH100KTL-DO/US-600	CPS SCH125KTL-DO/US-600
DC Input		
Max. PV power	187.5 kW	
Max. DC input voltage	1500 V	
Operating DC input voltage range	860-1450 Vdc	
Start-up DC input voltage / power	900 V / 250 W	
Number of MPP trackers	1	
MPPT voltage range ¹	870-1300 Vdc	
Max. PV input current (Isc x 1.25)	275 A	
Number of DC inputs	Standard Wire-box: 20 PV source circuits, pos. and neg. fused Centralized Wire-box: 1 input circuit, 1-2 terminations per pole, non-fused	
DC disconnection type	Load-rated DC switch	
DC surge protection	Type II MOV (with indicator/remote signaling)	
AC Output		
Rated AC output power	100 kW	125 kW
Max. AC output power ²	100 kVA (111 kVA @ PF>0.9)	125 kVA (132 kVA @ PF>0.95)
Rated output voltage	600 Vac	
Output voltage range ³	528-660 Vac	
Grid connection type ⁴	3Φ / PE / N (neutral optional)	
Max. AC output current @ 600 Vac	96.2 / 106.8 A	120.3 / 127.0 A
Rated output frequency	60 Hz	
Output frequency range ³	57-63 Hz	
Power factor	>0.99 (±0.8 adjustable)	>0.99 (±0.8 adjustable)
Current THD	<3%	
Max. fault current contribution (1-cycle RMS)	41.47 A	
Max. OCPD rating	200 A	
AC disconnection type	Load-rated AC switch	
AC surge protection	Type II MOV (with indicator/remote signaling)	
System		
Topology	Transformerless	
Max. efficiency	99.1%	
CEC efficiency	98.5%	
Stand-by / night consumption	<4 W	
Environment		
Enclosure protection degree	NEMA Type 4X	
Cooling method	Variable speed cooling fans	
Operating temperature range	-22°F to +140°F / -30°C to +60°C (derating from +108°F / +42°C)	
Non-operating temperature range ⁵	-40°F to +158°F / -40°C to +70°C maximum	
Operating humidity	0-100%	
Operating altitude	8202 ft / 2500 m (no derating)	
Audible noise	<65 dBA @ 1 m and 25°C	
Display and Communication		
User interface and display	LED indicators, WiFi + APP	
Inverter monitoring	Modbus RS485	
Site-level monitoring	CPS FlexOM Gateway (1 per 32 inverters)	
Modbus data mapping	SunSpec / CPS	
Remote diagnostics / firmware upgrade functions	Standard / (with FlexOM Gateway)	
Mechanical		
Dimensions (W x H x D)	Standard Wire-box: 45.28 x 24.25 x 9.84 in (1150 x 616 x 250 mm) Centralized Wire-box: 39.37 x 24.25 x 9.84 in (1000 x 616 x 250 mm)	
Weight	Inverter: 121 lbs (55 kg) Standard Wire-box: 55 lbs (25 kg) Centralized Wire-box: 33 lbs (15 kg)	
Mounting / installation angle	15 - 90 degrees from horizontal (vertical or angled)	
AC termination	M10 stud type terminal [3Φ] (wire range: 1/0 AWG - 500 kcmil CU/AL; lugs not supplied) Screw clamp terminal block [N] (#12 - 1/0 AWG CU/AL)	
DC termination	Standard Wire-box: Screw clamp fuse holder (wire range: #12 - #6 AWG CU) Centralized Wire-box: Busbar, M10 bolts (wire range: #1AWG - 500kcmil CU/AL [1 termination per pole], #1 AWG - 300 kcmil CU/AL [2 terminations per pole]; lugs not supplied)	
Fused string inputs	20 A fuses provided (fuse values up to 30 A acceptable)	
Safety		
Certifications and standards	UL 1741-SA/SB Ed. 3, CSA-C22.2 NO.107.1-01, IEEE 1547-2018, FCC PART15	
Selectable grid standard	IEEE 1547a-2014, IEEE 1547-2018 ⁶ , CA Rule 21, ISO-NE	
Smart-grid features	Volt-RideThru, Freq-RideThru, Ramp-Rate, Specified-PF, Volt-VAR, Freq-Watt, Volt-Watt	
Warranty		
Standard ⁷	5 years	
Extended terms	10, 15 and 20 years	

1) See user manual for further information regarding MPPT voltage range when operating at non-unity PF.

2) "Max AC apparent power" rating valid within MPPT voltage range and temperature range of -30°C to +40°C (-22°F to +104°F) for 100 kW PF≥0.9, and 125 kW PF≥0.95.

3) The "output voltage range" and "output frequency range" may differ according to the specific grid standard.

4) Wye neutral-grounded; delta may not be corner-grounded.

5) See user manual for further requirements regarding non-operating conditions.

6) Firmware version 12.0 or later required.

7) 5-year warranty effective for units purchased after October 1, 2019.



SWITCHGEAR



*Engineered Solutions for
Power Distribution*

Switchgear

In this brochure, we present a complete range of advanced, problem-solving switchgear products that have established Park as an industry leader in power distribution systems. Shown and described are medium voltage switchgear units for many diverse applications, all featuring the Park hallmarks of modern design and cutting-edge technology. With some of the industry's finest electrical engineers on staff, Park is ideally equipped to handle difficult custom jobs that many other companies may not have the capability to undertake.


Special projects are one of our particular strengths at Park, evidenced by our outstanding record for delivering these systems on tight schedules, and often under demanding circumstances.

Whatever your switchgear requirements, you can always rely on Park to provide you with the finest, state-of-the-art products and support services.



FEATURES & ADVANTAGES

- Interrupter switches are completely factory adjusted.
- No taping of bus connections
- Built-in access control eliminates expensive fencing
- Wide-view windows allow inspection of switches from outside
- Louvers and space heaters reduce moisture
- Spare fuses store in built-in racks
- Generous access and ample work space
- Hot dipped galvanized base
- Sturdy, lockable latches
- Welded construction for security and strength
- Heavy duty hinges
- Manufactured to applicable utility standards



Metal Enclosed

Metal Enclosed Load Interrupter Switchgear

Park Switchgear configurations are limited only by your imagination.

Each unit features welded steel construction with wideview windows that allow checking switchgear without opening doors. Corrosionproof, rainproof louvers at the bottom and top, and space heaters inside each unit maintain air circulation to keep the interior dry. Three point cam-type, high-strength latches seal the doors shut. The lockable latches and screened louvers discourage tampering. Wide bulkhead doors provide easy access to all bays. Each full-length door has durable heavy-duty hinges with brass pivots. Foot operated holders lock the doors open, providing ample room for pulling cables and making terminations.

All interrupter switches are maintenance-free and are available in 200, 600, and 1200 amp ratings. S&C® Power Fuses provide full-fault-spectrum protection. The switches are manually operated by nonremovable switch handles. Bus connections are silverplated copper for long life. Continuous ground bus in multibay lineups has a short-circuit rating equal to that of the integrated assembly. The HV meter bays are built to utility specifications and multibay lineups are assembled with a minimum of interbay bolting.

Call today and discuss your requirements with a Park sales representative.

UL[®] Listed up to 15KV

SPECIFICATIONS

Ratings of S&C Mini-Ruptor Switches


KV			Amperes, RMS				
Nom.	Max. Des.	BIL	Cont.	Interrupting			Mom. S Peak Close (ASYM KA)
				Load	Cap.	Mag.	
5	5.5	60	600	600	35	21	40
5	5.5	60	1200	1200	35	21	61
15	17	95	600	600	35	21	40
15	17	95	1200	1200	35	21	61
25	29	125	600	400	35	21	40
34.5	38	150	600	600	35	21	28

Physical Sizes & Park Numbers

Park No.	Voltage KV	Height	Depth	Width
PM 315-4.8	4.8	104"	44"	42"
PM 315-15	15	104"	44"	42"
PM 315-25	25	120"	44"	42"
PM 315-35	34.5	130"	70"	60"
PM 315-CT	PT/CT Bay	to match	to match	to match
PM 315-WM	Meter Bay	to match	to match	60"

To order specify current rating & fuse size.


Cabling Locations
Width



Switchgear

FEATURES & ADVANTAGES

- Interrupter switches are completely factory adjusted
- Built-in access control eliminates expensive fencing
- Standard drilling and tapping for mounting various size and manufacturers' current and potential transformers
- No taping of bus connections
- Front operator standard
- Side operator available as an option
- Louvers and space heaters reduce moisture
- Spare fuses store in built in racks
- Sturdy 3 point door latch
- Heavy duty hinges
- Sturdy, lockable latches
- Welded construction for security and strength
- Hot dipped galvanized base
- Manufactured to applicable utility standards
- Finished with one prime and two enamel coats for corrosion resistance



PM 123

Pad-mounted 15KV Primary Switch and Metering Cubicle

Each unit features welded steel construction. Corrosionproof, rainproof louvers at the bottom and top, and space heaters inside each unit maintain air circulation to keep the interior dry. Three point cam-type, high-strength latches seal the doors shut. The lockable latches and screened louvers discourage tampering. Wide bulkhead doors provide easy access. Each full-length door has durable heavy-duty hinges with brass pivots. Foot operated holders lock the doors open and provides ample room for pulling cables and making terminations.

Interruptor switches are maintenance-free and are 600 amp rated. S&C® Power Fuses provide full-fault-spectrum protection. The switches are manually operated by removable switch handles. Bus connections are silverplated copper for long life. The HV meter bays are built to utility specifications.

Call today and discuss your requirements with a Park sales representative.

UL® Listed up to 15KV

SPECIFICATIONS

Ratings of S&C Mini-Ruptor Switches


KV			Amperes, RMS				
Nom.	Max. Des.	BIL	Interrupting				Mom. & Fault Close (ASYM ICA)
			Cont.	Load	Cap.	Mag.	
15	17	96	600	600	35	21	40
25	29	125	600	400	35	21	40

Physical Sizes & Park Numbers

Park No.	Voltage KV	Height	Depth	Width	A	B
PM 123-4.8	4.8	82"	60"	40"	19"	12"
PM 123-15	15	82"	60"	40"	19"	12"
PM 123-25	25	94"	60"	54"	19"	14"

To order specify current rating & knee size.

Cabling Locations



A,B,C.- Approximate Cable Termination Points

X - Approximate Heating Cable Termination

NOTE: Front and rear clearance of 4' required—2' on right for handle operations



Switchgear

FEATURES & ADVANTAGES

- Welded steel construction for security and strength.
- Various combinations of switch and fuse arrangements available.
- Interrupter switches are factory adjusted.
- Built-in access control eliminates expensive fencing.
- No taping of bus connections.
- Folding switch handle stores in padlockable compartment on enclosure side.
- Sturdy 3 point lockable door latches.
- Heavy duty hinges.
- Louvers help reduce moisture.
- Manufactured to applicable utility standards.
- Hot dipped galvanized base.
- Finished with one prime and two enamel coats for corrosion resistance.



PM-255



PM-155

PM 155 & 255

Pad-mounted 15 & 25KV Switch & Fuse

All 155 and 255 units feature welded steel construction. Louvers at the top and bottom of each unit are rainproof and corrosion proof, maintain air circulation to keep interior dry. Three point cam-type, high-strength latches seal the doors shut. Lockable latches and screened louvers discourage tampering. Wide bulkhead doors provide easy access. Each full-length door has durable heavy-duty hinges with brass pivots. Foot operated holders lock the doors open, and

provide ample room for pulling cables and making terminations.


Interruptor switches are maintenance-free and rated at 600 amp. S&C® Power Fuses provide full-fault-spectrum protection. Switches are manually operated by removable switch handles. Bus connections are silverplated copper for long life.

Call today and discuss your requirements with a Park sales representative.


SPECIFICATIONS

Park #	Volts	Height*	Width	Depth
155	15 kv	60	36	52
155	25 kv	65	40	62
255	15 kv	60	72	62
255	25 kv	65	82	72

*Height includes 10" base.




PM 255



PM-155 front view ▲

rear view ▲

PM 255 Side View





POWER DISTRIBUTION SYSTEMS

RELIABLE POWER DISTRIBUTION SYSTEMS FOR EVERY REQUIREMENT

- Busway
- Switchgear
- Switchboards
- Panelboards
- Transformer Enclosures
- Multiple Service Cabinets
- Standard & Custom Enclosures
- Control Panels

WWW.PARKDETROIT.COM
EMAIL: INFO@PARKDETROIT.COM
1-800-796-PARK



THREE PHASE PADMOUNT TRANSFORMERS

Short for "Tamper-proof, compartmentalized, liquid-filled, pad mounted transformer", all padmount designs feature fully enclosed tamper-proof terminal compartments and can be supplied with dead-front or live-front configuration, for loop or radial feed applications, with Type II mineral oil, or environmentally friendly and high flash-point Envirotemp™ FR3™.

All new Maddox padmount transformers are constructed of the highest quality materials and built in the US to heavy duty industrial standards, making them ideal for commercial and industrial applications such as data centers, solar step-up, manufacturing facilities, shopping centers, etc. Our padmounts are designed to the latest department of energy efficiency standards built and tested in accordance with industry standards including NEMA, ANSI C.57, DOE, and IEEE as applicable.

With thousands of new units in stock and ready-to-ship, and the manufacturing ability to produce almost any custom design, Maddox stands ready to meet your transformer need(s). Maddox stocks all standard configurations to match most common applications and deliver on short notice.

Design

HV Bushing Config.:

- Dead front or live front
- Loop feed or radial feed

Fluid Options:

- Type II Mineral Oil
- Envirotemp™ FR3™

Standard Gauge/Accessory Package:

- Pressure relief valve
- Pressure vacuum gauge
- Liquid temp & level gauges
- Drain & sample valve
- Adjustment taps

Switch Options:

- 2 Position LBOR Switch
- 4 Position LBOR Switch (V-blade or T-blade)
- (3) 2 Position LBOR Switches

Fusing Options:

- Bayonets w/ isolation links or CLFs

Construction:

- 5-legged core
- Rectangular wound copper or aluminum windings
- Carbon reinforced or stainless steel tank
- Steel divider between HV and LV cabinets
- Penta-head captive bolt

Optional Design Features & Accessories:

- Gauges w/ Contacts
- External drain and sample valve
- Electrostatic Shielding
- Step-up Design
- Surge-Arresters

Available Ratings

Table 1. Typical Transformer Ratings

Sizes (kVA)	45, 75, 112.5, 150, 225, 300, 500, 750, 1000, 1500, 2000, 2500, 3000, 3750, 5000
Frequency	60 Hz or 50 Hz
Cooling Class	ONAN or KNAN
Temp Rise	55°C, 65°C, 55/65°C, 75°C
Voltages	Available in Δ or Y configuration
600V	208
	240
	416
	480
	600
2.5kv – 5kv	2400
	4160
	4800
15kV	12000
	12470
	13200
	13800
	14400
25kV	20780
	21600
	22900
	24940
35kV	26400
	33000
	34500

Fig 1. Padmount Transformer Outline




Table 2. Approximate Transformer Dimensions

kVA	A	B	C	D	E	F	G	Gallons	Weight (Lbs)
300	59"	29.5"	22"	51.5"	20.5"	24"	10"	196	4,056
500	59"	33"	26.5"	59.5"	24"	26.5"	10"	210	5,023
750	73"	36"	29"	65"	24"	26.5"	10"	358	7,664
1000	73"	36"	29"	65"	24"	27"	10"	354	8,530
1500	73"	36"	35.5"	71.5"	24"	33.5"	10"	410	10,782
2000	75"	39.5"	28"	67.5"	24"	35"	27"	433	12,490
2500	78"	39.5"	35.5"	75.5"	24"	37.5"	22.5"	545	14,246
3000	84"	30.5"	32"	62.5"	24"	37.5"	38"	550	14,014
3750	75"	50.5"	30"	80.5"	25.5"	42"	38"	730	17,785

Fig 2. Three Phase Maddox Padmount Transformer



Table 3. Common Accessories



1. Bayonet Fuses



2. Loadbreak Switch




3. Tap-changer



4. Bushings



5. Parking Stand




6: Gauges



Series 6 *Plus* Bifacial.

455-480 Watt Thin Film Solar Module

First Solar is once again setting the industry benchmark for reliable energy production, optimized design and environmental performance with Series 6 *Plus* Bifacial - the world's first bifacial thin film CdTe module. The advanced design significantly reduces balance of system, shipping, and operating costs while delivering more energy per nameplate watt.



More Lifetime Energy per Nameplate Watt

- Industry's best (0.3%) warranted degradation rate
- Superior temperature coefficient, spectral response and shading behavior
- Unlike crystalline silicon modules, First Solar's thin film technology does not experience losses from LID or LeTID
- Anti-reflective coated glass enhances energy production
- Added bifacial energy yield



Innovative Module Design

- Under-mount frame provides the cleaning and snowshedding benefits of a frameless module while protecting edges against breakage
- Innovative SpeedSlots combine the robustness of bottom mounting with the speed of top clamping while utilizing fewer fasteners to achieve the industry's fastest installation times and lowest mounting hardware costs
- Dual junction box design reduces wire management complexity and cost



Best In-Class Reliability & Durability

- Manufactured under one roof with 100% traceable QA/QC
- Independently tested and certified for reliable performance that exceeds IEC standards in high temperature, high humidity, extreme desert and coastal applications
- Inherently immune to and warranted against power loss from cell cracking
- Durable glass/glass construction



Best Environmental Profile

- Fastest energy payback time in the industry
- Carbon footprint that is 2.5X lower and a water footprint that is 3X lower than mono crystalline silicon panels on a life cycle basis
- Global PV module recycling services available through First Solar or customer-selected third-party

19.0%
HIGH BIN EFFICIENCY


30YR
LINEAR PERFORMANCE
WARRANTY

98%
WARRANTY START POINT

0.3%
WARRANTED ANNUAL
DEGRADATION RATE¹



Learn more about First Solar
and Series 6 *Plus* Bifacial
at firstsolar.com/S6



Series 6 *Plus* Bifacial.



Electrical Specifications

RATINGS AT STANDARD TEST CONDITIONS (1000W/m², AM 1.5, 25°C)²

SERIES 6 PLUS BIFACIAL MODEL TYPES: FS-6XXX-P-B / FS-6XXXX-P-B (XXX = NOMINAL POWER)

Nominal Power ³ (-0/+5%)	P _{MAX} (W)	455		460		465		470		475		480	
		STC ⁴	BNPI ⁵	STC	BNPI	STC	BNPI	STC	BNPI	STC	BNPI	STC	BNPI
Nominal Power	P _{MAX} (W)	455	464	460	469	465	474	470	479	475	485	480	490
Voltage at P _{MAX}	V _{MAX} (V)	187.8	187.8	188.8	188.8	189.8	189.8	191.1	191.1	191.5	191.5	192.8	192.8
Current at P _{MAX}	I _{MAX} (A)	2.42	2.47	2.44	2.49	2.45	2.50	2.46	2.50	2.48	2.53	2.49	2.54
Open Circuit Voltage	V _{OC} (V)	222.0	222.0	222.9	222.9	223.8	223.8	224.3	224.3	224.8	224.8	225.4	225.4
Short Circuit Current	I _{SC} (A)	2.58	2.63	2.59	2.64	2.60	2.65	2.61	2.66	2.61	2.66	2.62	2.67
Efficiency (%)	%	18.1		18.3		18.5		18.7		18.9		19.0	
Maximum System Voltage	V _{SYS} (V)	1500 ⁶											
Limiting Reverse Current	I _R (A)	5.0											
Maximum Series Fuse	I _{CF} (A)	5.0											

TEMPERATURE CHARACTERISTICS

Module Operating Temperature Range	°C	-40 to +85
Temperature Coefficient of P _{MAX}	T _K (P _{MAX})	-0.32%/°C [Temperature Range: 25°C to 75°C]
Temperature Coefficient of V _{OC}	T _K (V _{OC})	-0.28%/°C
Temperature Coefficient of I _{SC}	T _K (I _{SC})	+0.04%/°C
Nominal Operating Cell Temperature	°C	43
Bifaciality Factor	%	15±5


PACKAGING INFORMATION

Model Type	Modules Per Pack	Packs per 40' Container
FS-6XXX-P-B / FS-6XXXX-P-B	27	18

MECHANICAL DESCRIPTION

Module/Glass Length	2024mm/2016mm
Module/Glass Width	1245mm/1216mm
Module/Glass Area	2.52m ² /2.45m ²
Module Weight	34.0kg
Leadwire ⁷	2.5mm ² , 733mm (+) & Bulkhead (-)
Connectors	TE Connectivity PV4-S, or alternate
Junction Box	IP68 Rated
Bypass Diode	N/A
Cell Type	Thin film CdTe semiconductor, up to 268 cells
Frame Material	Anodized Aluminum
Front Glass	Heat strengthened
Back Glass	Heat strengthened
Encapsulation	Laminate material with edge seal
Frame to Glass Adhesive	Silicone
Load Rating ⁸	+/-2400Pa

Mechanical Specifications



Install in portrait only

Certifications & Tests⁹

CERTIFICATIONS AND LISTINGS

IEC 61215:2021 & 61730-1:2016⁶, CE
IEC 61701 Salt Mist Corrosion
IEC 60068-2-68 Dust and Sand Resistance
UL 61730

EXTENDED DURABILITY TESTS

IEC TS 63209-1 Extended Stress Test
Long-Term Sequential
Thresher Test
PID Resistant

QUALITY & EHS

ISO 9001:2015
ISO 14001:2015
ISO 45001:2018
ISO 14064-3:2006
EPEAT Silver Registered

Disclaimer

All images shown are provided for illustrative purposes only and may not be an exact representation of the product. First Solar, Inc. reserves the right to change product images at any time without notice.

The information included in this Module Datasheet is subject to change without notice and is provided for informational purposes only. No contractual rights are established or should be inferred because of user's reliance on the information contained in this Module Datasheet. Please refer to the appropriate Module User Guide and Module Product Specification document for more detailed technical information regarding module performance, installation and use.

First Solar, the First Solar logo, and Series 6 are trademarks of First Solar, Inc., registered in the U.S. and other countries. Series 6 *Plus*, Series 6 *Plus* Bifacial and SpeedSlots are trademarks of First Solar, Inc.

©2023



- Limited power output and product warranties subject to warranty terms and conditions
- All ratings ±10%, unless specified otherwise. Specifications are subject to change
- Measurement uncertainty applies
- Frontside electrical ratings
- Bifacial Name Plate Irradiance, as per IEC 61215:2021
- IEC 61730-1: 2016 Class II
- Leadwire length from junction box exit to connector mating surface
- 1500Pa tentative load rating for 1956mm mounting slots. Higher loads may be acceptable, subject to testing
- Testing Certifications/Listings pending



Series 6 Plus TCLP Report

March 21, 2022

1 INTRODUCTION

The purpose of this report is to provide waste characterization of First Solar Series 6 Plus photovoltaic (PV) modules using USEPA Method 1311 Toxicity Characteristic Leaching Procedure (TCLP).

2 METHODS

In February, 2022, First Solar provided three Series 6 Plus modules to Eurofins Calscience laboratory for TCLP testing.

3 RESULTS

TCLP test results are documented in the enclosed laboratory test report and are below the hazardous waste thresholds in Table 1 of 40 CFR 261.24¹.

¹ <https://www.ecfr.gov/current/title-40/chapter-I/subchapter-I/part-261/subpart-C/section-261.24>

ANALYTICAL REPORT

Eurofins Calscience
2841 Dow Avenue, Suite 100
Tustin, CA 92780
Tel: (714)895-5494

Laboratory Job ID: 570-85215-1

Client Project/Site: Photovoltaic (PV) Modules - TCLP Metals

For:

First Solar, Inc
28101 Cedar Park Blvd
Perrysburg, Ohio 43551

Attn: Adam Squire



Authorized for release by:
3/17/2022 2:23:03 PM

Rossina Tomova, Project Manager I
(657)210-6367
Rossina.Tomova@Eurofinset.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Table of Contents

Cover Page	1
Table of Contents	2
Definitions/Glossary	3
Case Narrative	4
Detection Summary	5
Client Sample Results	6
QC Sample Results	9
QC Association Summary	11
Lab Chronicle	13
Certification Summary	14
Method Summary	15
Sample Summary	16
Chain of Custody	17
Receipt Checklists	18



Definitions/Glossary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Qualifiers

Metals

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Job ID: 570-85215-1

Laboratory: Eurofins Calscience

Narrative

Job Narrative 570-85215-1

Comments

No additional comments.

Receipt

The samples were received on 2/17/2022 1:30 PM. Unless otherwise noted below, the samples arrived in good condition. The temperature of the cooler at receipt was 23.0° C.

Receipt Exceptions

The samples were received at the laboratory outside the required temperature criteria for Mercury. There was no cooling media present in the cooler.

Metals

Method 6010B: The matrix spike / matrix spike duplicate (MS/MSD) recoveries of Barium for preparation batch 440-667641 and 440-667772 and analytical batch 440-667873 were outside control limits. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample (LCS) recovery was within acceptance limits.(440-294036-A-22-F MSD)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

Organic Prep

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Detection Summary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Client Sample ID: OD0-0026-01

Lab Sample ID: 570-85215-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Barium	0.24		0.10		mg/L	1		6010B	TCLP
Cadmium	0.085		0.050		mg/L	1		6010B	TCLP

Client Sample ID: OD0-0026-02

Lab Sample ID: 570-85215-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Barium	0.19		0.10		mg/L	1		6010B	TCLP

Client Sample ID: OD0-0026-03

Lab Sample ID: 570-85215-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Barium	0.14		0.10		mg/L	1		6010B	TCLP

This Detection Summary does not include radiochemical test results.

Eurofins Calscience

Client Sample Results

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Client Sample ID: OD0-0026-01

Lab Sample ID: 570-85215-1

Date Collected: 02/09/22 15:00

Matrix: Solid

Date Received: 02/17/22 13:30

Method: 6010B - Metals (ICP) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:36	1
Barium	0.24		0.10		mg/L		02/23/22 17:20	02/24/22 19:36	1
Cadmium	0.085		0.050		mg/L		02/23/22 17:20	02/24/22 19:36	1
Chromium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:36	1
Lead	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:36	1
Selenium	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:36	1
Silver	ND		0.10		mg/L		02/23/22 17:20	02/24/22 19:36	1

Method: 7470A - Mercury (CVAA) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.0025		mg/L		03/15/22 19:30	03/16/22 13:38	1

Client Sample Results

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Client Sample ID: OD0-0026-02

Lab Sample ID: 570-85215-2

Date Collected: 02/09/22 15:00

Matrix: Solid

Date Received: 02/17/22 13:30

Method: 6010B - Metals (ICP) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:39	1
Barium	0.19		0.10		mg/L		02/23/22 17:20	02/24/22 19:39	1
Cadmium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:39	1
Chromium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:39	1
Lead	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:39	1
Selenium	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:39	1
Silver	ND		0.10		mg/L		02/23/22 17:20	02/24/22 19:39	1

Method: 7470A - Mercury (CVAA) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.0025		mg/L		03/15/22 19:30	03/16/22 13:43	1

Client Sample Results

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Client Sample ID: OD0-0026-03

Lab Sample ID: 570-85215-3

Date Collected: 02/09/22 15:00

Matrix: Solid

Date Received: 02/17/22 13:30

Method: 6010B - Metals (ICP) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:34	1
Barium	0.14		0.10		mg/L		02/23/22 17:20	02/24/22 19:34	1
Cadmium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:34	1
Chromium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:34	1
Lead	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:34	1
Selenium	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:34	1
Silver	ND		0.10		mg/L		02/23/22 17:20	02/24/22 19:34	1

Method: 7470A - Mercury (CVAA) - TCLP

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.0025		mg/L		03/15/22 19:30	03/16/22 13:45	1

QC Sample Results

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Method: 6010B - Metals (ICP)

Lab Sample ID: MB 440-667641/1-B

Matrix: Solid

Analysis Batch: 667873

Client Sample ID: Method Blank

Prep Type: TCLP

Prep Batch: 667772

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Arsenic	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:05	1
Barium	ND		0.10		mg/L		02/23/22 17:20	02/24/22 19:05	1
Cadmium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:05	1
Chromium	ND		0.050		mg/L		02/23/22 17:20	02/24/22 19:05	1
Lead	0.0710		0.050		mg/L		02/23/22 17:20	02/24/22 19:05	1
Selenium	ND		0.20		mg/L		02/23/22 17:20	02/24/22 19:05	1
Silver	ND		0.10		mg/L		02/23/22 17:20	02/24/22 19:05	1

Lab Sample ID: LCS 440-667641/2-B

Matrix: Solid

Analysis Batch: 667873

Client Sample ID: Lab Control Sample

Prep Type: TCLP

Prep Batch: 667772

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Arsenic	2.00	2.12		mg/L		106	80 - 120
Barium	2.00	2.12		mg/L		106	80 - 120
Cadmium	2.00	2.03		mg/L		101	80 - 120
Chromium	2.00	2.16		mg/L		108	80 - 120
Lead	2.00	2.09		mg/L		104	80 - 120
Selenium	2.00	1.89		mg/L		95	80 - 120
Silver	1.00	1.06		mg/L		106	80 - 120

Lab Sample ID: 440-294036-A-22-E MS

Matrix: Solid

Analysis Batch: 667873

Client Sample ID: Matrix Spike

Prep Type: TCLP

Prep Batch: 667772

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Arsenic	ND		2.00	2.19		mg/L		103	75 - 125
Barium	5.4	F1	2.00	7.85		mg/L		121	75 - 125
Cadmium	0.055		2.00	2.09		mg/L		102	75 - 125
Chromium	0.36		2.00	2.53		mg/L		109	75 - 125
Lead	2.1	B	2.00	4.19		mg/L		104	75 - 125
Selenium	ND		2.00	1.85		mg/L		93	75 - 125
Silver	ND		1.00	1.04		mg/L		104	75 - 125

Lab Sample ID: 440-294036-A-22-F MSD

Matrix: Solid

Analysis Batch: 667873

Client Sample ID: Matrix Spike Duplicate

Prep Type: TCLP

Prep Batch: 667772

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Arsenic	ND		2.00	2.21		mg/L		103	75 - 125	1	20
Barium	5.4	F1	2.00	8.23	F1	mg/L		140	75 - 125	5	20
Cadmium	0.055		2.00	2.08		mg/L		101	75 - 125	1	20
Chromium	0.36		2.00	2.58		mg/L		111	75 - 125	2	20
Lead	2.1	B	2.00	4.36		mg/L		113	75 - 125	4	20
Selenium	ND		2.00	1.91		mg/L		95	75 - 125	3	20
Silver	ND		1.00	1.05		mg/L		105	75 - 125	1	20

Eurofins Calscience

QC Sample Results

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Method: 7470A - Mercury (CVAA)

Lab Sample ID: MB 570-219655/1-B

Matrix: Solid

Analysis Batch: 220034

Client Sample ID: Method Blank

Prep Type: TCLP

Prep Batch: 219783

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.0025		mg/L		03/15/22 19:30	03/16/22 13:32	1

Lab Sample ID: LCS 570-219655/2-B

Matrix: Solid

Analysis Batch: 220034

Client Sample ID: Lab Control Sample

Prep Type: TCLP

Prep Batch: 219783

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Mercury	0.0500	0.0529		mg/L		106	80 - 120

Lab Sample ID: LCSD 570-219655/6-B

Matrix: Solid

Analysis Batch: 220034

Client Sample ID: Lab Control Sample Dup

Prep Type: TCLP

Prep Batch: 219783

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Mercury	0.0500	0.0530		mg/L		106	80 - 120	0	20

Lab Sample ID: 570-85215-1 MS

Matrix: Solid

Analysis Batch: 220034

Client Sample ID: OD0-0026-01

Prep Type: TCLP

Prep Batch: 219783

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec. Limits
Mercury	ND		0.0500	0.0503		mg/L		101	55 - 133

Lab Sample ID: 570-85215-1 MSD

Matrix: Solid

Analysis Batch: 220034

Client Sample ID: OD0-0026-01

Prep Type: TCLP

Prep Batch: 219783

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	Limit
Mercury	ND		0.0500	0.0504		mg/L		101	55 - 133	0	20

QC Association Summary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Metals

Leach Batch: 219655

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-85215-1	OD0-0026-01	TCLP	Solid	1311	
570-85215-2	OD0-0026-02	TCLP	Solid	1311	
570-85215-3	OD0-0026-03	TCLP	Solid	1311	
MB 570-219655/1-B	Method Blank	TCLP	Solid	1311	
LCS 570-219655/2-B	Lab Control Sample	TCLP	Solid	1311	
LCSD 570-219655/6-B	Lab Control Sample Dup	TCLP	Solid	1311	
570-85215-1 MS	OD0-0026-01	TCLP	Solid	1311	
570-85215-1 MSD	OD0-0026-01	TCLP	Solid	1311	

Prep Batch: 219783

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-85215-1	OD0-0026-01	TCLP	Solid	7470A	219655
570-85215-2	OD0-0026-02	TCLP	Solid	7470A	219655
570-85215-3	OD0-0026-03	TCLP	Solid	7470A	219655
MB 570-219655/1-B	Method Blank	TCLP	Solid	7470A	219655
LCS 570-219655/2-B	Lab Control Sample	TCLP	Solid	7470A	219655
LCSD 570-219655/6-B	Lab Control Sample Dup	TCLP	Solid	7470A	219655
570-85215-1 MS	OD0-0026-01	TCLP	Solid	7470A	219655
570-85215-1 MSD	OD0-0026-01	TCLP	Solid	7470A	219655

Analysis Batch: 220034

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-85215-1	OD0-0026-01	TCLP	Solid	7470A	219783
570-85215-2	OD0-0026-02	TCLP	Solid	7470A	219783
570-85215-3	OD0-0026-03	TCLP	Solid	7470A	219783
MB 570-219655/1-B	Method Blank	TCLP	Solid	7470A	219783
LCS 570-219655/2-B	Lab Control Sample	TCLP	Solid	7470A	219783
LCSD 570-219655/6-B	Lab Control Sample Dup	TCLP	Solid	7470A	219783
570-85215-1 MS	OD0-0026-01	TCLP	Solid	7470A	219783
570-85215-1 MSD	OD0-0026-01	TCLP	Solid	7470A	219783

Leach Batch: 667641

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-85215-1	OD0-0026-01	TCLP	Solid	1311	
570-85215-2	OD0-0026-02	TCLP	Solid	1311	
570-85215-3	OD0-0026-03	TCLP	Solid	1311	
MB 440-667641/1-B	Method Blank	TCLP	Solid	1311	
LCS 440-667641/2-B	Lab Control Sample	TCLP	Solid	1311	
440-294036-A-22-E MS	Matrix Spike	TCLP	Solid	1311	
440-294036-A-22-F MSD	Matrix Spike Duplicate	TCLP	Solid	1311	

Prep Batch: 667772

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-85215-1	OD0-0026-01	TCLP	Solid	3010A	667641
570-85215-2	OD0-0026-02	TCLP	Solid	3010A	667641
570-85215-3	OD0-0026-03	TCLP	Solid	3010A	667641
MB 440-667641/1-B	Method Blank	TCLP	Solid	3010A	667641
LCS 440-667641/2-B	Lab Control Sample	TCLP	Solid	3010A	667641
440-294036-A-22-E MS	Matrix Spike	TCLP	Solid	3010A	667641
440-294036-A-22-F MSD	Matrix Spike Duplicate	TCLP	Solid	3010A	667641

Eurofins Calscience

QC Association Summary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Metals

Analysis Batch: 667873

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-85215-1	OD0-0026-01	TCLP	Solid	6010B	667772
570-85215-2	OD0-0026-02	TCLP	Solid	6010B	667772
570-85215-3	OD0-0026-03	TCLP	Solid	6010B	667772
MB 440-667641/1-B	Method Blank	TCLP	Solid	6010B	667772
LCS 440-667641/2-B	Lab Control Sample	TCLP	Solid	6010B	667772
440-294036-A-22-E MS	Matrix Spike	TCLP	Solid	6010B	667772
440-294036-A-22-F MSD	Matrix Spike Duplicate	TCLP	Solid	6010B	667772

Lab Chronicle

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Client Sample ID: OD0-0026-01

Lab Sample ID: 570-85215-1

Date Collected: 02/09/22 15:00

Matrix: Solid

Date Received: 02/17/22 13:30

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			100.20 g	2000 mL	667641	02/22/22 20:17		IRV 2
TCLP	Prep	3010A			5 mL	50 mL	667772	02/23/22 17:20		IRV 2
TCLP	Analysis	6010B		1			667873	02/24/22 19:36	P1R	IRV 2
Instrument ID: ICP8										
TCLP	Leach	1311			100.20 g	2000 mL	219655	02/22/22 20:17		ECL 3
TCLP	Prep	7470A			10 mL	100 mL	219783	03/15/22 19:30	VWJ7	ECL 4
TCLP	Analysis	7470A		1			220034	03/16/22 13:38	VWJ7	ECL 4
Instrument ID: HG7										

Client Sample ID: OD0-0026-02

Lab Sample ID: 570-85215-2

Date Collected: 02/09/22 15:00

Matrix: Solid

Date Received: 02/17/22 13:30

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			101.30 g	2000 mL	667641	02/22/22 20:17		IRV 2
TCLP	Prep	3010A			5 mL	50 mL	667772	02/23/22 17:20		IRV 2
TCLP	Analysis	6010B		1			667873	02/24/22 19:39	P1R	IRV 2
Instrument ID: ICP8										
TCLP	Leach	1311			101.30 g	2000 mL	219655	02/22/22 20:17		ECL 3
TCLP	Prep	7470A			10 mL	100 mL	219783	03/15/22 19:30	VWJ7	ECL 4
TCLP	Analysis	7470A		1			220034	03/16/22 13:43	VWJ7	ECL 4
Instrument ID: HG7										

Client Sample ID: OD0-0026-03

Lab Sample ID: 570-85215-3

Date Collected: 02/09/22 15:00

Matrix: Solid

Date Received: 02/17/22 13:30

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
TCLP	Leach	1311			100.42 g	2000 mL	667641	02/22/22 20:17		IRV 2
TCLP	Prep	3010A			5 mL	50 mL	667772	02/23/22 17:20		IRV 2
TCLP	Analysis	6010B		1			667873	02/24/22 19:34	P1R	IRV 2
Instrument ID: ICP8										
TCLP	Leach	1311			100.42 g	2000 mL	219655	02/22/22 20:17		ECL 3
TCLP	Prep	7470A			10 mL	100 mL	219783	03/15/22 19:30	VWJ7	ECL 4
TCLP	Analysis	7470A		1			220034	03/16/22 13:45	VWJ7	ECL 4
Instrument ID: HG7										

Laboratory References:

ECL 3 = Eurofins Calscience Knott, 11380 Knott Street, Garden Grove, CA 92841, TEL (714)895-5494

ECL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

IRV 2 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Eurofins Calscience

Accreditation/Certification Summary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	Los Angeles County Sanitation Districts	10109	09-30-22
California	SCAQMD LAP	17LA0919	11-30-21 *
California	State	2944	09-30-22
Guam	State	21-003R	06-22-22
Nevada	State	CA00111	07-31-22
Oregon	NELAP	CA300001	01-31-23
USDA	US Federal Programs	P330-20-00034	02-10-23
Washington	State	C916-18	10-12-22

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	Los Angeles County Sanitation Districts	10256	06-30-22
California	State	2706	06-30-22
Kansas	NELAP	E-10420	07-31-22
Nevada	State	CA015312022-1	07-31-22
Washington	State	C900	09-03-22

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Calscience

Method Summary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Method	Method Description	Protocol	Laboratory
6010B	Metals (ICP)	SW846	IRV 2
7470A	Mercury (CVAA)	SW846	ECL 4
1311	TCLP Extraction	SW846	ECL 3
1311	TCLP Extraction	SW846	IRV 2
3010A	Preparation, Total Metals	SW846	IRV 2
7470A	Preparation, Mercury	SW846	ECL 4

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

ECL 3 = Eurofins Calscience Knott, 11380 Knott Street, Garden Grove, CA 92841, TEL (714)895-5494

ECL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

IRV 2 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: First Solar, Inc
Project/Site: Photovoltaic (PV) Modules - TCLP Metals

Job ID: 570-85215-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
570-85215-1	OD0-0026-01	Solid	02/09/22 15:00	02/17/22 13:30
570-85215-2	OD0-0026-02	Solid	02/09/22 15:00	02/17/22 13:30
570-85215-3	OD0-0026-03	Solid	02/09/22 15:00	02/17/22 13:30

Login Sample Receipt Checklist

Client: First Solar, Inc

Job Number: 570-85215-1

Login Number: 85215

List Number: 1

Creator: Cruise, Noel

List Source: Eurofins Calscience

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	Out of temperature for Mercury
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	False	Requested analyses are not listed on COC
Is the Field Sampler's name present on COC?	False	Refer to Job Narrative for details.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is $<6\text{mm}$ (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	