



## ISSUED FOR INTERCONNECTION APPROVAL NOT FOR CONSTRUCTION

## **GENERAL NOTES**

## DATA

- AC PEAK OUTPUT AT POI 15.0 MWAC
- INVERTER RATING 210KVA / 210KWAC
- INVERTER QUANTITY 96
- TRANSFORMER RATING -5140 KVA
- TRANSFORMER QUANTITY 4
- BATTERY UNIT TBD AT CONSTRUCTION
- BATTERY UNIT TOTAL TBD
- BATTERY RATING TBD

**WEST HAVEN ENERGY CENTER,LLC** 337 ELM STREET WELCOME, CT 06516

**SITE COORDINATES:** 41°16'31.34"N, 72°57'17.51"W

## 15.0 MW UNITED ILLUMINATING

11	Added Switchgear	10/31/24
10	Added Station Service	10/31/24
9	Added Meters per ISO-NE reqs.	10/31/24
8	Added Aux Trans and Aux Loads	10/31/24
7	Changed,34.5 KV to 13.8 KV	04/12/24
6	Changed 13.8 KV to 34.5 KV	03/25/24
5	Changed Inverters and Tranf's	02/28/24
4	Changed to 2 - Feeder Circuits	01/31/23
3	Added Recloser Function Table	06/22/21
2	Added Recloser (Customer)	05/19/21
1	Changed from 10 MW to 15 MW	04/28/21
REV#	DESCRIPTION	DATE

PROJECT NAME

EAST POINT ENERGY WEST HAVEN ENERGY CENTER, LLC

PROJECT: WEST HAVEN SLD	SHEET
MONTH/YR: 02/2021	IC-WHE-1
INTERCONNECTION	IC-VVIIL-I
SINGLE LINE DRAWING	