



**TA Solar 335 LLC a Subsidiary of TRITEC
Americas, LLC**

**EMERGENCY RESPONSE PLAN FOR THE PROPOSED 1.90
MW AC SOLAR PHOTOVOLTAIC PROJECT AT 0 HUNTERS
MOUNTAIN ROAD IN NAUGATUCK, CONNECTICUT**

EMERGENCY RESPONSE PLAN

In case of an on-site emergency that calls for the immediate shutdown of the solar system, the following emergency shutdown procedure should be conducted in conjunction with representatives of the police and fire department:

1. Open AC disconnect located on equipment pad.
2. Turn off DC disconnects on all inverters located on equipment pad.
3. Turn off all DC disconnects on DC combiners located throughout the array.
4. Contact the Naugatuck Fire and Police departments if not already present.

Police:

Police Chief: Colin McAllister
Naugatuck Police Department
211 Spring Street
Naugatuck, CT 06770
Main: (203) 729-5222

Fire:

Fire Chief: Ken Hanks
Naugatuck Fire Department
41 Maple Street
Naugatuck, CT 0677
Main: (203) 720-7080

TRITEC O&M Provider Contact Information:

Warren Horton
Horton Electrical Services, LLC
97 River Road
Canton, CT 06019
Direct office phone: 860-940-2056
Cell phone: 860-965-7538 cell
Email: whorton@hortonelectric.com