



**TRITEC Energy Development LLC, a Subsidiary  
of TRITEC Americas, LLC**

**EMERGENCY RESPONSE PLAN FOR THE PROPOSED 1.0  
MW AC SOLAR PHOTOVOLTAIC PROJECT AT 74 BOKUM  
ROAD IN OLD SAYBROOK, CONNECTICUT**

## **EMERGENCY RESPONSE PLAN**

In case of an on-site emergency that calls for the immediate shutdown of the solar system, the following emergency shutdown procedure should be conducted in conjunction with representatives of the police and fire department:

1. Open AC disconnect located on equipment pad.
2. Turn off DC disconnects on all inverters located on equipment pads.
3. Turn off all DC disconnects on DC combiners located throughout the array.
4. Contact the Old Saybrook Fire and Police departments if not already present.

Police:

Lieutenant Ryan Walsh, Acting Chief  
(860) 395-3142

Fire:

Peter Terenzi, Fire Marshal  
(860) 395-3149  
(860) 395-3133

TRITEC O&M Provider Contact Information:

Warren Horton  
Horton Electrical Services, LLC  
97 River Road  
Canton, CT 06019  
Direct office phone: 860-940-2056 direct  
Cell phone: 860-965-7538 cell  
Email: [whorton@hortonelectric.com](mailto:whorton@hortonelectric.com)