

Exhibit J



**TRITEC Energy Development, LLC, a Subsidiary
of TRITEC Americas, LLC**

**EMERGENCY RESPONSE PLAN FOR THE PROPOSED
1.99 MW AC SOLAR PHOTOVOLTAIC PROJECT AT 40
OLD COLCHESTER ROAD IN SALEM, CONNECTICUT**

EMERGENCY RESPONSE PLAN

In case of an on-site emergency that calls for the immediate shutdown of the solar system, the following emergency shutdown procedure should be conducted in conjunction with representatives of the police and fire department:

1. Open AC disconnect located on equipment pad.
2. Turn off DC disconnects on all inverters located on equipment pad.
3. Turn off all DC disconnects on DC combiners located throughout the array.
4. Contact the Salem Fire and Police departments if not already present.

Police:

Main: (860) 859-3873 ext. 200

Troop K: (860) 465-5400

Fire:

Fire Marshal, Thomas Main

860-859-3873 ext. 190

TRITEC O&M Provider Contact Information:

Warren Horton

Horton Electrical Services, LLC

97 River Road

Canton, CT 06019

Direct office phone: 860-940-2056 direct

Cell phone: 860-965-7538 cell

Email: whorton@hortonelectric.com