

STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

JOINT APPLICATION OF THE CONNECTICUT
LIGHT AND POWER COMPANY AND THE
UNITED ILLUMINATING COMPANY FOR A
CERTIFICATE OF ENVIRONMENTAL
COMPATIBILITY AND PUBLIC NEED FOR A
345-KV ELECTRIC TRANSMISSION LINE
FACILITY AND ASSOCIATED FACILITIES
BETWEEN SCOVILL ROCK SWITCHING
STATION IN MIDDLETOWN AND NORWALK
SUBSTATION IN NORWALK

DOCKET NO. 272

MARCH 9, 2004

PREFILED TESTIMONY OF ISO NEW ENGLAND INC.
BY STEPHEN G. WHITLEY

1 **I. WITNESS EXPERIENCE**

2

3 *Q. Please state your name, title and business address.*

4 A. Stephen G. Whitley
5 Senior Vice President and Chief Operating Officer
6 ISO New England Inc.
7 One Sullivan Road
8 Holyoke, MA 01040

9

10 *Q. What positions have you held at ISO and what have your responsibilities been?*

11 A. As the Senior Vice President and Chief Operating Officer of ISO New England

12 Inc. ("ISO"), I have overall responsibility for System Planning, System

13 Operations, Market Operations, Settlements, and Customer Service & Training

14 for the company. I manage a staff of approximately 200 people and oversee the

15 Dispatch Control Center in Holyoke, Massachusetts. Prior to this position, from

16 2000-2001, I served as Vice-President for Systems Operations and oversaw that

17 department. I presently serve as Chairman of the Electric Power Research
18 Institute Grid Operations, Planning and Markets Working Group.

19 *Q. What experience prior to ISO did you have that concerned transmission system*
20 *planning?*

21 A. As detailed in my attached biography¹, my entire career has been spent on matters
22 concerning the operations and planning of transmission systems. Prior to joining
23 ISO, from 1996-2000, I was responsible for control area operations, power
24 supply, economic dispatch, system protection, transmission security and services,
25 and dispatching for the 80,000 square mile Tennessee Valley Authority (“TVA”)
26 service territory, comprising five States. From 1991-1996, I was responsible for
27 the planning, design, and construction of the TVA transmission system.

28 *O. Have you previously testified before the Connecticut Siting Council?*

29 A. Yes, I testified in Docket 217 regarding Northeast Utilities Service Company’s
30 application for a 345kV line from Plumtree Substation in Bethel to Norwalk.

31 *Q. What has been your involvement in Connecticut Siting Council Docket 217?*

32 A. As the Chief Operating Officer of ISO, I am responsible for operating the existing
33 system and for overseeing and supervising the studies that ISO performed, as
34 described in this testimony.

35 *Q. Is the information presented in this testimony and in the responses to pre-hearing*
36 *questions true and correct to the best of your knowledge and belief?*

37 A. Yes.

38

¹ ISO Exhibit 1.

39 **II. SUMMARY OF TESTIMONY**

40 *Q. Please summarize your testimony.*

41 A. Based on studies to date, applicable regional reliability standards, and its own
42 operating experience, ISO considers the electricity delivery system in the
43 southwestern region of Connecticut to be unreliable. Given the present and
44 predicted future composition of generating units and electric demand in that part
45 of the state, transmission system reinforcements are required to enable consumers
46 of electricity in that part of the state to receive reliable electricity service in
47 accordance with regional reliability standards.

48 As part of its responsibility to assess and develop a long-range
49 transmission expansion plan, ISO seeks to identify solutions to expected
50 transmission system problems, and to identify solutions that will solve those
51 problems while there is still time to permit, design and construct a solution.
52 Pursuant to its obligation as the region's transmission system planner, ISO has
53 identified a "full loop" 345-kV transmission line, located in the southwestern
54 region of Connecticut, as a long-term response to its concerns about electricity
55 service meeting NEPOOL Reliability Standards. A "full loop" would consist of
56 the 345-kV transmission line which was the subject of the Siting Council's
57 approval proceeding in Docket 217 and a 345-kV transmission line running from
58 the Norwalk substation to the Scovill Rock Switching Station in Middletown,
59 including related facilities. A combination overhead/underground 345 kV line
60 from Norwalk to Middletown has been proposed by The Connecticut Light and
61 Power Company ("CL&P") and The United Illuminating Company ("UI,"

62 together with CL&P sometimes jointly referred to as the “Applicants”) in this
63 proceeding.

64 A 345-kV transmission line between Middletown and Norwalk (the “M-N
65 Line”) is a vital part of a long range transmission upgrade plan that will
66 comprehensively address present and future reliability problems in Connecticut,
67 will complete the transmission loop connecting Southwestern Connecticut with
68 the rest of New England’s bulk power grid system, and will alleviate many of the
69 reliability problems ISO has observed in this area. Completion of the full 345 kV
70 loop is necessary to address the reliability problems in this area and addresses
71 those problems more completely than other transmission or non-transmission
72 alternatives studied by ISO.

73

74 **III. ISO'S MISSION AND RESPONSIBILITIES**

75 *Q. Why was ISO established?*

76 A. The “Independent System Operator” concept was developed by the Federal
77 Energy Regulatory Commission (“FERC”) as part of the framework to support
78 competitive electricity markets. In 1996, FERC stated its principles for ISO
79 operation and governance in FERC Order 888.² FERC identified key Independent
80 System Operator principles as: providing independent, open and fair access to the
81 region’s transmission system; establishing a non-discriminatory governance

² Promoting Wholesale Competition Through Open Access, Non-Discriminatory Transmission Services by Public Utilities; Recovery of Stranded Costs by Public Utilities and Transmitting Utilities, Order No. 888, 75 FERC ¶ 31,036 (1996)(establishing principles for ISO's operation and governance).

82 structure; facilitating market based wholesale electricity rates; and ensuring the
83 efficient management and reliable operation of the regional bulk power system.
84 ISO was established to be the Independent System Operator of the New England
85 bulk power grid on July 1, 1997, and it assumed certain operating and
86 transmission reservation responsibilities which had previously been carried out by
87 NEPOOL, which transferred staff and assets to ISO. Administrative Notice
88 Exhibit 1.³ In May, 1999, ISO commenced administration of the restructured
89 wholesale electricity marketplace for the region.⁴ In June, 2001, FERC conferred
90 authority on ISO to be responsible for the regional transmission planning
91 process.⁵ In June 2003, FERC confirmed ISO's authority to approve planning for
92 upgrades and changes to supply and demand-side resources.⁶

93 *Q. Does ISO make any profit from its role as the Independent System Operator?*

94 *A.* No. As the Independent System Operator, ISO complies with FERC Order No.
95 889.⁷ 75 FERC 61,078. In this regard, ISO is an independent, private, non-profit,
96 non-stock, company. ISO therefore has no shareholders, and its Directors,
97 employees and consultants are barred from being employed by or owning shares

³ New England Power Pool, Order Conditionally Authorizing Establishment of an Independent System Operator and Disposition of Control Over Jurisdictional Facilities, 79 FERC ¶ 61,374 (1997)(authorizing formation of ISO).

⁴ New England Power Pool, Order Conditionally Accepting New and Revised Market Rules, 87 FERC ¶ 61,045 (1999)(authorizing ISO-NE to administer the restructured wholesale electricity marketplace).

⁵ ISO New England Inc. & New England Power Pool, Order On Rehearing Requests and Compliance Filings, 95 FERC ¶ 61384 (2001)(authorizing ISO to oversee regional transmission planning).

⁶ New England Power Pool & ISO New England Inc., 103 FERC ¶ 61,304 (2003) (accepting October 2001 compliance filing as to the directive regarding Sections 18.4 and 18.5 of the Restated NEPOOL Agreement, and stating that “[w]e are persuaded by ISO-NE's arguments that it is the appropriate authority to approve planning for transmission upgrades and changes to supply and demand-side resources.”).

⁷ Open Access Same-Time Information System Conduct, Order No. 889, 75 FERC ¶ 61,078 (1996)(rules establishing and governing Open Access Same-Time Information System).

98 in NEPOOL Market participants. Its budget is reviewed and approved annually
99 by FERC, and ISO's Tariff only recoups its annual expenses. As a result, market
100 activity covers ISO's expenses in monitoring and administering the system.

101 *Q. What are ISO's mission and responsibilities?*

102 A. ISO is responsible for managing the New England region's bulk electric power
103 system, operating the wholesale electricity market, administering the region's
104 Open Access Transmission Tariff, and conducting centralized system planning.
105 More specifically, ISO's responsibilities include independently operating and
106 maintaining a highly reliable bulk transmission system, promoting efficient
107 wholesale electricity markets, and working collaboratively and proactively with
108 state and federal regulators, NEPOOL Participants, and other stakeholders.
109 NEPOOL Participants include generators, transmission owners, marketers,
110 municipalities and "end users." Each of these types of entities make up a
111 "NEPOOL Sector." Each sector has an equal vote in all NEPOOL matters, *i.e.*, a
112 weighted vote of 20% per section. Connecticut NEPOOL Participants include
113 both of the Applicants in this proceeding, as well as Connecticut Municipal
114 Electric Energy Cooperative, Connecticut Energy Cooperative, Inc., Connecticut
115 Resource Recovery Authority, and the Office of Consumer Counsel ("OCC").

116 Pursuant to this mission, ISO must maintain a level of system reliability
117 that meets criteria established by NEPOOL, the Northeast Power Coordinating
118 Council ("NPCC") and the North American Electric Reliability Council
119 ("NERC"). Applicable reliability standards are discussed more fully below.

120 NEPOOL Reliability Standards, which are based on NERC Planning Standards,
121 are found in NEPOOL Planning Procedure No. 3 (July 9, 1999).⁸

122 The massive outage which struck the North American electric power
123 system on August 14, 2003, causing the loss of approximately 2,500 MW of load
124 in New England, including much of Southwest Connecticut and portions of other
125 areas in the state, has underscored the significance of ISO's mission and
126 responsibilities. The event demonstrated the need for appropriate reliability
127 standards, effective monitoring of compliance, and, most importantly, a reliable
128 bulk power transmission system. A well-coordinated system plan and additional
129 power system infrastructure are more essential than ever to ensure reliability of
130 service to load, because without a well-planned system, there may not be
131 operating decisions available to maintain uninterrupted service.

132 *Q. What is ISO's role in operating the region's power grid system?*

133 *A.* ISO operates the power grid for the six-state New England region, which includes
134 approximately 350 generating facilities connected by approximately 8,000 miles
135 of transmission lines. This regional network, originally established with the
136 formation of NEPOOL in 1971, serves electricity in real time to more than 14
137 million New England residents and businesses. ISO's Control Center, which
138 centrally dispatches this system based on the economic merit order of generating
139 resources at any given time to match the region's electric load, is staffed around
140 the clock by a team of experienced operators to ensure safe and reliable delivery

⁸ NERC Planning Standards and NEPOOL Planning Procedure No. 3 are included in Volume 5 of the Application.

141 of electricity and transmission system reliability. If overloads are identified, a re-
142 dispatch process occurs, if available.

143 *Q. What is ISO's role in conducting regional transmission planning?*

144 A. In June 2001, FERC conferred upon ISO responsibility for conducting long-term
145 system planning for the New England region. The regional transmission plan
146 ("RTEP") is developed through an open process and through participation of, and
147 review by, interested parties, including state regulators and NEPOOL market
148 participants. The RTEP is updated annually.

149 Each RTEP summarizes results from a yearlong regional planning effort
150 that examines system needs throughout New England. The RTEP is a
151 comprehensive electrical engineering assessment comprised of numerous studies
152 and analyses of New England's bulk electric power system. By identifying
153 problem areas, the RTEP is intended to provide appropriate information to the
154 wholesale electricity marketplace on power system problems and the needs that
155 may be addressed through investment in market solutions. Market responses
156 might include investment in generation, merchant transmission facilities,
157 distributed resources and demand response programs. If the market does not
158 respond with adequate solutions to defined system needs, ISO is charged with
159 providing a coordinated transmission plan that identifies appropriate upgrades for
160 reliability and economic needs. The plan would be implemented only after
161 market solutions have been considered. Thus, the RTEP is a planning process
162 that responds to and integrates market responses with needed reliability and

163 economic transmission upgrades in order to achieve a reliable system of
164 generation, distributed resources, and transmission.

165 *Q. Does the RTEP study process focus on specific geographic areas?*

166 A. The RTEP study process included the development of “RTEP sub-areas” based on
167 electrical interfaces in the system to evaluate region-wide reliability and economic
168 indicators, including a Southwest Connecticut RTEP sub-area (“SWCT”)
169 covering more than 50 municipalities in South and Central Connecticut, a
170 Norwalk-Stamford sub-area (“Nor-Stam”) covering 14 municipalities in Fairfield
171 County within the SWCT sub-area, and a Connecticut sub-area (“CT”) covering
172 the remaining northern and eastern portions of the state. For purposes of broad
173 resource adequacy and economic modeling, these sub-areas simplistically assume
174 no operating constraints within them, although in fact such constraints exist. As a
175 result, they provide screening analyses. ISO then conducted more detailed studies
176 of the operating constraints, embodied in various studies discussed herein, that
177 provide more accurate pictures of the nature of the transmission system
178 shortcomings in the SWCT and Nor-Stam sub-areas and the need transmission
179 upgrades.

180 *Q. Who conducts the RTEP process?*

181 A. ISO conducts and directs the studies that comprise the RTEP with the advice of
182 the Transmission Expansion Advisory Committee (“TEAC”). The TEAC is
183 composed of a wide variety of regional stakeholders as may change from time to
184 time, including NEPOOL Participants (such as generator owners, marketers, load
185 serving entities and transmission owners), governmental representatives, state

186 agencies (including those participating in the New England Conference of Public
187 Utilities Commissioners), representatives of local communities, and consultants.
188 The TEAC meets regularly throughout the year, and TEAC meetings are open to
189 any interested party and have included representatives of the Connecticut
190 Department of Public Utility Control, the OCC, the Institute for Sustainable
191 Energy at Eastern Connecticut State University and the Connecticut Attorney
192 General's Office.

193 *Q. Can you briefly summarize the conclusions drawn by the RTEP process with*
194 *respect to Southwest Connecticut?*

195 A. Yes, the Regional Transmission Expansion Plan issued in October, 2001
196 (“RTEP01”)⁹ identified the system in Southwest Connecticut as having severe
197 reliability problems whenever the largest single generation source in the SWCT
198 sub-area is unavailable, and RTEP01 recommended feasibility studies to examine
199 alternatives and cost estimates for major transmission upgrades to increase
200 imports to the SWCT and NOR sub-areas. RTEP01 also noted the potential for
201 significant congestion costs.

202 *Q. Were the studies recommended by RTEP01 performed?*

203 A. ISO, CL&P and UI personnel formed a working group (the “Working Group”) to
204 coordinate detailed thermal, voltage, short-circuit, transfer limit, and stability
205 study analyses. A study scope was prepared and presented at a special TEAC
206 meeting in August 2001, and the study was developed with public input as the
207 first stage in an ongoing review of transmission system needs. The Working

⁹ ISO Admin. Notice No. 9; See http://www.iso-ne.com/smd/transmission_planning/Regional_Transmission_Expansion_Plan/RTEP_2001/

208 Group formulated ideas for the ultimate transmission plan for the southwestern
209 region of Connecticut, and in January 2002 issued the Southwestern Connecticut
210 Reliability Study – Interim Report (“Interim Report”), which covered the initial
211 phase of the thermal, voltage and short-circuit analysis. Related studies were
212 subsequently performed, including: (a) Southwestern Connecticut Reliability
213 Study, Final Power-Flow, Voltage and Short Circuit Report, (issued in December,
214 2002) (“Final Report”)¹⁰; (b) Comparative Analysis of a 345 kV Plumtree-
215 Norwalk Overhead Line Versus 2 – 115 kV Cables from Plumtree-Norwalk
216 (issued December, 2002, as part of the Southwestern Connecticut Reliability
217 Study)(“Comparison Study”)¹¹; (c) Southwest Connecticut Electric Reliability
218 Study, 345-kV Plumtree – Norwalk Project Final Power-Flow, Voltage and
219 Short-Circuit Report (“Phase I Report”)¹²; and (d) Southwest Connecticut
220 Reliability Study, Comparison of Middletown to Norwalk Project vs. East Shore
221 Alternative (issued in February, 2004) (“East Shore Study”)¹³. All of these
222 reports form the Southwestern Connecticut Reliability Study.

223 *Q. Have subsequent RTEP reports further examined the system in SWCT and Nor-*
224 *Stam sub-areas?*

225 A. Subsequent RTEP reports issued in November, 2002 and November, 2003
226 (respectively referred to as “RTEP02” and “RTEP03”) reported extensively on

¹⁰ ISO Exhibit 4.

¹¹ ISO Exhibit 5.

¹² ISO Exhibit 6 (filed by CL&P in response to PSEG-01 and OCC-01 Interrogatories)

¹³ See Addendum 3 to December 16, 2003 Supplemental Filing by Applicants.

227 problems in the SWCT and Nor-Stam sub-areas. RTEP02¹⁴ contained the
228 following finding:

229 The most urgent system reliability need is in the SWCT and NOR
230 Sub-Areas. The combined area lacks the required transmission
231 infrastructure to provide adequate reliability to its electric customers.
232 Without transmission infrastructure upgrades, studies demonstrate
233 widespread violations of transmission planning criteria. As a result,
234 without such upgrades, it is doubtful that the existing system could
235 reliably support projected loads in the long term. In the short term,
236 without significantly increased implementation of DSM and LRP it is
237 doubtful that the existing system can reliably support the projected loads.
238 ISO-NE has determined that the existing transmission system
239 configuration cannot provide for significant generation expansion or even
240 the simultaneous operation of the existing generation at full load. (See
241 RTEP02, Section 1.2.1, p. 13)
242

243 RTEP02 recommended proceeding with 345 kV Phases I and II transmission
244 upgrades to SWCT. (*Id.* at Section 1.3.1, p. 14)

245 The Executive Summary of RTEP03¹⁵ repeated the foregoing admonition,
246 indicating that in spite of recent local improvements, the most urgent system
247 reliability need in New England continues to be in the SWCT and Nor-Stam
248 sub-areas (RTEP03, Section 5.4.5, p.32), again warning that the existing
249 transmission system in Southwest Connecticut can neither provide for significant
250 generation expansion nor fully utilize the area's generating resources during times
251 of need. RTEP03 expressed support for the approval of a 345 kV line from
252 Middletown to Norwalk.

253 There have been no new developments that would significantly mitigate
254 long term reliability concerns for this area since RTEP03 was issued.

¹⁴ ISO Admin. Notice No. 10; *see* http://www.iso-ne.com/smd/transmission_planning/Regional_Transmission_Expansion_Plan/RTEP_2002/
¹⁵ ISO Admin. Notice No. 11; *see* http://www.iso-ne.com/smd/transmission_planning/Regional_Transmission_Expansion_Plan/RTEP_2003/

255 Accordingly, ISO recommends approval and completion of the 345kV full loop as
256 soon as practicable.

257 *Q. Will ISO experience any pecuniary benefit if the Connecticut Siting Council*
258 *approves the Applicants' request for a Certificate of Environmental Compatibility*
259 *and Public Need for the electric transmission line at issue and the line is placed*
260 *in service?*

261 A. No. Because ISO is an independent, not-for-profit entity, neither ISO as a
262 corporate entity nor its directors, employees or consultants, may experience a
263 pecuniary benefit from the Siting Council's approval of the application in this
264 proceeding for a Certificate of Environmental Compatibility and Public Need.

265

266 **IV. THE RELIABILITY OF THE TRANSMISSION SYSTEM IN**
267 **SOUTHWEST CONNECTICUT**

268 *Q. Does ISO consider electricity service in the southwestern region of Connecticut to*
269 *be unreliable?*

270 A Yes.

271 *Q. Why does ISO consider electricity service in the southwestern region of*
272 *Connecticut to be unreliable?*

273 A. ISO believes that electricity service in the southwestern region of Connecticut is
274 unreliable because under current assumptions about electric demand growth and
275 available generation in the area, the existing transmission system is incapable of
276 importing sufficient amount of electricity into and moving it reliably within the
277 region. As a result, there are an unacceptable number of violations of the

278 NEPOOL Reliability Standards when the system is tested and modeled in
279 accordance with those Standards. Transmission system inadequacies could also
280 hamper new generation from addressing growing load in the region.

281 Generally speaking, the electric demand in the southwestern region of
282 Connecticut – *i.e.*, the number of consumers of electricity and the amount of
283 electricity they consume – regularly increases, demanding new sources of
284 electricity. Additionally, because there are inadequate transmission facilities, the
285 local electricity supply plus the supply that must be imported from other areas of
286 Connecticut and New England are unable to reach the demand areas in the
287 southwestern region of Connecticut.

288 Because there is an insufficient local supply of electricity, users of
289 electricity in the southwestern region of Connecticut must rely on transmission
290 lines not only to transport electricity produced within the southwestern region of
291 Connecticut, but also to import electricity from the rest of Connecticut and New
292 England. For example, the peak demand in the Norwalk-Stamford area is
293 approximately 2.5 times the total amount of local generation.

294 As a result, this region of Connecticut is highly dependent on power
295 imports over the 115-kV transmission system in Connecticut and is critically
296 dependent on a 138-kV transmission line from Long Island, New York in the
297 event of severe demands for electricity. This 138-kV line has, however, been
298 unavailable for prolonged periods of time and has an uncertain future.

299 The problems in providing electricity are exacerbated if local supplies of
300 electricity are unavailable. Given the natural occurrences of unexpected outages,

301 there is concern that local generating units, which may be in great demand, may
302 not be available. In addition, given the age of the units and the environmental and
303 political pressures, there is also concern that units in key locations could be shut
304 down due to a catastrophic or other failure, either permanently or for an extended
305 period for replacement. As a result, there must be a robust transmission system in
306 place to import needed electricity into and around this region. However, the
307 amount of electricity that the existing transmission system can import from other
308 areas and transmit within the southwestern region of Connecticut is limited,
309 creating an unacceptable risk of failure under NEPOOL Reliability Standards.

310 *Q. Have there been any actual experiences which have caused operational concern?*

311 As described in more detail below, residents and businesses in the SWCT sub-
312 area experienced two close calls in losing electricity in August, 2001 due to
313 circumstances arising within the SWCT sub-area. These events illustrate the
314 potential of the system in the SWCT sub-area, without the full 345 kV loop, to
315 trigger disturbances which could have widespread consequences. I was
316 concerned when I testified during Docket No. 217 regarding the Bethel to
317 Norwalk 345 kV line, that a situation in Southwestern Connecticut could give rise
318 to a widespread outage affecting several states in a matter of seconds, and I
319 remain concerned today that until the 345 kV full loop is installed, such an event
320 in Southwestern Connecticut could still occur with massive consequences.

321 While ISO's operating experience is that the system in southwestern
322 Connecticut has been unreasonably close to experiencing blackouts on other
323 occasions without the influence of any events external to the system, my concerns

324 about the speed and scope of an outage caused by Southwestern Connecticut's
325 unreliable system were nevertheless illustrated by the Northeast power system
326 disturbance on August 14, 2003. That event spread eastward from Ohio in a
327 matter of seconds, affecting some 50 million people in the Northeastern United
328 States and adjacent parts of Canada. While the August 14, 2003, disturbance did
329 not originate in our system, and while electricity service was not disrupted in most
330 of New England, it is worth noting that much of the SWCT sub-area, the weakest
331 part of the New England grid, was blacked out for close to 12 hours. No other
332 part of the New England system was affected as seriously or lost so much load.

333 *Q. What criteria did ISO use to determine whether electricity service was unreliable*
334 *in the southwestern region of Connecticut?*

335 *A.* In accordance with the NEPOOL Reliability Standards applicable to ISO's
336 transmission system planning process, ISO reviewed those generation and
337 transmission facilities in the southwestern region of Connecticut on which faults
338 or disturbances can have a significant effect in New England.

339 Since several years are required for permitting, financing, designing and
340 constructing a major transmission system upgrade, as evidenced by the
341 Applicants' proposed 2007 target for placing the M-N Line in service, ISO relied
342 on reasonable load forecasts and assumptions about the future availability of
343 generation units, applying that information in a computer modeling process
344 designed to observe problems on the transmission system under a variety of
345 scenarios.

346 *Q. What do the NEPOOL Reliability Standards establish?*

347 A. NEPOOL Reliability Standards define the criteria that are used to assure the
348 reliability and performance of the interconnected electrical network in New
349 England. Adherence to these standards assures that the New England
350 transmission system shall be designed with sufficient transmission capacity to
351 integrate all resources and serve area demands under certain specified conditions.
352 Analyzing the system with due regard to these standards determines whether the
353 transmission is capable of delivering generation to the load in any given region
354 under both anticipated and unusual circumstances.

355 *Q. What are the NEPOOL Reliability Standards based on?*

356 A. NEPOOL Reliability Standards are based on standards developed by regional and
357 independent bodies to avoid large-scale blackouts. Following blackouts in the
358 northeastern United States in the 1960s and 1970s, what is now known as NERC
359 was formed in an attempt to prevent future occurrences by establishing broad-
360 based reliability standards. The NPCC, of which ISO is a member, was
361 subsequently formed to develop regionally-specific criteria based on NERC
362 standards. The NEPOOL reliability standards are consistent with NPCC
363 reliability criteria.

364 These reliability standards have long provided the basis for the
365 development of the New England transmission grid, and provide the basis for
366 similar standards throughout the Nation, and portions of North America.

367 *Q. How did ISO analyze whether the transmission system in the southwestern region
368 of Connecticut violates NEPOOL Reliability Standards?*

369 A. The Interim Report and the Final Report issued by the Working Group analyzed
370 the operational capability of the transmission facilities in the southwestern region
371 of Connecticut. These reports identify the transmission system inadequacies and
372 reliability violations prior to installation of the 345 kV line from Bethel to
373 Norwalk (Phase I) approved by the Connecticut Siting Council in Docket 217.
374 The reliability violations ran into the hundreds, as listed in Appendix D to the
375 Interim Report. The Final Report identified numerous thermal overload, voltage
376 violation and voltage collapse scenarios which exist with today's transmission
377 system, prior to installation of the Phase I line, and proposed that a 345 kV "loop"
378 be constructed to fully integrate SWCT and the Norwalk–Stamford area into the
379 New England 345-kV network and alleviate reliability problems. The Phase I
380 Report indicates that while system performance improves at the design peak load
381 level of 27,700 MW with the installation of the 345 kV line from Bethel to
382 Norwalk, significant thermal overloads and voltage violations continue to exist
383 following construction of this line. The Phase I Report therefore concludes that
384 the SWCT electric power system does not meet regional reliability performance
385 standards.

386 The Phase I Report is consistent with the Comparison Study, which
387 examined Phase I both as a stand alone project and as part of a full 345 kV loop
388 connecting Bethel to Middletown through Norwalk. Construction of the 345 kV
389 line from Bethel to Norwalk would alleviate system performance, but modeling
390 indicates that even after installation of this line, 276 contingency overloads would
391 occur on 40 lines and there would be 17 non-convergent contingencies. A non-

392 convergent contingency is one for which there is no mathematical solution, and it
393 signals the potential for voltage collapse. The Comparison Study, which assumed
394 an overhead project with no underground lines, showed no violations when the
395 Phase I line was modeled as part of a full 345 kV loop which would continue
396 from Norwalk to Middletown.

397 *Q. Does ISO therefore believe that the proposed M-N Line will eliminate all SWCT*
398 *reliability violations?*

399 *A.* As noted, the Comparison Study was based on the assumption of an overhead line
400 so its conclusions do not necessarily apply to the combination
401 overhead/underground alternative approved for Phase I from Bethel to Norwalk,
402 especially as the M-N Line also proposes an underground component. Because
403 overhead lines and underground cables have different electrical characteristics
404 and properties and behave differently, one is not necessarily a substitute for the
405 other under all circumstances. Underground cables are inherently more capacitive,
406 have lower impedance, and lower capacity than overhead lines. Heavy reliance on
407 long underground cables in the SWCT area can result in increasing and excessive
408 voltage on the bulk power system, thereby causing heretofore unforeseen threats
409 to reliability associated with high voltage levels. Additionally, power will
410 naturally flow on the lower impedance path introduced by the cables, resulting in
411 a disproportionate loading of these lower capacity facilities. Therefore,
412 modification of the full overhead loop to an overhead/underground combination
413 requires supplemental studies to determine any additional system modifications
414 required to develop a cost-effective design with acceptable transient and

415 steady-state voltages and facility thermal loadings. Impacts on the entire loop
416 will be considered. The length of underground cable, with its lower impedance,
417 must not undermine short-circuit current mitigation efforts addressed by the
418 project.

419 *Q. Why was a 27,700 MW peak load used in these studies?*

420 *A.* It is good utility practice to consider a range of forecasted peak demands in
421 selecting a design basis load level. ISO issues a forecast which assumes average
422 weather conditions and a peak load which has a 50% probability of being
423 exceeded (the so-called “50/50” forecast), and ISO also issues a forecast which
424 assumes extreme weather conditions and a peak load which has a 10% probability
425 of being exceeded (the so-called “90/10” forecast). Designing a system on the
426 peak load projected by the 50/50 forecast essentially means that the system would
427 not meet peak loads reached 50% of the time. It is therefore prudent to plan for
428 peak loads which may be reached in extreme weather conditions. The 27,700
429 MW design basis peak New England demand level used in this study is based on
430 the NEPOOL 2003 Capacity, Energy, Load and Transmission (“CELT”) Report,
431 issued in April 2003, that predicts a 2010 peak demand of 27,820 MW with a
432 50% probability of being exceeded. However, considering a 10% probability of
433 exceeding the forecasted peak demand, this load level would be reached as early
434 as 2006. Bearing in mind the Applicants’ proposed completion date of December,
435 2007, a 27,700 MW load level appeared to represent demanding, yet plausible,
436 stresses on the transmission grid. Based on the peak load of 25,348 MW on
437 August 14, 2002, which as of that time had not been projected to occur until

438 Summer 2005, and extreme weather conditions experienced on several occasions
439 during the summer of 2002, the 27,700 MW load level is reasonable.

440 RTEP03 indicates that the summer peak has increased by 20 percent over
441 the last ten years and is expected to continue to grow by 15 percent over the next
442 ten years, a compound annual growth rate of 1.5 percent per year. The 2003
443 CELT Report predicts a peak New England summer load of 25,690 MW in 2004
444 based on normal weather and a 50% probability of being exceeded, and this
445 would increase to 26,300 MW based on extreme weather and a 10% probability of
446 being exceeded. Historical and anticipated load growth rates, applied to extreme
447 weather conditions, indicate that the 27,700 MW design load level would be
448 exceeded in the summer of 2008.

449 *Q. What sorts of reliability problems was ISO concerned about in conducting the*
450 *Southwestern Connecticut Reliability Study and why are they problematic?*

451 A. The Southwestern Connecticut Reliability Study examined the thermal and
452 voltage capability of the transmission facilities in the southwestern region of
453 Connecticut. The Working Group had several concerns, each associated with the
454 combination of demand in the southwestern region of Connecticut and available
455 generation.

456 We share the Working Group's concerns with thermal overloading of
457 transmission lines, poor voltage performance, potential voltage collapse, and high
458 short circuit current levels. We are concerned that there not be any interruption of
459 service in Southwest Connecticut, and as the operator of the regional bulk power
460 grid for all of New England, we are further concerned that any outage in

461 Connecticut not cascade into neighboring states and neighboring systems in New
462 York and Canada. The Northeast Blackout of August 14, 2003 is clear evidence
463 that if voltage collapse occurs, it can spread in a matter of seconds over a large
464 geographic area, creating massive blackouts and resulting damage and loss.

465 *Q. How do thermal overloads occur?*

466 A. Thermal overloads occur when transmission lines are forced, often as a result of a
467 contingency event elsewhere on the system, to carry current in excess of their
468 design capacity. Overloaded lines build up heat beyond their temperature limits
469 and may fail, redirecting power to other lines, which in turn may become
470 overloaded, a pattern which may result in loss of load, equipment damage and
471 cascading outages which could affect areas inside of and well outside of
472 Connecticut.

473 Transmission lines have normal and emergency current ratings. Normal
474 ratings are the rating limits within which a line should generally operate at all
475 times. Normal line loading ratings are violated when a transmission line is used
476 to carry more current than it is capable of carrying under normal conditions.

477 Transmission lines can be operated at current loads that exceed the normal rating,
478 but only for a limited period of time, such as in an emergency. An emergency
479 current rating is the upper operational limit of the line. A consequence of
480 running lines between normal and emergency limits is reduced life expectancy of
481 the transmission line. Exceeding emergency ratings of transmission lines could
482 result in line mechanical failure or sagging into public areas, such as highways,
483 thereby compromising public safety, and uncontrolled outages.

484 *Q24. Why is low voltage a concern?*

485 A24. Low voltage is also a concern because it could damage equipment and interfere
486 with the proper operation of appliances and machinery. Insufficient voltage can
487 also cause unanticipated and undesirable protective equipment operation, voltage
488 collapse and loss of load.

489 *Q. Are there concerns involving busses?*

490 A. There is a concern that busses, which are substation terminals, would experience
491 voltage outside of their design criteria. If a bus's voltage is below design criteria,
492 then there is an increased and unacceptable likelihood that an area will lose
493 supply of electricity. Left unchecked, low voltage can damage customer
494 equipment.

495 There is also concern that voltage to busses could be so low that the
496 System Operator would be unable to take action (such as controlled load
497 shedding) to avoid widespread voltage collapse. Under this scenario, affected
498 areas will likely lose supply of electricity in an uncontrolled manner.

499 *Q. Why are high short circuit current levels a concern?*

500 A. High short circuit currents are a concern because they could result in catastrophic
501 equipment failure and present a danger to personnel. The equipment failure could
502 lead to extended equipment and customer outages and diminish the ability to
503 reliably operate the power system.

504 *Q. How many violations of NEPOOL Reliability Standards may occur before a*
505 *system is considered to be out of compliance?*

506 A. None. A system that has one violation of the criteria outlined in the NEPOOL
507 Reliability Standards is not in compliance.

508 *Q. Are there other studies or analyses ISO has conducted to assess the reliability of*
509 *the electric network in Connecticut?*

510 A. ISO regularly performs “System Impact Studies.” These are studies that ISO is
511 contractually obligated to perform pursuant to the NEPOOL Open Access
512 Transmission Tariff and Section 18 of the Restated NEPOOL Agreement. In
513 these studies, ISO determines the transmission requirements necessary to
514 interconnect generation units or transmission facilities in a manner that would not
515 adversely affect the reliability of the transmission grid in New England. In
516 conducting these studies, ISO found that the circuit breakers at both the Devon
517 and Pequonnock substations have come close to exceeding their ratings for the
518 amount of current they are capable of interrupting. If the rating is exceeded, a
519 catastrophic equipment failure could result. For this reason alone, ISO believes
520 that considerable system changes would be necessary to protect the integrity of
521 the system if a party sought to add another generator.

522 *Q. Are there other reasons why ISO believes electricity service in southwestern*
523 *region of Connecticut to be unreliable?*

524 A. Yes. ISO’s experience in operating the New England transmission system makes
525 it concerned that the southwestern region of Connecticut is unreasonably close to
526 losing electrical supply. For example, on August 31, 2001, a day on which
527 demand for electricity was relatively light in the region, Bridgeport Energy
528 Station tripped off-line. The loss of this generation increased the flow on lines

529 supplying the area, causing certain lines to fail. Due to the rapid loss of energy
530 supply, ISO declared an emergency for the area, dispatched all area generation,
531 and was required to purchase emergency energy from the Long Island system
532 over the 138-kV transmission line that runs from Northport, New York, to
533 Norwalk Harbor, an option which might well not be available in the near future.
534 ISO also configured the system to enable discontinuance of electric service to
535 several communities in the Danbury area to avoid large-scale blackouts in the
536 event of a particularly severe contingency. The operators, during this non-peak
537 condition, were able to manage the system without disconnecting the load.

538 On August 9, 2001, a heat wave resulted in unprecedented demand for
539 electricity in the southwestern region of Connecticut. The high demand required
540 ISO to dispatch nearly all generating units in New England. ISO was not required
541 to discontinue electricity service to areas in the southwestern region of
542 Connecticut because all generating units happened to be available and no
543 contingencies occurred on the transmission system.

544 It was fortunate in these circumstances that every available generating unit
545 was on-line, unlike January 22, 2003, when SWCT and Nor-Stam suffered
546 outages of eight units representing 1,038 MW, close to 40% of the 2700 MW
547 installed capacity of these sub-areas. The loss of any one generating unit on
548 either August 9 or August 31, 2001, would have resulted in ISO discontinuing
549 electricity service to some areas in an effort to prevent a cascading outage. Under
550 certain load conditions, load-shedding schemes are automatically set following

551 certain contingency events in order to ensure that electricity service will not be
552 discontinued in an uncontrolled fashion.

553 *Q. What are the consequences of an uncontrolled blackout?*

554 A. There are two consequences to uncontrolled blackout. First, there is no way to
555 predict how large an area will be affected by blackout, and as a result, it could
556 encompass vast areas of the northeastern United States, as happened in August,
557 2003 and September, 1965. Second, it will likely result in equipment damage that
558 will hamper restoration of service and make efforts to remedy the system more
559 expensive.

560 *Q. Would the use of underground cable be a reliability concern?*

561 A. Yes. Underground cable is generally used in urban areas where it might be
562 difficult to locate and maintain overhead lines, generally for relatively short
563 distances and at lower transmission voltages. There are various underground
564 cable technologies, and I am aware that each has its advantages and
565 disadvantages. Excessive reliance on underground cable in the SWCT area would
566 result in a more complex system, potentially exceeding the practical limits of
567 operator interaction to prevent increasing and excessive voltage on the system
568 due to the inherent capacitive nature of the cable and control loadings on the
569 cables due to their lower impedance. In addition, ISO would point out that if an
570 underground cable experiences a fault which takes it out of service, it would take
571 considerably longer to restore an underground cable to service than would be the
572 case for an overhead line. It is relatively easy to locate and repair the problem in
573 an overhead line, all of which can generally be accomplished in a day or two. It

574 may take many days to locate the break in an underground cable, since it is buried
575 and inaccessible, and the repair itself, which may require splicing of cables, is
576 also more complicated and time-consuming. If an underground cable fails, it may
577 therefore stay out for up to weeks or months.

578 It should also be understood that an underground cable does not
579 necessarily have the same properties and characteristics as an overhead line, and
580 while the differences can be accommodated and planned for, the system will not
581 necessarily behave the same way if one is viewed simply as a substitute for the
582 other in all circumstances. Transmission solutions, often with several
583 components, like the full 345 kV loop, are planned as an integrated and balanced
584 “whole”. Indiscriminately substituting an underground cable in one component
585 can easily upset the balance and substantially undermine the solution.

586

587 **V. CONGESTION IMPACTS**

588 *Q. Do transmission inadequacies create other disadvantages for Connecticut*
589 *customers?*

590 A. Transmission system inadequacies prevent access to more economical generation
591 because the transmission facilities are unable to carry less expensive electricity
592 into Southwest Connecticut from newer, lower cost facilities located outside of
593 the area. Transmission also allows for access to additional generation capacity,
594 thereby resulting in approved reliability.

595 *Q. Will you comment on the impacts of “Standard Market Design” on costs in a*
596 *transmission-constrained area, such as Southwest Connecticut?*

597 A. Congestion costs incurred by all areas in New England used to be spread across
598 customers in all states through the mechanism of a single region-wide clearing
599 price. The management of congestion and congestion costs has changed under
600 Standard Market Design (“SMD”), which became effective in New England in
601 March, 2003. Under the new system, the costs of paying higher-cost generators
602 to address the electricity needs of a transmission-constrained area are reflected in
603 “locational marginal pricing” (“LMP”). Under this pricing mechanism, a
604 different electric price is charged in each zone in New England, and Connecticut
605 is one zone. The wholesale prices of electricity in zones where transmission
606 constraints prevent access to the least-cost sources of generation located outside
607 the zone will be higher in order to reflect the extra costs resulting from dispatch of
608 more expensive sources of generation inside those zones. These higher costs to
609 serve a zone are no longer “socialized” across New England, but are borne
610 directly by wholesale purchasers supplying power to retail customers within the
611 constrained zone. Due to current constraints, Connecticut residents will thus
612 incur additional indirect financial burdens.

613 *Q. Is your support for the 345 kV full loop based on an anticipated reduction in*
614 *congestion costs?*

615 A. ISO believes that a 345 kV full loop is necessitated by reliability alone, whether
616 or not congestion costs are reduced, and reliability is the main reason ISO
617 supports the M-N Line. Congestion costs ordinarily occur where there are
618 transmission constraints, so the M-N Line, in relieving transmission constraints,
619 should also have the collateral benefit of reducing congestion costs.

620 **VI. NEW GENERATION**

621 *Q. Have any new generating facilities in the southwestern region of Connecticut*
622 *been approved for interconnection, in addition to those assumed for the*
623 *Southwestern Connecticut Reliability Study – Interim Report, to alleviate the*
624 *strain on transmission lines?*

625 *A. No. In fact, there is the threat of existing generating facilities being retired in the*
626 *next few years. The age and condition of generators in the area is a concern, and*
627 *financial considerations may prevent units from remaining in operation.*

628 The first generating unit in Milford has come on line, as had been
629 anticipated, at a summer claimed capability of 234 MW. However, the
630 addition of the new Milford unit does not necessarily represent an increase
631 in generation above existing supply of the full 234MW. First, there had
632 been a conditional dependency between Milford and Devon units which had
633 prevented the simultaneous operation of both units, and that dependency can
634 only be relieved by a transmission upgrade. Second, Devon Units 7 and 8,
635 had been operating pursuant to a "Reliability Must Run" ("RMR") contract,
636 under which ISO could terminate the contract with respect to one or both of
637 the units. Because one Milford unit is in-service, the ISO has given notice
638 of its termination of the RMR contract with one of the Devon Units. As a
639 result, from the perspective of the overall capacity of the SWCT area, the
640 Milford unit's contribution to area generation may be offset by the loss of
641 approximately 107 MW at Devon.

642 *Q. Would the construction of new generating facilities in Southwest Connecticut*
643 *resolve ISO's concerns about reliable electricity service?*

644 A. No. ISO has analyzed the existing transmission system to assess the range of
645 local generator outputs and power transfers that can be accommodated without
646 violating system reliability standards. These analyses show that as the load
647 increases in the southwestern region of Connecticut, reliance on any particular
648 local generator precludes reliance on other local generators due to constraints on
649 the transmission facilities. As a result, the reliability of service for the region is
650 unacceptable, because the transmission facilities are simply inadequate, especially
651 with major generating units out of service.

652 ISO has found that this situation worsens with load growth to the point at
653 which nearly any and every combination of local area generation outputs and
654 power imports results in violations of NEPOOL Reliability Standards. This can
655 result in an unacceptable likelihood of load being shed in order to avoid
656 equipment damage or a possible cascading outage that results in a significant
657 blackout. In considerable contrast, a "compliant" system would allow any
658 amount of, or at least most, generation from area generators to be used under any
659 load scenario without any violations of Reliability Standards.

660 Additionally, the high short circuit current levels present a very significant
661 challenge to the interconnection of new generation in Southwest Connecticut.

662

663

664

665 **VII. BENEFITS OF THE 345-kV TRANSMISSION LINE**

666 *Q. What reliability benefits will the project proposed by the Applicants provide to*
667 *the transmission system?*

668 A. Installation of this the M-N Line will reduce the number of line segments and
669 busses that violate NEPOOL Reliability Standards. While further study must be
670 done to determine whether the overhead/underground combination 345 kV loop
671 will be as helpful as an overhead solution would have been, addition of the M-N
672 Line will improve performance of the Phase I line, which does not achieve its full
673 potential without the M-N Line. It will increase power flow into the region,
674 increase the area's import capability and enable both the use of the full capacity of
675 local generating units and the addition of local generation. The installation of the
676 M-N Line should also result in less lost energy at a transmission level.

677 In the RTEP process, ISO set out to formulate a long-term transmission
678 solution for the southwestern region of Connecticut that satisfies reliability
679 criteria, eliminates operating difficulties, eliminates "first contingency" (including
680 double circuit overloads) and eliminates the threat of voltage collapse. The
681 345kV transmission "full loop" would resolve these concerns.

682 *Q. Has ISO examined the so-called "East Shore Alternative" to the M-N Line?*

683 A. Yes, this alternative was examined in the East Shore Study. The East Shore
684 Alternative as studied was found to be an unacceptable substitute to the M-N Line
685 because it does not meet NERC, NPCC, or NEPOOL criteria. The East Shore
686 Alternative does not strengthen the power supply into SWCT by introducing a
687 new source; it simply connects the load in SWCT to an already heavily loaded

688 387 line. The most notable overload in this report is the one on the 387 line. Even
689 with the assumed reconductoring of the limiting portion of the 387 line, the line
690 continues to overload. In addition, an extended outage of this line yields
691 substantial overloads on the remaining corridors serving SWCT and the 345-kV
692 across the state.

693 Since the East Shore Alternative is not considered acceptable, continued
694 comparative testing was not performed.

695

696 **VIII. NON-TRANSMISSION ALTERNATIVES**

697 *Q. Has ISO advocated that other actions be taken to address reliability concerns in*
698 *Southwest Connecticut?*

699 A. ISO supports any action that can be taken that promotes reliable, efficient and
700 competitive electricity service. ISO believes that the reliability problems in the
701 southwestern region of Connecticut are critical. Because the proposed M-N Line
702 is not scheduled for completion until December 2007, ISO has taken other actions
703 to address its concerns about reliability in the southwestern region of Connecticut
704 for the interim, including the issuance of a Gap RFP in December 2003. The
705 RFP, whose results may not be finalized until early spring, 2004, sought 300 MW
706 of generation resources, demand response resources or peak-load reducing
707 Conservation and Load Management projects for up to four and possibly five
708 years. These solutions are intended to provide temporary relief to “buy time” until
709 the 345-kV project is complete.

710 The problems inherent in the Southwest Connecticut transmission system
711 have even made it very difficult to temporarily address reliability concerns with
712 the GAP RFP. Generation resources responding to the RFP may be restricted to
713 operate in only significant emergency conditions.

714 ISO has also advocated weighting load response dollars toward greater
715 participation in Southwest Connecticut, where the need for such action is greatest.

716 ISO believes, however, that the 345 kV full loop is the only proposal that
717 promises to provide a long-term solution to concerns about reliability. Neither
718 new generation nor load response programs can achieve the same long-term
719 results as the 345-kV full loop.

720 *Q. Has ISO reflected the load reduction contributions of distributed resources,*
721 *demand response and other conservation and load management efforts in its load*
722 *forecasts?*

723 A. Yes. ISO the 27,700 MW load level reflects expected contributions from these
724 programs.

725 *Q. Can distributed generation in the southwestern region of Connecticut resolve*
726 *ISO's concerns about reliability?*

727 A. Distributed Generation, which generally means small generators of kW to
728 multi-MW size installed at a customer's point of use, will not alone resolve ISO's
729 concerns about reliability. Distributed Generation has a number of different uses,
730 including emergency or backup power, peak shaving, premium power for critical
731 loads, and combined heat and power. There are cost and performance issues with
732 distributed generation, and it will take some time for these to be resolved. There

733 may also be noise and emissions concerns. ISO does not foresee any rapid
734 expansion of Distributed Generation over the next five years or so.

735 Even if sufficient distributed generation could be installed to offset annual
736 growth in load, this course of action would do nothing to eliminate the severe
737 operating constraints that exist in the southwestern region of Connecticut today.
738 As a result, ISO's concerns about violation of NEPOOL Reliability Standards
739 would remain unaddressed.

740 *Q. Can demand response programs resolve ISO's concerns about reliability?*

741 A. Demand response can help, but it will not eliminate the need for a 345-kV full
742 loop. ISO has overseen a FERC-approved Load Response Program for New
743 England. ISO New England's 2003 Demand Response Program signed up
744 approximately 400 MW of relief for Summer, 2003, for New England. Of this, a
745 Northeast Utilities sponsored program specifically for Southwest Connecticut
746 provided 20 MW of load relief and over 60 MW of emergency generation for use
747 during high load periods. Typically, only a portion of the load in a voluntary
748 demand response program actually responds when called upon. As a result, ISO
749 believes it unlikely that load response programs could be implemented in a
750 manner that addresses its concerns about reliability. Those concerns will best be
751 addressed by a 345 kV full loop connecting Southwestern Connecticut with the
752 rest of New England's 345 kV bulk power grid.

753 *Q Does this conclude your testimony?*

754 A. Yes.

755