



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@po.state.ct.us

www.ct.gov/csc

August 5, 2005

Ms. Anne Bartosewicz
Project Director – Transmission Projects
Northeast Utilities System
P.O. Box 270
Hartford, CT 06141-0270

RE: **DOCKET NO. 272** - The Connecticut Light and Power Company and The United Illuminating Company Certificate of Environmental Compatibility and Public Need for the Construction of a New 345-kV Electric Transmission Line and Associated Facilities Between Scovill Rock Switching Station in Middletown and Norwalk Substation in Norwalk, Connecticut Including the Reconstruction of Portions of Existing 115-kV and 345-kV Electric Transmission Lines, the Construction of the Beseck Switching Station in Wallingford, East Devon Substation in Milford, and Singer Substation in Bridgeport, Modifications at Scovill Rock Switching Station and Norwalk Substation and the Reconfiguration of Certain Interconnections. **Scovill Rock Switching Station - Development and Management Plan**

Dear Ms. Bartosewicz:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions on Scovill Rock Switching Station - Development and Management Plan no later than August 19, 2005. To help expedite the Council's review, please file individual responses as soon as they are available.


Please forward original and 15 copies to this office. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors dated January 26, 2005, is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,


S. Derek Phelps
Executive Director

SDP/laf

c: Council Members
Parties and Intervenors



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@po.state.ct.us

www.ct.gov/csc

Docket No. 272

Scovill Rock Switching Station, Middletown

Development and Management Plan

Interrogatories

1. Explain discrepancy between the application identifying two 345-kV circuit breakers and four disconnect switches compared to the Development and Management Plan proposing four 345-kV circuit breakers and nine disconnect switches.
2. Why is the Scovill Rock Switching Station not included in the electric and magnetic field monitoring plan?