

Wiggin and Dana LLP  
One Century Tower  
P.O. Box 1832  
New Haven, Connecticut  
06508-1832  
www.wiggin.com

Bruce L. McDermott  
203.498.4340  
203.782.2889 fax  
bmcdermott@wiggin.com

WIGGIN AND DANA  
*Counsellors at Law*

October 18, 2004

RECEIVED  
OCT 18 2004

Pamela B. Katz  
Chairman  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

CONNECTICUT  
SITING COUNCIL


Re: **Docket 272** - The Connecticut Light and Power Company and The United Illuminating Company Application for a Certificate of Environmental Compatibility and Public Need for the Construction of a New 345-kV Electric Transmission Line and Associated Facilities Between Scovill Rock Switching Station in Middletown and Norwalk Substation in Norwalk, Connecticut Including the Reconstruction of Portions of Existing 115-kV and 345-kV Electric Transmission Lines, the Construction of the Beseck Switching Station in Wallingford, East Devon Substation in Milford, and Singer Substation in Bridgeport, Modifications at Scovill Rock Switching Station and Norwalk Substation and the Reconfiguration of Certain Interconnections

Dear Chairman Katz:

I enclose REVISED Exhibit 166 which provides information demonstrating how high transmission structures would need to be in order to attain 0.6 mg for the 15 GW and 27.7 GW cases. In addition to studying the transmission structure heights for cross section 8S, the Companies undertook a similar study for cross section 5.

If you have any questions concerning this filing, please call me.

Very truly yours,



Bruce L. McDermott

cc: Service List

\\10705\1209\494656.1



middletown | nonwalk

**"Homework Assignment"**  
Revised 10/15/2004

**Reductions in Magnetic Fields from Increasing Transmission Structure Heights**

**Typical Segment – Pease Road Junction to East Devon S/S in the Municipalities of Woodbridge, Orange, West Haven & Milford**

Site Condition	Transmission ROW																											
	150'	135'	120'	105'	90'	75'	60'	45'	30'	15'	S/E Edge	50'	25'	Center	25'	50'	NW Edge	15'	30'	45'	60'	75'	90'	105'	120'	135'	150'	
Existing Lines (For Reference)	0.2	0.2	0.2	0.2	0.3	0.4	0.5	0.6	0.9	1.4	2.2	3.9	6.1	12.7	15	7.0	3.2	1.6	1.1	0.7	0.5	0.4	0.3	0.2	0.2	0.1	0.1	0.1
<b>OPTIONS</b>																												
345 kV Split Phase (105' Pole) 115 kV Double Circuit (80' Pole)	0.1	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.5	0.7	1.0	1.7	2.7	4.7	7.0	9.4	11.8	14.1	16.4	18.7	2.1	1.6	1.2	1.0	0.8	0.6	0.5	0.4
345 kV Split Phase +30' (135' Pole) 115 kV Double Circuit +30' (110' Pole)	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.4	0.5	0.6	1.4	2.7	4.3	6.0	7.6	9.2	10.8	12.4	1.5	1.2	0.9	0.8	0.6	0.5	0.5	0.4
345 kV Split Phase +45' (150' Pole) 115 kV Double Circuit +45' (125' Pole)	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.4	0.5	0.9	1.6	2.5	3.4	4.3	5.2	6.1	7.0	1.4	1.2	0.8	0.7	0.6	0.5	0.4	0.4
345 kV Split Phase +70' (175' Pole) 115 kV Double Circuit +70' (150' Pole)	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.4	0.6	0.9	1.2	1.4	1.5	1.6	1.7	1.8	1.0	0.9	0.7	0.6	0.5	0.4	0.4	0.3
345 kV Split Phase +94' (199' Pole) 115 kV Double Circuit +94' (174' Pole)	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.6	0.7	0.8	0.9	0.9	0.8	0.7	0.6	0.5	0.4	0.4	0.3	0.3	0.3	0.3
<b>Height Required to reach 3.0 mG at the edge of the existing ROW (345kV - 135', 115kV - 110')</b>																												
345 kV Split Phase +30' (135' Pole) 115 kV Double Circuit +30' (110' Pole)	0.1	0.1	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.4	0.5	0.8	1.4	2.7	4.3	6.0	7.6	9.2	10.8	12.4	1.5	1.2	0.9	0.8	0.6	0.5	0.5	0.4
<b>Height Required to reach 0.6 mG at the edge of the existing ROW (345kV - 279', 115kV - 194')</b>																												
345 kV Split Phase +114' (219' Pole) 115 kV Double Circuit +114' (194' Pole)	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.3	0.3	0.3	0.2

**Typical Segment – Pease Road Junction to East Devon S/S in the Municipalities of Woodbridge, Orange, West Haven & Milford**

**Cross Section 8 (27GW Case) South Segment**

Site Condition	Transmission ROW																											
	150'	135'	120'	105'	90'	75'	60'	45'	30'	15'	S/E Edge	50'	25'	Center	25'	50'	NW Edge	15'	30'	45'	60'	75'	90'	105'	120'	135'	150'	
Existing Lines (For Reference)	0.9	1.0	1.2	1.4	1.7	2.1	2.8	3.8	5.6	9.0	15.8	27.7	47.7	61.4	65.9	69.9	77.7	19.3	13.3	9.5	7.0	5.3	4.2	3.3	2.7	2.3	1.9	
<b>OPTIONS</b>																												
345 kV Split Phase (105' Pole) 115 kV Double Circuit (80' Pole)	0.8	1.0	1.2	1.4	1.7	2.2	2.7	3.5	4.7	6.4	9.0	15.8	27.7	47.7	61.4	65.9	77.7	19.3	13.3	9.5	7.0	5.3	4.2	3.3	2.7	2.3	1.9	
345 kV Split Phase +30' (135' Pole) 115 kV Double Circuit +30' (110' Pole)	0.7	0.9	1.0	1.2	1.5	1.8	2.3	2.8	3.6	4.6	6.0	10.4	16.4	21.3	21.5	17.5	10.4	7.9	5.9	4.5	3.5	2.7	2.2	1.7	1.4	1.1	0.9	
345 kV Split Phase +45' (150' Pole) 115 kV Double Circuit +45' (125' Pole)	0.7	0.8	1.0	1.1	1.4	1.7	2.0	2.5	3.1	3.8	4.8	7.9	10.6	13.1	13.3	11.3	7.5	6.0	4.7	3.7	3.0	2.4	1.9	1.5	1.3	1.0	0.9	
345 kV Split Phase +70' (175' Pole) 115 kV Double Circuit +70' (150' Pole)	0.6	0.7	0.8	1.0	1.2	1.4	1.6	1.9	2.3	2.8	3.3	4.8	6.7	8.7	9.8	8.0	4.5	3.8	3.2	2.7	2.2	1.8	1.5	1.3	1.1	0.9	0.8	
345 kV Split Phase +94' (199' Pole) 115 kV Double Circuit +94' (174' Pole)	0.6	0.6	0.7	0.8	1.0	1.1	1.3	1.5	1.8	2.0	2.3	3.1	3.6	3.9	4.0	3.6	3.0	2.6	2.3	1.9	1.7	1.4	1.2	1.0	0.9	0.8	0.7	
<b>Height Required to reach 3.0 mG at the edge of the existing ROW (345kV - 199', 115kV - 174')</b>																												
345 kV Split Phase +94' (199' Pole) 115 kV Double Circuit +94' (174' Pole)	0.6	0.6	0.7	0.8	1.0	1.1	1.3	1.5	1.8	2.0	2.3	3.1	3.6	3.9	4.0	3.6	3.0	2.6	2.3	1.9	1.7	1.4	1.2	1.0	0.9	0.8	0.7	
<b>Height Required to reach 0.6 mG at the edge of the existing ROW (345kV - 319', 115kV - 294')</b>																												
345 kV Split Phase +214' (319' Pole) 115 kV Double Circuit +214' (294' Pole)	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.4	0.4	0.4	0.3	0.3	0.3	0.3



**“Homework Assignment”  
Revised 10/15/2004  
Reductions in Magnetic Fields from Increasing Transmission Structure Heights**

**Cross Section 5 (15GW Case)  
Typical Segment – Besek S/S to East Wallingford Junction in the Town of Wallingford**

Site Condition	Transmission ROW																											
	150'	135'	120'	105'	90'	75'	60'	45'	30'	15'	NW Edge	50'	25'	Center	25'	50'	NW Edge	15'	30'	45'	60'	75'	90'	105'	120'	135'	150'	
Existing Lines (For Reference)	1.6	1.8	2.0	2.2	2.4	2.7	3.0	3.4	3.9	4.5	5.2	17.6	26.5	56.1	102.0	123.7	24.7	18.2	13.9	10.9	8.8	7.3	6.1	5.2	4.5	3.9	3.4	
<b>OPTIONS</b>																												
Vertical Reconstructed ROW (130' Pole)	0.9	1.0	1.1	1.2	1.4	1.7	2.0	2.3	2.8	3.5	4.3	26.5	47.8	65.6	52.7	26.4	1.9	1.3	0.9	0.7	0.5	0.4	0.4	0.3	0.3	0.3	0.3	0.3
Vertical Reconstructed ROW + 20' (150' Pole)	0.8	0.9	1.0	1.2	1.4	1.6	1.8	2.2	2.6	3.1	3.8	15.5	22.6	26.4	22.9	14.0	1.7	1.2	0.9	0.7	0.6	0.5	0.4	0.4	0.3	0.3	0.3	0.3
Vertical Reconstructed ROW + 45' (175' Pole)	0.8	0.9	1.0	1.1	1.2	1.4	1.6	1.9	2.2	2.6	3.1	8.8	10.8	11.5	10.0	7.4	1.5	1.1	0.9	0.7	0.6	0.5	0.4	0.4	0.3	0.3	0.3	0.3
Vertical Reconstructed ROW + 69' (199' Pole)	0.7	0.8	0.9	1.0	1.1	1.3	1.4	1.6	1.9	2.1	2.5	5.4	6.1	6.3	5.6	4.5	1.3	1.0	0.8	0.7	0.6	0.5	0.4	0.4	0.3	0.3	0.3	0.3

**Height required to reach 3.0 mG at the edge of the existing ROW (345kV - 178')**

Vertical Reconstructed ROW + 48' (178' Pole)	0.8	0.9	1.0	1.1	1.2	1.4	1.6	1.9	2.2	2.5	3.0	8.2	10.0	10.5	9.3	6.9	1.5	1.1	0.9	0.7	0.6	0.5	0.4	0.4	0.3	0.3	0.3	0.3
--	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------	------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

**Height required to reach 0.6 mG at the edge of the existing ROW (345kV - 372')**

Vertical Reconstructed ROW + 242' (372' Pole)	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.4	0.4	0.4	0.4	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2
---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

**Cross Section 5 (27GW Case)  
Typical Segment – Besek S/S to East Wallingford Junction in the Town of Wallingford**

Site Condition	Transmission ROW																											
	150'	135'	120'	105'	90'	75'	60'	45'	30'	15'	S/E Edge	50'	25'	Center	25'	50'	NW Edge	15'	30'	45'	60'	75'	90'	105'	120'	135'	150'	
Existing Lines (For Reference)	4.0	4.3	4.8	5.3	5.8	6.5	7.3	8.3	9.4	10.8	12.6	42.6	71.9	136.6	248.5	391.1	60.1	44.2	33.8	26.6	21.5	17.7	14.8	12.6	10.8	9.4	8.3	
<b>OPTIONS</b>																												
Vertical Reconstructed ROW (130' Pole)	0.4	0.4	0.5	0.6	0.8	1.0	1.3	1.7	2.2	3.0	4.1	41.3	90.7	159.3	159.3	98.7	72.9	10.0	7.9	6.3	5.2	4.3	3.6	3.1	2.6	2.3	2.0	
Vertical Reconstructed ROW + 20' (150' Pole)	0.4	0.4	0.5	0.6	0.8	1.0	1.2	1.6	2.1	2.7	3.6	35.4	43.6	61.7	64.3	49.5	40.8	8.6	6.9	5.7	4.7	4.0	3.4	2.9	2.5	2.2	1.9	
Vertical Reconstructed ROW + 45' (175' Pole)	0.4	0.4	0.5	0.6	0.8	0.9	1.2	1.5	1.8	2.4	3.0	14.5	20.9	26.4	27.7	24.2	8.3	6.9	5.7	4.8	4.1	3.5	3.0	2.6	2.3	2.0	1.8	
Vertical Reconstructed ROW + 69' (199' Pole)	0.4	0.4	0.5	0.6	0.7	0.9	1.1	1.3	1.6	2.0	2.5	3.0	19.8	14.0	14.8	15.7	6.4	5.5	4.7	4.0	3.5	3.0	2.6	2.3	2.1	1.8	1.6	

**Height required to reach 3.0 mG at the edge of the existing ROW (345kV - 269')**

Vertical Reconstructed ROW + 139' (269' Pole)	0.4	0.4	0.5	0.5	0.6	0.7	0.8	0.9	1.1	1.3	1.4	3.1	3.6	3.9	4.1	4.1	3.0	2.7	2.5	2.3	2.1	1.9	1.7	1.6	1.4	1.3	1.2
---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

**Height required to reach 0.6 mG at the edge of the existing ROW (345kV - 477')**

Vertical Reconstructed ROW + 347' (477' Pole)	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5
---	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----