

STATE OF CONNECTICUT  
CONNECTICUT SITING COUNCIL

NORTHEAST UTILITIES SERVICE  
COMPANY APPLICATION TO THE  
CONNECTICUT SITING COUNCIL  
FOR A CERTIFICATE OF  
ENVIRONMENTAL COMPATIBILITY  
AND PUBLIC NEED ("CERTIFICATE")  
FOR THE CONSTRUCTION OF A  
NEW 345-KV ELECTRIC TRANSMISSION  
LINE FACILITY AND ASSOCIATED  
FACILITIES BETWEEN SCOVILL  
ROCK SWITCHING STATION IN  
MIDDLETOWN AND NORWALK  
SUBSTATION IN NORWALK, INCLUDING  
THE RECONSTRUCTION OF PORTIONS  
OF EXISTING 115-KV AND 345-KV  
ELECTRIC TRANSMISSION LINES,  
THE CONSTRUCTION OF BESECK  
SWITCHING STATION IN  
WALLINGFORD, EAST DEVON  
SUBSTATION IN MILFORD, AND  
SINGER SUBSTATION IN BRIDGEPORT,  
MODIFICATIONS AT SCOVILL ROCK  
SWITCHING STATION AND NORWALK  
SUBSTATION, AND THE  
RECONFIGURATION OF CERTAIN  
INTERCONNECTIONS

DOCKET NO. 272

DECEMBER 3, 2004

KEMA RESPONSES TO PRE-HEARING QUESTIONS  
FROM THE CONNECTICUT LIGHT AND POWER COMPANY

Question: (unnumbered – request to the Council)

Provide the load impedances and impedance angles vs. frequency characteristics that were used in the analyses in the KEMA, Inc. report of October 18, 2004?

Response to CL&P Interrogatory, dated December 3, 2004:

KEMA does not have load information in the form requested. KEMA provided active and reactive loads by bus to the PowerFactory program, based on the results of the Applicant's load flow studies provided in response to a data request by the Towns. Using this load information and the results of a converged power flow analysis, the PowerFactory program models the equivalent load at each bus as a shunt-connected branch of parallel resistance, inductance and capacitance. KEMA does not have the associated equivalent impedances, which are calculated internally by the PowerFactory program.