

East Devon to Singer – 15GW Case
HPFF Cable

Horizontal Distance (ft)	(mG)
-50	0.0
-49	0.0
-48	0.0
-47	0.0
-46	0.0
-45	0.0
-44	0.0
-43	0.0
-42	0.1
-41	0.1
-40	0.1
-39	0.1
-38	0.1
-37	0.1
-36	0.1
-35	0.1
-34	0.1
-33	0.1
-32	0.1
-31	0.1
-30	0.1
-29	0.1
-28	0.1
-27	0.1
-26	0.1
-25	0.1
-24	0.1
-23	0.2
-22	0.2
-21	0.2
-20	0.2
-19	0.2
-18	0.2
-17	0.3
-16	0.3
-15	0.3
-14	0.4
-13	0.4
-12	0.5
-11	0.5

East Devon to Singer – 15GW Case
HPFF Cable

Horizontal Distance (ft)	(mG)
-10	0.6
-9	0.7
-8	0.8
-7	0.9
-6	1.1
-5	1.3
-4	1.4
-3	1.6
-2	1.8
-1	1.9
0	1.9
1	1.9
2	1.8
3	1.6
4	1.4
5	1.3
6	1.1
7	0.9
8	0.8
9	0.7
10	0.6
11	0.5
12	0.5
13	0.4
14	0.4
15	0.3
16	0.3
17	0.3
18	0.2
19	0.2
20	0.2
21	0.2
22	0.2
23	0.2
24	0.1
25	0.1
26	0.1
27	0.1
28	0.1
29	0.1
30	0.1

East Devon to Singer – 15GW Case
HPFF Cable

Horizontal Distance (ft)	(mG)
31	0.1
32	0.1
33	0.1
34	0.1
35	0.1
36	0.1
37	0.1
38	0.1
39	0.1
40	0.1
41	0.1
42	0.1
43	0.0
44	0.0
45	0.0
46	0.0
47	0.0
48	0.0
49	0.0
50	0.0