

Singer to Norwalk – 15GW Case
HPFF Cable

Horizontal Distance (ft)	(mG)
-50	0.0
-49	0.0
-48	0.1
-47	0.1
-46	0.1
-45	0.1
-44	0.1
-43	0.1
-42	0.1
-41	0.1
-40	0.1
-39	0.1
-38	0.1
-37	0.1
-36	0.1
-35	0.1
-34	0.1
-33	0.1
-32	0.1
-31	0.1
-30	0.1
-29	0.1
-28	0.1
-27	0.1
-26	0.2
-25	0.2
-24	0.2
-23	0.2
-22	0.2
-21	0.2
-20	0.2
-19	0.3
-18	0.3
-17	0.3
-16	0.4
-15	0.4
-14	0.5
-13	0.5
-12	0.6
-11	0.7
-10	0.8

Singer to Norwalk – 15GW Case
HPFF Cable

Horizontal Distance (ft)	(mG)
-9	0.9
-8	1.0
-7	1.2
-6	1.4
-5	1.6
-4	1.8
-3	2.1
-2	2.2
-1	2.4
0	2.4
1	2.4
2	2.2
3	2.1
4	1.8
5	1.6
6	1.4
7	1.2
8	1.0
9	0.9
10	0.8
11	0.7
12	0.6
13	0.5
14	0.5
15	0.4
16	0.4
17	0.3
18	0.3
19	0.3
20	0.2
21	0.2
22	0.2
23	0.2
24	0.2
25	0.2
26	0.2
27	0.1
28	0.1
29	0.1
30	0.1

Singer to Norwalk – 15GW Case
HPFF Cable

Horizontal Distance (ft)	(mG)
31	0.1
32	0.1
33	0.1
34	0.1
35	0.1
36	0.1
37	0.1
38	0.1
39	0.1
40	0.1
41	0.1
42	0.1
43	0.1
44	0.1
45	0.1
46	0.1
47	0.1
48	0.1
49	0.0
50	0.0