



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@po.state.ct.us

www.ct.gov/csc

April 6, 2005

Maurice R. Scully, Executive Director
Connecticut Municipal Electric Energy
Cooperative
30 Stott Avenue
Norwich, CT 06360-1526

RE: **DOCKET NO. F-2005** – Connecticut Siting Council Review of the Ten-Year Forecast
of Connecticut Electric Loads and Resources

Dear Mr. Scully:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than April 27, 2005. To help expedite the Council's review, please file individual responses as soon as they are available.

Please forward an original and 20 copies to this office. In accordance with the State Solid Waste Management Plan, the Council is requesting that all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. A list of parties and intervenors is enclosed. Fewer copies of bulk material may be provided as appropriate.

Yours very truly,

S. Derek Phelps
Executive Director

SDP/MP

c: Council Members
Parties and Intervenors

Docket F-2005
CMEEC Pre-Hearing Interrogatories, Set One

1. How does the Connecticut Municipal Electric Energy Cooperative (CMEEC) compute seasonal claimed capability?
2. In Table I of CMEEC's 2005 Forecast of Electric Loads and Resources (CMEEC Forecast), are the System Energy Requirements and Summer Coincident Peak Demand columns weather normalized? If no, provide these two columns as weather normalized.
3. In Table I of the CMEEC Forecast, is the summer coincident peak demand based on a 50/50 scenario (i.e. the forecast peak has a 50 percent chance of being exceeded)? Explain.
4. Identify the generating facilities listed in the CMEEC Forecast that have black start capability, if any.
5. List the technologies CMEEC members have in place to monitor and communicate voltage fluctuations? Identify transmission system conditions and actions to maintain and protect the grid and customers.
6. In the April 2005 ISO-New England Seasonal Claimed Capability Report, the Norwich Tenth Street plant has a winter rating of 1.23 MW. Does CMEEC agree with that number?