



March 1, 2021

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: Docket No. F-2014/2015

Dear Melanie Bachman:

I am writing in response to the 2012 Connecticut General Statutes Title 16 – Public Service Companies Chapter 277a – Public Utility Environmental Standards Act Section 16-50r – Report of forecast of loads and resources for the Town of Wallingford CT Department of Public Utilities.

The attached document includes:

- A tabulation of estimated peak loads
- Data on energy use and peak loads for the five preceding calendar years

Enclosed is one signed original and 15 hard copies of the report.

Sincerely,

Michelle Coscia

ENCLOSURE



March 1, 2021



Michelle Coscia
Energy New England
5 Hampshire Street. #100
Mansfield, MA 02048

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Melanie Bachman,

(1) A tabulation of estimated peak loads for each year 2021-2030

YEAR	2021	2022	2023	2024	2025
Peak MW	127.218	128.108	129.005	129.908	130.817

YEAR	2026	2027	2028	2029	2030
Peak MW	131.733	132.655	133.584	134.519	135.461

(2) Data on energy use and peak loads for the five preceding calendar years 2016-2020

YEAR	2020	2019	2018	2017	2016
Peak MW	122.523	126.335	129.912	126.632	130.687

YEAR	2020	2019	2018	2017	2016
MWH Load	417,105	583,621	615,485	596,391	611,919

Sincerely

Michelle Coscia
Senior Energy Analyst
Energy New England