



February 25, 2026

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: Docket No. F-2014/2015

Dear Melanie Bachman:

I am writing in response to the 2012 Connecticut General Statutes Title 16 – Public Service Companies Chapter 277a – Public Utility Environmental Standards Act Section 16-50r – Report of forecast of loads and resources for the Town of Wallingford CT Department of Public Utilities.

The attached document includes:

- A tabulation of estimated peak loads
- Data on energy use and peak loads for the five preceding calendar years

Sincerely,

Michelle Coscia

ENCLOSURE



2/25/2026



Michelle Coscia
Energy New England
5 Hampshire Street. #100
Mansfield, MA 02048

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Melanie Bachman,

(1) A tabulation of estimated peak loads for each year 2026-2035

YEAR	2026	2027	2028	2029	2030
Peak MW	135.1	137.4	138.4	138.1	138.1

YEAR	2031	2032	2033	2034	2035
Peak MW	139.5	140.9	142.3	143.7	145.1

(2) Data on energy use and peak loads for the five preceding calendar years 2020-2025

YEAR	2021	2022	2023	2024	2025
Peak MW	129.631	127.626	124.993	127.868	129.872

YEAR	2021	2022	2023	2024	2025
MWH Load	557,638	581,976	549,382	553,763	556,250

Sincerely

Michelle Coscia
Manager, Market Operations
Energy New England