



DEPARTMENT OF ADMINISTRATIVE SERVICES

PROPOSED CHANGE OF THE CONNECTICUT STATE BUILDING CODE AND FIRE SAFETY CODE

DATE SUBMITTED: 5-24-21

CODE INFORMATION

Proposed change to: ☒ **Building Code** ☐ Fire Safety Code
Code section(s): 2021 Connecticut Residential Code - Section M1402

PROPONENT INFORMATION

Name: Mary E. Koban
Telephone: (484) 220-3011
Address: 2311 Wilson Blvd, Suite 400
Street Address

Representing: Air-Conditioning, Heating, and Refrigeration
Institute (AHRI)
Email: mkoban@ahrinet.org
Arlington
Town

VA
State

22201
Zip Code

PROPOSAL INFORMATION

Description of change and reason for change (attach additional information as needed):

- Update standard reference in Section M1402 – ANCE is no longer associated with this standard after the 2nd edition.

Proposed text change, addition or deletion (attach additional information as needed):

SECTION M1402 CENTRAL FURNACES

M1402.1 General.

Oil-fired central furnaces shall conform to ANSI/UL 727. Electric furnaces shall conform to UL 1995 or UL/CSA/~~ANCE~~ 60335-2-40.

Supporting data and documents (attach additional information as needed)

The references to ANCE as a sponsor of this UL/CSA 60335-2-40 standard has been removed as ANCE in Mexico withdrew from the 3rd Edition is no longer associated with this standard after the 2nd Edition.

- ☒ **This Proposal is original material.** (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought or research and, to the best of his/her knowledge, is not copied from another source.)
- ☐ **This Comment is not original material, its source (if known) is as follows:** (such as material / code development proposal from a prior development cycle or proposal submitted to model code committee etc.)
- ☐ **I would like to make an in-person presentation of my proposal.**

Release

I hereby grant the State of Connecticut full rights to the use of this material without benefit to me, including, but not limited to, publication and reproduction rights.

Proponent's Signature



Printed Name: Mary E. Koban

PLEASE EMAIL (PREFERRED) TO DAS.CodesStandards@CT.GOV OR MAIL OR FAX (SEE BELOW)

*Department of Administrative Services
Office of the State Building Inspector
450 Columbus Boulevard, Suite 1303
Hartford, CT 06103
Tel: 860-713-5900 Fax: 860-713-7410
Affirmative Action/Equal Opportunity Employer*

12/29/16