

STATE BUILDING CODE INTERPRETATION NO. I-09-12R (Revised)

March 16, 2012

The following is in response to your request for formal interpretation dated March 13, 2012.

Question:

Does Section 1109.2.4, of the 2003 International Building Code portion of the 2005 State Building Code, only require the additional grab bar within one men's and women's toilet room per floor?

Answer:

Yes, the above code section states in part that a separate, additional swing grab bar shall be provided at a minimum of one accessible toilet location for each gender per floor within any nonexempt building.