

STATE BUILDING CODE INTERPRETATION NO. I-44-99

October 13, 1999

The following is offered in response to your communication to me in which you seek a determination of whether or not the 1995 CABO One and Two Family Dwelling Code portion of the 1999 State Building Code allows combustion air to be taken from within a garage where the heater is located and is not enclosed.

Answer: Yes, provided that such installation complies with Section 1307.3 for appliances that are not enclosed in a separate compartment within such garage and the manufacturer's installation instructions.